

START

007282

Part: OLB
GMC
JCW

cc: ~~Smith~~
JARS
NRM
KRG
Gut
RAX

INTERIM
UCRL - 15910


**DESIGN AND EVALUATION GUIDELINES FOR
DEPARTMENT OF ENERGY FACILITIES
SUBJECTED TO NATURAL PHENOMENA HAZARDS**

by

Robert P. Kennedy
Stephen A. Short
James R. McDonald
Martin W. McCann
Robert C. Murray

prepared for

The Office of the Assistant Secretary for
Environment, Safety & Health
Office of Safety Appraisals
United States Department of Energy




October 1989

RECEIVED
DEC 6 1989
D.E. SMYSON

9 2 1 3 9 3 1 3 1 4

**THIS PAGE INTENTIONALLY
LEFT BLANK**



PREFACE

The guidelines presented herein were prepared for Lawrence Livermore National Laboratory (LLNL) under contract to the Assistant Secretary for Environment, Safety and Health, Office of Safety Appraisals of the U.S. Department of Energy (DOE/OSA). The Project Manager was Mr. J. R. Hill of DOE/OSA. Dr. R. C. (Bob) Murray was the Project Manager for LLNL. These guidelines were prepared under the direction of the Department of Energy Natural Phenomena Hazards Panel. The general material in this document as well as specific earthquake guidelines have been written by Bob Kennedy and Steve Short. The wind guidelines were prepared by Jim McDonald; the flood guidelines were prepared by Marty McCann. Bob Murray provided overall direction, guidance, and review. The authors and their affiliations are:

Robert P. Kennedy	RPK Structural Mechanics Consulting
Stephen A. Short	Impell Corporation
James R. McDonald	Texas Tech University
Martin W. McCann	Jack R. Benjamin & Associates
Robert C. Murray	Lawrence Livermore National Laboratory

The guidelines have been extensively reviewed by panel members and selected consultants. Additionally, review comments from throughout the DOE complex have been received and incorporated into this document. Panel and independent reviewers and their affiliations are listed below.

James E. Beavers	Martin Marietta Energy Systems, Inc.
Catalino B. Cecilio*	Private Consultant
A. H. Hadjian*	Private Consultant
James R. Hill	DOE Office of Safety Appraisals
Frank E. McClure	Lawrence Berkeley Laboratory
Joseph P. Nicoletti	URS/J.A. Blume & Associates
John W. Reed	Jack R. Benjamin & Associates
Jean B. Savy*	Lawrence Livermore National Laboratory
John D. Stevenson*	Stevenson & Associates
Delano F. Surdahl	DOE Albuquerque Operations
Peter I. Yanev	EQE Engineering

* Independent Reviewers

These guidelines are being presented for review and trial use at DOE facilities. Comments should be addressed to Bob Murray, Lawrence Livermore National Laboratory, P.O. Box 808, Livermore, CA 94550, (415) 422-0308.

ABSTRACT

Uniform design and evaluation guidelines have been developed for protection against natural phenomena hazards for facilities at DOE sites throughout the United States. The guidelines apply to design of new facilities and to evaluation, modification, or upgrade of existing facilities. The goal of the guidelines is to assure that DOE facilities are constructed to safely withstand the effects of natural phenomena such as earthquakes, extreme winds, and flooding.

DOE Order 6430.1A, the General Design Criteria Manual, has recently been revised and material from these guidelines are referenced by the revised Order as an acceptable approach for the design or evaluation of DOE facilities for the effects of natural phenomena hazards. This document provides earthquake ground acceleration, wind speeds, tornado wind speeds and other effects, and flood levels corresponding to the DBE, DBW, DBT, and DBFL as defined in 6430.1A.

The design and evaluation guidelines presented in this document are intended to control the level of conservatism introduced in the design/evaluation process such that earthquake, wind, and flood hazards are treated on a reasonably consistent and uniform basis and such that the level of conservatism is appropriate for facility characteristics such as importance, cost, and hazards to on-site personnel, the general public, and the environment. For each natural phenomena hazard covered, these guidelines generally consist of the following:

1. Facility-use categories and facility performance goals.
2. Hazard probability from which facility loading is developed.
3. Recommended design and evaluation procedures to evaluate facility response to hazard loads and criteria to assess whether or not computed response is permissible.

The first step in these design and evaluation guidelines is to establish performance goals expressed as the annual probability of exceedance of some level of facility damage due to natural phenomena hazards. The appropriate performance goal for a facility is dependent on facility characteristics such as mission dependence, cost, and hazardous functions. As an aid to selecting performance goals, facility-use categories ranging from general use to highly hazardous use have been defined along with a corresponding performance goal. Performance goal probability levels for each category are consistent with current common design practice for general use and high hazard use facilities.

The likelihood of occurrence of natural phenomena hazards at DOE sites has been evaluated. Probabilistic hazard models for earthquake, extreme wind/tornado, and flood for each DOE site are available from earlier phases of the DOE Natural Phenomena Hazard Program. To achieve the facility performance goal, hazard annual probabilities of exceedance are specified with design and evaluation procedures that provide a consistent level of conservatism.

While performance goals and hazard levels are expressed in this document in probabilistic terms, deterministic design and evaluation procedures are presented. Design/evaluation procedures recommended in this document are intended to conform closely to common standard practices such that they are easily understood by most engineers. The intended audience for these guidelines is primarily the civil/structural or mechanical engineers conducting the design or evaluation of facilities.

Performance goals are expressed in terms of structure or equipment damage to the extent that the facility cannot function, that the facility would need to be replaced, or that personnel are endangered. The performance goals in this document do not refer to the consequences of structure or equipment damage beyond those just described. For example, this document does not attempt to set performance goals in terms of off-site release of hazardous materials, general public safety, or environmental damage per NRC safety goals. These guidelines contain information needed for the first two steps in a natural phenomena risk assessment: characterization of the hazard and procedures for structural analysis. The remaining steps in estimating risk extend to consequences beyond the levels of facility damage addressed in the performance goals, and these steps are not covered in this document.

TABLE OF CONTENTS

PREFACE	iii
ABSTRACT	iv
TABLE OF CONTENTS	vi
TABLE OF TABLES	ix
TABLE OF FIGURES	x
1 INTRODUCTION	1-1
1.1 OVERVIEW OF THE DOE NATURAL PHENOMENA HAZARDS PROJECT	1-1
1.2 OVERVIEW OF THE DESIGN AND EVALUATION GUIDELINES	1-3
1.3 TERMINOLOGY AND DEFINITIONS	1-6
1.4 EARTHQUAKE, WIND, AND FLOOD HAZARDS FOR DOE FACILITIES	1-8
2 GENERAL DESIGN AND EVALUATION GUIDELINES	2-1
2.1 DESIGN AND EVALUATION PHILOSOPHY	2-1
2.2 PERFORMANCE GOALS AND FACILITY-USE CATEGORIES	2-3
2.2.1 Facility-Use Categories	2-4
2.2.2 Performance Goals	2-6
2.3 EVALUATION OF EXISTING FACILITIES	2-7
2.4 QUALITY ASSURANCE AND PEER REVIEW	2-10
3 EFFECTS OF NATURAL PHENOMENA HAZARDS	3-1
3.1 EFFECTS OF EARTHQUAKES	3-1
3.2 EFFECTS OF WIND	3-4
3.2.1 Wind Pressures	3-4
3.2.2 Additional Adverse Effects of Tornadoes	3-6
3.2.3 Effects on Structural Systems	3-7
3.2.4 Effects on Cladding	3-8
3.3 EFFECTS OF FLOODING	3-10
3.3.1 Causes and Sources of Flooding and Flood Hazards	3-10
3.3.2 Flooding Damage	3-11

TABLE OF CONTENTS (cont'd)

4 EARTHQUAKE DESIGN AND EVALUATION GUIDELINES	4-1
4.1 INTRODUCTION	4-1
4.2 SEISMIC GUIDELINES FOR EACH FACILITY-USE CATEGORY	4-2
4.2.1 General	4-2
4.2.2 Evaluation of General Use & Important or Low Hazard Facility Seismic Behavior	4-3
4.2.3 Evaluation of Moderate & High Hazard Facility Seismic Behavior	4-8
4.3 EARTHQUAKE DESIGN DETAILS AND QUALITY ASSURANCE	4-10
4.4 OTHER SEISMIC DESIGN AND EVALUATION CONSIDERATIONS	4-16
4.4.1 Effective Peak Ground Motion	4-16
4.4.2 Soil-Structure Interaction (SSI)	4-18
4.4.3 Combination of Earthquake Components	4-22
4.4.4 Special Considerations for Equipment and Piping	4-23
4.4.5 Special Considerations for Evaluation of Existing Facilities	4-27
5 DESIGN AND EVALUATION CRITERIA FOR WIND LOAD	5-1
5.1 INTRODUCTION	5-1
5.2 CRITERIA FOR DESIGN OF FACILITIES	5-5
5.2.1 General Use Facilities	5-8
5.2.2 Important or Low Hazard Facilities	5-10
5.2.3 Moderate Hazard Facilities	5-11
5.2.4 High Hazard Facilities	5-13
5.2.5 Recommended Design Wind Speeds for Specific DOE Sites	5-14
5.3 CRITERIA FOR EVALUATION OF EXISTING FACILITIES	5-16
5.3.1 Data Collection	5-16
5.3.2 Analysis of Components	5-17
5.3.3 Postulation of Failure Mechanism	5-18
5.3.4 Comparison of Postulated Performance with Performance Goals	5-18

TABLE OF CONTENTS (cont'd)

6 FLOOD DESIGN AND EVALUATION GUIDELINES	6-1
6.1 FLOOD DESIGN OVERVIEW	6-1
6.1.1 DESIGN BASIS FLOOD (DBFL)	6-1
6.1.2 EVALUATION OF SITE CONDITIONS	6-3
6.1.3 FLOOD DESIGN STRATEGIES	6-5
6.2 DOE FLOOD HAZARD ASSESSMENTS	6-5
6.3 FLOOD DESIGN GUIDELINES FOR EACH FACILITY-USE CATEGORY	6-7
6.3.1 General Use Facilities	6-8
6.3.2 Important or Low Hazard Facilities	6-8
6.3.3 Moderate Hazard Facilities	6-9
6.3.4 High Hazard Facilities	6-9
6.4 FLOOD DESIGN PRACTICE FOR FACILITIES BELOW THE DBFL ELEVATION	6-10
6.4.1 Flood Loads	6-10
6.4.2 Design Requirements	6-10
6.4.2.1 General Use and Important or Low Hazard Facilities	6-11
6.4.2.2 Moderate and High Hazard Facilities	6-11
6.4.3 Design of Other Civil Engineering Facilities	6-11
6.4.4 Flood Protection Structures	6-11
6.5 FLOOD RISK ASSESSMENT	6-12
APPENDIX A COMMENTARY ON SEISMIC DESIGN AND ANALYSIS GUIDELINES	A-1
A.1 Basic Approach for Earthquake Design and Evaluation at Appropriate Lateral Force Levels	A-1
A.2 Earthquake Hazard Annual Exceedance Probabilities	A-4
A.3 Earthquake Ground Motion Response Spectra	A-6
A.4 Static Force Method of Seismic Analysis	A-8
A.5 Dynamic Seismic Analysis	A-9
A.6 Analytical Treatment of Energy Dissipation and Absorption	A-11
A.7 Basis for Seismic Guidelines for Important or Low Hazard, Moderate Hazard, and High Hazard Facilities	A-15
REFERENCES	R-1

TABLE OF TABLES

TABLE 2-1 FACILITY-USE CATEGORY GUIDELINES	2-4
TABLE 2-2 COMPARISON OF FACILITY-USE CATEGORIES FROM VARIOUS SOURCES	2-5
TABLE 2-3 PERFORMANCE GOALS FOR EACH FACILITY-USE CATEGORY	2-6
TABLE 3-1 CAUSES OF FLOODING	3-10
TABLE 3-2 FLOOD DAMAGE SUMMARY	3-12
TABLE 4-1 SUMMARY OF EARTHQUAKE EVALUATION GUIDELINES	4-3
TABLE 4-2 CODE REDUCTION COEFFICIENTS, R_w AND INELASTIC DEMAND CAPACITY RATIOS, F_u	4-6
TABLE 4-3 MAXIMUM HORIZONTAL GROUND SURFACE ACCELERATIONS AT DOE SITES	4-7
TABLE 4-4 RECOMMENDED DAMPING VALUES	4-9
TABLE 4-5 FREQUENCY DEPENDENT ELASTIC HALF-SPACE IMPEDANCE	4-21
TABLE 5-1 TYPES OF WIND FOR DESIGN LOADS	5-3
TABLE 5-2 RELATIONSHIP BETWEEN TORNADO WIND SPEEDS AND FASTEST-MILE WIND SPEEDS	5-5
TABLE 5-3 SUMMARY OF MINIMUM WIND DESIGN CRITERIA	5-6
TABLE 5-4 RECOMMENDED BASIC WIND SPEEDS FOR DOE SITES	5-7
TABLE 5-5 IMPORTANCE FACTORS AND EFFECTIVE VELOCITY PRESSURES	5-8
TABLE 6-1 FLOOD GUIDELINES SUMMARY	6-1
TABLE 6-2 DESIGN BASIS FLOOD EVENTS	6-2
TABLE A-1 INELASTIC DEMAND-CAPACITY RATIOS FROM EQUATION A-7 AND REFERENCE 11	A-21

TABLE OF FIGURES

FIGURE 1-1 FLOW DIAGRAM OF THE NATURAL PHENOMENA HAZARDS PROJECT	1-1
FIGURE 1-2 FLOW DIAGRAM FOR ASSESSMENT OF RISK FROM NATURAL PHENOMENA HAZARDS	1-4
FIGURE 1-3 EXAMPLE SEISMIC HAZARD CURVE	1-8
FIGURE 1-4 EXAMPLE WIND/TORNADO HAZARD CURVE	1-9
FIGURE 1-5 EXAMPLE FLOOD HAZARD CURVE	1-9
FIGURE 2-1 EXISTING FACILITY EVALUATION APPROACH	2-8
FIGURE 4-1 EXAMPLE DESIGN/EVALUATION EARTHQUAKE GROUND MOTION RESPONSE SPECTRUM	4-5
FIGURE 5-1 STRAIGHT WIND AND TORNADO REGIONS OF WIND HAZARD CURVES	5-2
FIGURE 6-1 FLOOD EVALUATION PROCEDURE	6-3
FIGURE A-1 COMPARISON OF 1988 UBC ZC WITH TYPICAL DESIGN/EVALUATION RESPONSE SPECTRUM	A-7
FIGURE A-2 CYCLIC LOAD-DEFLECTION BEHAVIOR OF CONCRETE SHEAR WALLS AND STEEL BRACED FRAMES	A-12

1 INTRODUCTION

1.1 OVERVIEW OF THE DOE NATURAL PHENOMENA HAZARDS PROJECT

Lawrence Livermore National Laboratory (LLNL), under contract to the Assistant Secretary for Environment, Safety and Health, Office of Safety Appraisals (OSA) of the U.S. Department of Energy (DOE), is developing uniform design and evaluation criteria for protection against natural phenomena hazards for facilities at DOE sites throughout the United States. The overall goal of this program is to provide guidance and criteria for design of new facilities and for evaluation, modification, or upgrade of existing facilities such that DOE facilities are adequately constructed to safely withstand the effects of natural phenomena such as earthquakes, extreme winds, and flooding. This goal is being achieved by the natural phenomena hazards program illustrated in Figure 1-1.




FIGURE 1-1.
FLOW DIAGRAM OF THE NATURAL PHENOMENA HAZARDS PROJECT

This program consists of the following phases:

1. Gathering information including selection of specific DOE sites to be included in the project and identifying existing critical facilities at each site.
2. Evaluating the likelihood for natural phenomena hazards at DOE sites. Previously developed hazard models for earthquake, extreme wind/tornado, and flood at each DOE site.
3. Preparing design and evaluation guidelines that utilize information on the likelihood of natural phenomena hazards for the design of new facilities and the renovation, modification, or upgrade of existing facilities.
4. Preparing manuals describing and illustrating good design practice for structures, equipment, piping, etc. for earthquake and wind/tornado loadings. These manuals will be used in either design of new facilities or upgrading of existing facilities. Also, conducting supporting studies on specific problem areas related to the mitigation of natural phenomena hazards.

The guidelines presented in this document are the results of the third phase of this program. These guidelines, along with manuals on structural details and supporting studies on specific problem areas, should enable DOE and site personnel to design or evaluate facilities for the effects of natural phenomena hazards on a uniform and rational basis.

Several phases have been completed. The first phase - selecting DOE sites and identifying critical facilities - was completed many years ago. The development of probabilistic definitions of earthquake and wind hazards at 25 DOE sites across the country has also been completed. The seismic hazard definitions have been published in LLNL report UCRL 53582, Rev. 1 (Reference 1). The wind/tornado hazard definitions have been published in LLNL report UCRL 53526, Rev. 1 (Reference 2). Note that seismic hazard estimates have been changing rapidly during the last 5 years since Ref. 1 was completed. A number of ongoing studies which are not currently available will provide the basis for upgrading Ref. 1 in the future. However, Ref. 1 represents the best currently available information on seismic hazard at DOE sites.

There is an ongoing flood screening evaluation to establish which sites have a potential flood hazard and which sites do not and to develop preliminary probabilistic flood hazard definitions. These evaluations have currently been completed for the eight Albuquerque Operations Office sites and for the Richland Operations Office site, with results being published in LLNL report UCRL 53851 (Reference 3). Through the use of screening analysis, flooding can be eliminated for some sites as a design consideration. For those sites in which flooding is a significant design consideration, probabilistic definitions of the flood hazard will be refined by additional investigation.

Design and evaluation guidelines (i.e., Phase 3) have been prepared and are presented in this document. A wind design practice manual has been completed. Preparation of a seismic design practice manual is now being planned. In addition, supporting studies have been published on seismic bracing of suspended ceilings (Reference 4) and on seismic upgrade and strengthening guidelines for equipment (Reference 5).

1.2 OVERVIEW OF THE DESIGN AND EVALUATION GUIDELINES

The design and evaluation guidelines presented in this document are intended to provide relatively straightforward procedures to evaluate, modify, or upgrade existing facilities or design new facilities for the effects of natural phenomena hazards. The guidelines are intended to control the level of conservatism introduced in the design/evaluation process such that: (1) earthquake, wind, and flood hazards are treated on a reasonably consistent and uniform basis; and (2) the level of conservatism is appropriate for facility characteristics such as, importance, cost, and hazards to on-site personnel, the general public, and the environment.

For each natural phenomena hazard covered by this report, these guidelines generally consist of the following:

1. Facility-use categories and facility performance goals.
2. Hazard probability from which facility loading is developed.
3. Recommended design and evaluation procedures to evaluate facility response to hazard loads and criteria to assess whether or not computed response is permissible.

Note that these guidelines do not cover practice and procedures for facility design or upgrading detailing; these matters are to be covered by separate documents.

The first step in these design and evaluation guidelines is to establish performance goals expressed as the annual probability of exceedance of some level of facility damage due to natural phenomena hazards. The appropriate performance goal for a facility is dependent on facility characteristics such as mission dependence, cost, and hazardous functions of the facility. As an aid to selecting performance goals, facility-use categories ranging from general use to highly hazardous use have been defined, along with a corresponding performance goal. Performance goal probability levels for each category are consistent with current common design practice for general use and high-hazard use facilities.

To achieve the facility performance goal, hazard annual probabilities of exceedance are specified along with design and evaluation procedures with a consistent level of conservatism. While performance goals and hazard levels are expressed in this document in probabilistic terms, deterministic design and evaluation procedures are presented. Design/evaluation procedures recommended in this document are intended to conform closely to common standard practices such that they are easily understood by most engineers. Note that these guidelines do not preclude the use of probabilistic approaches or alternative approaches, which are also acceptable if it can be demonstrated that the specified performance goals are met.

The framework under which these guidelines have been developed allows for their use in an overall risk assessment as shown in Figure 1-2.




FIGURE 1-2.
FLOW DIAGRAM FOR ASSESSMENT OF RISK
FROM NATURAL PHENOMENA HAZARDS

These guidelines contain information needed for the first two steps in a natural phenomena risk assessment: (1) characterization of the hazard and (2) procedures for structural analysis. The remaining steps in estimating risk are not covered in this document. For an example of an overall risk assessment applied to commercial plutonium fabrication facilities, see References 6 and 7. The resulting estimate from an overall risk assessment could be compared with the NRC Safety Goals (Reference 8) to decide if the risk is acceptable.

Performance goals are expressed in terms of structure or equipment damage to the extent that the facility cannot function, that the facility would need to be replaced, or that personnel safety is endangered. The performance goals in this document do not refer to the consequences of structure or equipment damage beyond those just described. For example, this document does not attempt to set performance goals in terms of off-site release of hazardous materials, general public safety, or environmental damage. The intended audience for the guidelines in this report is primarily the civil/structural or mechanical engineer conducting the design or evaluation of facilities. The interests of safety engineers extend to consequences beyond the levels of facility damage addressed in this document.

Existing criteria for the design and evaluation of DOE facilities are provided by the General Design Criteria Manual, DOE Order 6430.1A (Reference 9). DOE Order 6430.1A has recently been revised, and material from these guidelines are referenced by the revised Order as an acceptable approach for the design or evaluation of DOE facilities for the effects of natural phenomena hazards. DOE 6430.1A requires that facilities be designed for design basis events including natural phenomena hazards, fire, accidents, etc. Design basis events due to natural phenomena hazards as defined in 6430.1A include earthquakes (DBE), winds (DBW), tornadoes (DBT), and floods (DBFL). This document provides earthquake ground acceleration, wind speeds, tornado wind speeds and other effects, and flood levels corresponding to these events for usage in design and evaluation of facilities.

The remainder of this chapter defines some of the terminology used in this report and briefly describes the seismic, wind, and flood hazard information from References 1, 2, and 3. Chapter 2 covers aspects of these design and evaluation guidelines common to all natural phenomena hazards. In particular, facility-use categories and performance goals are discussed in this chapter. Chapter 3 provides general discussion of the effects of natural phenomena hazards on facilities. Specific design and evaluation guidelines for earthquakes, extreme winds, and floods are presented in Chapters 4, 5, and 6, respectively. In particular, these chapters discuss recommended hazard probabilities as well as design and evaluation procedures for response evaluation and permissible behavior criteria.

1.3 TERMINOLOGY AND DEFINITIONS

HAZARD - The term "hazard" is defined as a source of danger. In this report, natural phenomena such as earthquakes, extreme winds, and floods are hazards to the buildings, equipment, piping, and other structures making up DOE facilities. Toxic or radioactive materials contained within facilities are also hazards to the population or environment in the vicinity of DOE facilities. Throughout this report, the term "hazard" is used to mean both the external sources of danger (such as potential earthquakes, extreme winds, or floods) and internal sources of danger (such as toxic or radioactive materials).

ANNUAL PROBABILITY OF EXCEEDANCE - The likelihood of natural phenomena hazards has been evaluated on a probabilistic basis in References 1, 2, and 3. The frequency of occurrence of parameters describing the external hazard severity (such as maximum earthquake ground acceleration, maximum wind speed, or maximum depth of inundation) is estimated by probabilistic methods. Common frequency statistics employed for rare events such as natural phenomena hazards include return period and annual probability of exceedance. Return period is the average time between consecutive events of the same or greater severity (for example, earthquakes with maximum ground acceleration of 0.2g or greater). It must be emphasized that the return period is only an average duration between events and should not be construed as the actual time between occurrences, which would be highly variable. If a given event of return period, T, is equally likely to occur any year, the probability of that event being exceeded in any one year is approximately 1/T. The annual probability of exceedance, p, of an event is the reciprocal of the return period of that event. As an example, consider a site at which the return period for an earthquake of 0.2g or greater is 1000 years. In this case, the annual probability of exceedance of 0.2g is 10^{-3} or 0.1 percent.

EXCEEDANCE PROBABILITY FOR A GIVEN NUMBER OF YEARS - It is of interest in the design of facilities to define the probability that an event will be exceeded during the design life of the facilities. For an event with return period, T, and annual probability of exceedance, p, the exceedance probability, EP, over design life, n, is given by:

$$EP = 1 - (1 - p)^n = 1 - (1 - 1/T)^n = 1 - e^{-n/T} \quad (1-1)$$

where EP and p are expressed as fractions of unity and n and T are expressed in years. As an example, the exceedance probabilities over a design life of 50 years of a given event with various annual probabilities of exceedance are as follows:

p	EP over 50 years
10 ⁻²	0.39
10 ⁻³	0.05
10 ⁻⁴	0.005
10 ⁻⁵	0.0005

Hence, an event with a 10⁻² annual probability of exceedance (100 year return period) has a 39 percent chance of being exceeded in a 50-year period, while an event with a 10⁻⁴ annual probability of exceedance has only a 0.5 percent chance of being exceeded during a 50-year period.

HAZARD CURVES - In References 1, 2 and 3, the likelihood of earthquake, wind, and flood hazards at DOE sites has been defined by graphical relationships between maximum ground acceleration, maximum wind speed, or maximum water elevation and return period (reciprocal of annual probability of exceedance). These relationships are termed seismic, wind or flood hazard curves. The earthquake or wind loads or the flood levels used for the design or evaluation of DOE facilities are based on hazard parameters from these curves at selected annual probabilities of exceedance.

PERFORMANCE GOALS - The likelihood of adverse facility behavior during natural phenomena hazards can also be expressed on a probabilistic basis. Goals for facility performance during natural phenomena hazards have been selected and expressed in terms of annual probability of exceedance. As an example, if the performance goal is 10⁻³ annual probability of exceedance for structural damage, there would be less than about a 5 percent chance that such damage could occur over a 50-year design life. If the performance goal is 10⁻⁴ annual probability of exceedance for structural or equipment damage, there would be about a 0.5 percent chance of such damage over a 50-year design life. The level of damage considered in the performance goal depends on the facility characteristics; for example, the performance goal for general use facilities is major damage to the extent that occupants are endangered. However, the performance goal for hazardous use facilities is lesser damage to the extent that the facility cannot perform its function.

CONFIDENCE LEVEL - Because of the uncertainty in the underlying hazard process (e.g., earthquake mechanism for seismic hazard), performance goals or hazard probabilities can be specified at higher confidence levels to provide greater conservatism for more critical conditions.

1.4 EARTHQUAKE, WIND, AND FLOOD HAZARDS FOR DOE FACILITIES

For the facility design and evaluation guidelines presented herein, loads induced by natural phenomena hazards are based on external hazard parameters (e.g., maximum earthquake ground acceleration, maximum wind speed, and maximum depth of inundation) at specified annual probabilities of exceedance. As a result, probabilistic hazard curves are required at each DOE facility. This information can be obtained from independent site-specific studies or from References 1, 2, and 3 for earthquake, wind, and flood hazards, respectively. The hazard information from these references is discussed throughout this report. In conjunction with these design and evaluation guidelines, the use of independent site specific evaluations of natural phenomena hazards may also be used as the basis for loads on facilities.

Seismic and wind hazard curves have been evaluated by site-specific studies of the DOE sites considered (References 1 and 2). In addition, flood hazard curves have been evaluated for some of the DOE sites considered (Reference 3). Flood hazard curves developed from screening studies are currently available for the eight Albuquerque Operations Office sites and for the Richland Operations Office site. Example hazard curves are presented in Figures 1-3, 1-4 and 1-5 in which hazard parameters are given as a function of return period in years or the annual probability of exceedance.




FIGURE 1-3. EXAMPLE SEISMIC HAZARD CURVE




FIGURE 1-4. EXAMPLE WIND/TORNADO HAZARD CURVE




FIGURE 1-5. EXAMPLE FLOOD HAZARD CURVE

For earthquakes, Reference 1 presents best estimate peak ground accelerations as a function of return period in the manner illustrated by Figure 1-3. Acceleration values correspond to the maximum acceleration that would be recorded by a three-axis strong-motion instrument on a small foundation pad at the free ground-surface. In addition, ground response spectra for each site are provided in Reference 1. Ground response spectra indicate the dynamic

amplification of the earthquake ground motion during linear, elastic, seismic response of facilities. These spectra provide information about the frequency content of potential earthquake ground motion at the site.

In Reference 2, mean predicted maximum wind speeds as a function of return period and annual probability of exceedance are given in the manner illustrated by Figure 1-4 for the 25 DOE sites considered. At annual probabilities of exceedance where tornadoes govern the wind loading on facilities, Reference 2 also specifies tornado-related effects. These effects include atmospheric pressure change and windborne missiles, which must be considered in the design and evaluation of facilities. At annual probabilities of exceedance where straight winds govern the wind loadings, these tornado related effects do not significantly affect facility behavior and need not be considered.

Reference 3 provides the results of flood hazard evaluation work performed to date for DOE sites. The results of this work are flood hazard curves in which mean water elevation is expressed as a function of return period and annual probability of exceedance as shown in Figure 1-5. Note that the work performed thus far is the result of flood screening analyses and not detailed flood hazard studies, such as those conducted for seismic and wind hazards. The scope of the flood screening analysis is restricted to evaluating the flood hazards that may exist in proximity to a site. The analysis does not involve an assessment of the potential encroachment of flooding at individual facility locations. Furthermore, the screening analyses do not consider localized flooding at a site due to precipitation (e.g., local run-off, storm sewer capacity, roof drainage). The results of the flood screening analyses serve as the primary input to DOE site managers to review the impact of flood hazards on individual facilities and to evaluate the need for more detailed flood hazard assessment.

2 GENERAL DESIGN AND EVALUATION GUIDELINES

2.1 DESIGN AND EVALUATION PHILOSOPHY

The guidelines presented in this document are intended to assure acceptable performance of DOE facilities in the event of earthquake, wind/tornado, and flood hazards. As discussed in Chapter 1, performance is measured herein by performance goals which are expressed as an annual probability of natural phenomena recurrence and resultant unacceptable damage. These annual probabilities of unacceptable damage are intended to be consistent with standard engineering practice for both normal use and hazardous use facilities. It must be emphasized that the performance goals referred to in this document correspond to probabilities of structure or equipment damage due to natural phenomena hazards and do not correspond to phenomena such as off-site release of hazardous materials or casualties and injuries to the general public. These performance goals do not extend to consequences beyond structure or equipment damage.

The responsibility for selecting performance goals rests with DOE management. Selection of performance goals for facilities subjected to natural phenomena hazards should be based on characteristics of the facility under consideration, including:

1. Vulnerability of occupants.
2. Cost of replacement of facility and contents.
3. Mission dependence or programmatic impact of the facility on operations at the DOE site.
4. Characteristics of hazardous materials contained within the facility, including quantity, physical state, and toxicity.
5. Factors affecting off-site release of hazardous materials, such as a high energy source or transport mechanism, as well as off-site land use and population distribution.

For example, a much higher likelihood of damage would be acceptable for an unoccupied storage building of low value than for a high-occupancy facility or a facility containing hazardous materials. Facilities containing hazardous materials which, in the event of damage, threaten public safety or the environment, and which are under close public scrutiny, should have a very low probability of damage due to natural phenomena hazards (i.e., much lower probability of damage than would exist from the use of conventional building code design and evaluation procedures). For ordinary facilities of relatively low cost, there is no reason to provide additional

facility response to these loadings, and provide criteria to judge whether computed facility response is acceptable. These guidelines are intended to apply equally to the design of new facilities and to the evaluation of existing facilities. In addition, the guidelines are intended to cover buildings, equipment, piping, and other structures.

The guidelines presented in this report primarily cover (1) methods of establishing load levels on facilities from natural phenomena hazards and (2) methods of evaluating the behavior of structures and equipment to these load levels. These items are very important and are typically emphasized in design and evaluation criteria. However, there are other aspects of facility design which are equally important and should be considered. These aspects include quality assurance considerations and attention to design details. Quality assurance requires peer review of design drawings and calculations, inspection of construction, and testing of material strengths, weld quality, etc. The peer reviewers should be qualified personnel who were not involved in the original design. Important design details include measures to assure ductile behavior and to provide redundant load paths, as well as proper anchorage of equipment and non-structural building features. Although quality assurance and design details are not discussed in this report to the same extent as hazard load levels and response evaluation methods, the importance of these parts of the design/evaluation process should not be underestimated. Quality assurance and peer review are briefly addressed in Section 2.5, in addition to discussions in the individual chapters on each natural phenomena hazard. Design detailing for earthquake and wind hazards is covered by separate manuals currently being prepared or planned.

2.2 PERFORMANCE GOALS AND FACILITY-USE CATEGORIES

As stated previously, it is the responsibility of DOE management to select the appropriate performance goal for specific facilities. This may be accomplished by either of the following two approaches:

1. Place facilities or portions of facilities into facility-use categories based on characteristics such as mission dependence, occupancy, amount and type of hazardous materials involved, and distance to population centers.
2. Place facilities or portions of facilities into facility-use categories based on the associated performance goals as presented in this section and on an independent assessment of the appropriate performance goal for the facility.

Note that the categories are intended to provide general guidance for reasonable facility categorization and performance goals. DOE management may either accept the performance

goals assigned to each category herein or else independently establish performance goals specifically for individual facilities or parts of facilities. In either case, the guidelines presented in this report may be utilized for design or evaluation.

2.2.1 Facility-Use Categories

Four facility-use categories are suggested herein for design/evaluation of DOE facilities for natural phenomena hazards. The four categories are (1) General Use, (2) Important or Low Hazard, (3) Moderate Hazard, and (4) High Hazard as defined in Table 2-1.

TABLE 2-1
FACILITY-USE CATEGORY GUIDELINES

Facility-Use Category	Description
General Use Facilities	Facilities which have a non-mission dependent purpose, such as administration buildings, cafeterias, storage, maintenance and repair facilities which are plant or grounds oriented.
Important or Low Hazard Facilities	Facilities which have mission dependent use (e.g., laboratories, production facilities, and computer centers) and emergency handling or hazard recovery facilities (e.g., hospitals, fire stations).
Moderate Hazard Facilities	Facilities where confinement of contents is necessary for public or employee protection. Examples would be uranium enrichment plants, or other facilities involving the handling or storage of significant quantities of radioactive or toxic materials.
High Hazard Facilities	Facilities where confinement of contents and public and environment protection are of paramount importance (e.g., facilities handling substantial quantities of in-process plutonium or fuel reprocessing facilities). Facilities in this category represent hazards with potential long term and widespread effects.

General Use and Important or Low Hazard categories correspond to facilities whose design or evaluation would normally be governed by conventional building codes. The General Use category includes normal use facilities for which no extra conservatism against natural phenomena hazards is required beyond that in conventional building codes that include earthquake, wind, and flood considerations. Important or Low Hazard facilities are those where it is very important to maintain the capacity to function and to keep the facility operational in the event of natural phenomena hazards. Conventional building codes would treat hospitals, fire and police stations, and other emergency handling facilities in a similar manner to the requirements of these guidelines for Important or Low Hazard facilities.

Moderate and High Hazard categories apply to facilities which deal with significant amounts of hazardous materials. Damage to these types of facilities could potentially endanger worker and public safety and the environment. As a result, it is very important for these facilities to continue to function in the event of natural phenomena hazards, such that the hazardous materials may be controlled and confined. For both of these categories, there must be a very

small likelihood of damage due to natural phenomena hazards. Guideline requirements for Moderate Hazard facilities are more conservative than requirements found in conventional building codes. Requirements for High Hazard facilities are even more conservative.

Factors distinguishing Moderate and High Hazard facilities are that the operations involving dangerous materials in High Hazard facilities pose a greater threat due to the potential for more widespread and/or long term contamination in the event of off-site release. Examples of High Hazard operations are those involving large quantities of in-process radioactive or toxic materials that have a high energy source or transport mechanisms that facilitate off-site dispersion of these materials. High energy sources, such as high pressure and temperature steam or water associated with the operations of some facilities, can provide the means for widespread dispersion of hazardous materials. Radioactive material in liquid or powder form or toxic gases are more easily transportable and may result in the facility being classified High Hazard. Hazardous materials in solid form or within storage canisters or casks may result in the same facility being classified Moderate Hazard. High Hazard facilities do not necessarily represent as great a hazard as commercial nuclear power plants which must be licensed by the Nuclear Regulatory Commission (NRC). The design and evaluation guidelines contained in this document are not intended to apply to facilities subject to NRC licensing requirements.

Table 2-2 illustrates that categories defined in these guidelines are compatible with facility categorization from other sources.

TABLE 2-2
COMPARISON OF FACILITY-USE CATEGORIES FROM VARIOUS SOURCES

Source	Facility Categorization			
UCRL-15910 - DOE Natural Phenomena Hazard Guidelines	General Use	Important or Low Hazard	Moderate Hazard	High Hazard
1988 Uniform Building Code	General Facilities	Essential Facilities	-	-
DOD Tri-Service Manual for Seismic Design of Essential Buildings	-	-	High Risk	Essential
IAEA-TECDOC-348 - Nuclear Facilities with Limited Radioactive Inventory	-	Class C	Class B	Class A
DOE 5481.1B SAR System	-	Low Hazard	Moderate Hazard	High Hazard
NFPA 13 (Classifications for Sprinkler Systems)	Light Hazard	Ordinary Hazard (Group 1)	Ordinary Hazard (Group 3)	Extra Hazard
Nuclear Regulatory Commission	-			*

* NRC licensed commercial nuclear power plants have slightly more conservative criteria than the criteria recommended for High Hazard facilities by these guidelines.

2.2.2 Performance Goals

Table 2-3 presents performance goals for each facility-use category.

TABLE 2-3
PERFORMANCE GOALS FOR EACH FACILITY-USE CATEGORY

Facility Use Category	Performance Goal Description	Performance Goal Annual Probability of Exceedance
General Use	Maintain Occupant Safety	10^{-3} of the onset of major structural damage to the extent that occupants are endangered
Important or Low Hazard	Occupant Safety, Continued Operation with Minimal Interruption	5×10^{-4} of facility damage to the extent that the facility cannot perform its function
Moderate Hazard	Occupant Safety, Continued Function, Hazard Confinement	10^{-4} of facility damage to the extent that the facility cannot perform its function
High Hazard	Occupant Safety, Continued Function, Very High Confidence of Hazard Confinement	10^{-5} of facility damage to the extent that the facility cannot perform its function

The design and evaluation guidelines for facilities subjected to natural phenomena hazards presented in this document have been specified to meet these performance goals. The basis for selecting these performance goals and the associated annual probabilities of exceedance are described briefly in this section.

For *General Use facilities*, the primary concern is preventing major structural damage or facility collapse that would endanger personnel within the facility. A performance goal annual probability of exceedance of about 10^{-3} of the onset of significant facility damage is appropriate for this category. This performance is considered to be consistent with conventional building codes (References 10, 15, and 16), at least for earthquake and wind considerations. The primary concern of conventional building codes is preventing major structural failure and maintaining life safety under major or severe earthquakes or winds. This primary concern for preventing structural failure does not consider repair or replacement of the facility or the ability of the facility to continue to function after the occurrence of the hazard.

Important or Low Hazard Use facilities are of greater importance due to mission-dependent considerations. In addition, these facilities may pose a greater danger to on-site personnel than general use facilities because of operations or materials within the facility. The performance goal is to maintain both capacity to function and occupant safety. Important or Low Hazard facilities should be allowed relatively minor structural damage in the event of natural phenomena hazards. This is damage that results in minimal interruption to facility operations and that can be easily and readily repaired following the event. A performance goal annual probability of exceedance of between 10^{-3} and 10^{-4} of structure/equipment damage, to the extent that the capacity of the facility is able to continue to function with minimal

interruption, is judged to be reasonable. This performance goal is believed to be consistent with the design criteria for essential facilities (e.g., hospitals, fire and police stations, centers for emergency operations) in accordance with conventional building codes such as Reference 10.

Moderate or High Hazard Use facilities pose a potential hazard to the safety of the general public and of the environment due to the presence of radioactive or toxic materials within these facilities. Concerns about natural phenomena hazards for these categories are facility damage to the extent that significant amounts of hazardous materials cannot be controlled and confined, occupants are endangered, and functioning of the facility is interrupted. The performance goal for Moderate Hazard facilities is to limit damage such that confinement of hazardous materials is maintained. The performance goal for High Hazard facilities is to provide very high confidence that hazardous materials are confined during and following a natural phenomena hazard occurrence. Maintaining confinement of hazardous materials requires that damage be limited in confinement barriers. Structural members and components should not be damaged to the extent that breach of the confinement or containment envelope is significant. Furthermore, ventilation filtering and containers of hazardous materials within the facility should not be damaged to the extent that they are not functional. In addition, confinement may depend on maintaining safety-related functions, so that monitoring and control equipment should remain operational following, and possibly during, the occurrence of severe earthquakes, winds, or floods.

For High Hazard facilities, a performance goal of an annual probability of exceedance of about 10^{-5} of damage, to the extent that confinement functions are impaired, is judged to be reasonable. This performance goal approaches, at least for earthquake considerations, the performance goal for seismic induced core damage associated with design of commercial nuclear power plants (References 17, 18, 19, and 20). For Moderate Hazard facilities, a performance goal of an annual probability of exceedance of about 10^{-4} of damage, to the extent that confinement functions are impaired, is judged appropriate.

2.3 EVALUATION OF EXISTING FACILITIES

These guidelines for natural phenomena hazards can be used for design of new facilities and evaluation, modification, or upgrade of existing facilities. In fact, these guidelines are primarily applicable to existing DOE facilities, since new design work may be infrequent. While new facilities can be designed in accordance with these guidelines, existing facilities may or may not meet the recommendations of these guidelines. For the earthquake hazard, most

facilities built a number of years ago in the eastern United States were designed without consideration of potential earthquake hazard. As a result, it is likely that some older DOE facilities do not meet the earthquake guidelines presented herein.

If an existing facility does not meet the natural phenomena hazard design/evaluation guidelines, several options need to be considered as illustrated by the flow diagram in Figure 2-1.




FIGURE 2-1
EXISTING FACILITY EVALUATION APPROACH

Potential options for existing facilities include:

1. Conduct a more rigorous evaluation of facility behavior to reduce added conservatism which may be introduced by simple techniques used for initial facility evaluation. Alternatively, a probabilistic assessment of the facility might be undertaken in order to demonstrate that the performance goals for the facility can be met.
2. The facility may be strengthened such that its resistance to hazard effects is sufficiently increased to meet the guidelines.
3. The usage of the facility may be changed so that it falls within a less hazardous facility-use category and consequently less stringent requirements.

Deficiencies or weaknesses uncovered by facility evaluation that can be easily remedied should generally be upgraded without considering the other options listed above. It is often more cost-effective to implement simple facility upgrades than to expend effort on further analytical studies.

If an existing facility is close to meeting the guidelines, a slight increase in the annual risk to natural phenomena hazards can be allowed because of (1) the difficulty in upgrading an existing facility compared to incorporating increased resistance in a new design and also because (2) existing facilities may have a shorter remaining life than a new facility. As a result, some relief in the guidelines for earthquake and wind/tornado evaluations can be allowed by performing the evaluation using hazard exceedance probability of twice the recommended value. For example, if the hazard annual probability of exceedance for the facility under consideration was 10^{-4} , it would be acceptable to reconsider the facility at hazard annual probability of exceedance of 2×10^{-4} . This would have the effect of slightly reducing the seismic and wind loads due to these natural phenomena hazards in the facility evaluation. Relief in the guidelines is not permitted for flood evaluation since the performance of facilities during floods is very sensitive to the water elevation and a factor of two increase in hazard exceedance probability would result in a significant increase in water elevation.

Evaluating existing facilities differs from designing new facilities in that both the as-built and as-is condition of the existing facility must be assessed. This assessment includes reviewing drawings and conducting site visits to determine deviations from the drawings and any in-service deterioration. In-place strength of the materials can be used when available. Corrosive action and other aging processes, which may have had deteriorating effects on the strength of the facility, should be considered. Evaluation of existing facilities would be similar to evaluations performed of new designs except that a single as-is configuration is evaluated instead of several configurations in an iterative manner, as required in the design process.

Evaluations should be conducted in order of priority, with highest priority given to those areas identified as weak links by preliminary investigations and to areas that are most important to personnel safety and operations with hazardous materials.

2.4 QUALITY ASSURANCE AND PEER REVIEW

To achieve well-designed and constructed facilities resistant to natural phenomena hazards or to assess whether existing facilities are well designed and constructed for natural phenomena hazard effects, it is recommended that important, hazardous (Important or Low Hazard, Moderate Hazard, and High Hazard categories) or unusual facilities be designed or evaluated utilizing an engineering quality assurance plan. Specific details about engineering quality assurance plans depend on the natural phenomena hazard considered. As a result, such plans are described in some detail in each of the remaining chapters of this document.

In general, an engineering quality assurance plan should include the following requirements. On the design drawings or evaluation calculations, the engineer must describe the hazard design basis including 1) description of the system resisting hazard effects and 2) definition of the hazard loading used for the design or evaluation. Design or evaluation calculations should be checked for numerical accuracy and for theory and assumptions. For new construction, the engineer should specify a material testing and construction inspection program. In addition, the engineer should review all testing and inspection reports as well as periodically visit the site to observe compliance with plans and specifications. For important or hazardous facilities, all aspects of the design or evaluation must include independent peer review. For various reasons, a designer may not be able to devote as much attention to natural phenomena hazard design as he or she might like. Therefore, it is required that the design be reviewed by a qualified, independent consultant or group. For existing facilities, the engineer conducting an evaluation for the effects of natural phenomena hazards will likely be qualified and will be able to devote his full attention to evaluating the adequacy of the facility to withstand these particular hazards. In this case, an independent review is not as important as it is for a new design. Even so, for major hazardous facilities, it may be prudent to have concurrent independent evaluations performed or to have the evaluation independently reviewed.

For more information concerning the implementation of a formal engineering quality assurance program and peer review, Chapters 10 and 13 of Reference 21 should be consulted. This reference should also be consulted for information on a construction quality assurance program consistent with the implementation of the engineering quality assurance program.

3 EFFECTS OF NATURAL PHENOMENA HAZARDS

3.1 EFFECTS OF EARTHQUAKES

For most facilities, the primary seismic hazard is earthquake ground shaking. These guidelines specifically cover the design and evaluation of buildings, equipment, piping and other structures for shaking. Other earthquake effects which can be devastating to facilities include differential ground motion induced by fault displacement, liquefaction, and seismic-induced slope instability and ground settlement. These latter earthquake effects must be avoided in facility siting, or the hazard must be eliminated by foundation design or site modification. Existing facilities located on active fault traces, adjacent to potentially unstable slopes, or on saturated, poorly consolidated cohesionless soil or fill material pose serious questions as to their usage for critical missions or handling hazardous materials.

While earthquake hazards of potential fault movement or other gross soil movement are typically avoided or mitigated, the earthquake ground shaking hazard is unavoidable. When a structure or component is subjected to earthquake shaking, its foundation or support moves with the ground or with the structural element on which it rests. If the structure or equipment is rigid, it follows the motion of its foundation, and the dynamic forces acting on it are nearly equal to those associated with the base accelerations. However, if the structure is flexible, large relative movements can be induced between the structure and its base. Earthquake ground shaking consists of a short duration of time-varying motion which has significant energy content in the range of frequencies of many structures. Thus, for flexible structures, dynamic amplification is possible such that the motions of the structure may be significantly greater than the ground shaking motion. In order to survive these motions, the structural elements must be sufficiently strong, as well as sufficiently ductile, to resist the seismic-induced forces and deformations. The effects of earthquake shaking on structures and equipment depend not only on the earthquake motion to which they are subjected, but also on the properties of the structure or equipment. Among the more important structural properties are the ability to absorb energy (due to damping or inelastic behavior), the natural periods of vibration, and the strength or resistance.

Earthquake ground shaking generally has lateral, vertical, and rotational components. Structures are typically more vulnerable to the lateral component of seismic motion; therefore, a lateral force-resisting system must be developed for structures to survive strong earthquakes without collapse or major damage. Typical lateral force-resisting systems for buildings include moment-resisting frames, braced frames, shear walls, diaphragms, and foundations. Properly designed lateral force-resisting systems provide a continuous load path from the top of the

structure down to the foundation. Furthermore, it is recommended that redundant load paths exist. Proper design of lateral force-resisting systems must consider the relative rigidities of the elements taking the lateral load and their capacities to resist load. An example of lack of consideration for relative rigidity are frames with brittle unreinforced infill walls which are not capable of resisting the loads attracted by such rigid construction. In addition, unsymmetrical arrangement of lateral force-resisting elements can produce torsional response which, if not accounted for in design, can lead to damage.

Earthquake ground shaking causes limited energy transient loading. Structures have energy absorption capacity through material damping and hysteretic behavior during inelastic response. The capability of structures to respond to earthquake shaking beyond the elastic limit without major damage is strongly dependent on structural design details. For example, to develop ductile behavior of inelastic elements, it is necessary to prevent premature abrupt failure of connections. For reinforced concrete members, design is based on ductile steel reinforcement in which steel ratios are limited such that reinforcing steel yields before concrete crushes, abrupt bond or shear failure is prevented, and compression reinforcement includes adequate ties to prevent buckling or spalling. With proper design details, structures can be designed to undergo different amounts of inelastic behavior during an earthquake. For example, if the goal is to prevent collapse, structures may be permitted to undergo large inelastic deformations; damage to the extent that the structure would have to be repaired or replaced may occur. If the goal is to allow only minor damage such that there is minimal or no interruption to the functioning of the structure, relatively small inelastic deformations should be permitted. For new facilities, it is assumed that by proper detailing, permissible levels of inelastic deformation can be reached at the specified force levels without unacceptable damage. In the case of existing facilities, the amount of inelastic behavior that can be allowed without unacceptable damage must be estimated from the as-built condition of the structure.

Earthquake ground shaking also affects building contents and nonstructural features such as windows, facades, and hanging lights. It is not uncommon for the structure to survive an earthquake without serious structural damage but to have significant, expensive, and dangerous internal damage. This damage could be caused by overturned equipment or shelves, fallen lights or ceilings, broken glass, and failed infill walls. Glass and architectural finishes may be brittle relative to the main structure and can fail well before structural damage occurs. Windows and cladding must be carefully attached in order to accommodate the seismic movement of the structure without damage. Building contents can usually be protected against earthquake damage by anchorage to the floor, walls, or ceiling.

Facilities in which radioactive materials are handled are typically designed with redundant confinement barriers between the hazardous material and the environment. Such barriers include:

1. The building shell
2. Ventilation system filtering and negative pressurization inhibiting outward air flow.
3. Storage canisters or glove boxes for storage or handling within the building.

Release of radioactive material to the environment requires failure of two or more of these barriers. Thus, seismic design considerations for these facilities aim to prevent collapse and control cracks or openings (i.e., failed doors, failed infill walls, etc.) such that the building can function as a hazardous materials confinement barrier. Seismic design considerations also include adequate anchorage and bracing of glove boxes and adequate anchorage of ventilation ducting, filters, and pumps to prevent their damage and loss of function during an earthquake. Storage canisters are usually very rugged and are not particularly vulnerable to earthquake damage.

Earthquake damage to components of a facility such as tanks, equipment, instrumentation, and piping can also cause injuries, loss of function, or loss of confinement. Many of these items can survive strong earthquake ground shaking with adequate anchorage. Some items, such as large vertical tanks, must be examined in more detail to assure that there is an adequate lateral force-resisting system for seismic loads. For components mounted within a structure, there are three additional considerations for earthquake shaking. First, the input excitation for structure-supported components is the response motion of the structure (which can be amplified from the ground motion) and not the earthquake ground motion. Second, potential dynamic coupling between the component and the structure must be taken into account if the component is massive enough to affect the seismic response of the structure. Third, large differential seismic motions may be induced on components which are supported at multiple locations on a structure or on adjacent structures.

3.2 EFFECTS OF WIND

In this document, three types of winds are discussed: extreme (straight), hurricane, and tornado winds. Extreme winds refer to non-rotating winds such as those found in thunderstorm gust fronts. Wind circulating around high or low pressure systems are rotational in a global sense, but are considered "straight" winds in the context used herein. Tornadoes and hurricanes both have rotating winds. The diameter of rotating winds in a small hurricane is considerably larger than the diameter of a large tornado. However, most tornado diameters are relatively large compared to the dimensions of typical buildings. It is estimated that the diameter of 80 percent of all tornadoes is greater than 300 feet.

Wind pressures produced by extreme winds are studied in boundary layer wind tunnels. The results generally are considered reliable because they have been verified by selected full scale measurements. Investigations of damage produced by extreme winds tend to support the wind tunnel findings. Although the rotating nature of hurricane and tornado winds cannot easily be duplicated in the wind tunnel, damage investigations suggest that pressures produced on enclosed buildings and other structures are similar to those produced by extreme winds, if the relative direction of the rotating wind is taken into account. The appearance of damage to buildings and other structures produced by extreme, hurricane and tornado winds is so similar that it is almost impossible to look at damage to an individual structure and tell which type of wind produced it. Thus, the approach for determining wind pressures on buildings and other structures proposed in this document is considered independent of the type of windstorm. The recommended procedure is essentially the same for straight, hurricane, and tornado winds.

3.2.1 Wind Pressures

Wind pressures on buildings can be classified as external and internal. External pressures develop as air flows over and around enclosed buildings. The air particles change speed and direction, which produces a variation of pressure on the external surfaces of the building. At sharp edges, the air particles separate from contact with the building surface with an attendant energy loss. These particles produce large outward acting pressures near the location where the separation takes place. To account for the large pressures near separations and the more uniform pressure over the rest of the surface, external pressures may be treated as local pressures and overall pressures. External pressures act outward on all surfaces of an enclosed building except on windward walls and on steep windward roofs. Overall external

pressures include pressures on windward walls, leeward walls, side walls, and roof. Local pressures occur at wall corners, eaves, ridges, and roof corners. They act outward over a limited area.

Internal pressures develop when air flows into or out of an enclosed building through broken windows, open doors, or fresh air intakes. Natural porosity of the building also allows air to flow into or out of the building in some cases. The internal pressure can be either inward or outward depending on the location of the openings. If air flows into the building through an opening in the windward wall, a "ballooning" effect takes place: pressure inside the building increases relative to the outside pressure. The pressure change produces additional net outward-acting pressures on all interior surfaces. An opening in any other wall or leeward roof surface permits air to flow out of the building: pressure inside the building decreases relative to the outside pressure. The pressure change produces net inward-acting pressure on all interior surfaces. Internal pressures combine with external pressures acting on a building's surface.

On structures other than buildings - such as towers, tanks, or chimneys - interest focuses on the net force acting to overturn or slide the structure, rather than the wind pressure distribution. The magnitude of these forces is determined by wind tunnel or full-scale tests. Also, in special instances, particularly associated with aerodynamically sensitive structures, it may be necessary to consider vortex shedding or flutter as a design requirement. Typical sensitive structures are: chimneys, stacks, poles, cooling towers, cable-stayed or supported bridges, and relatively light structures with large smooth surfaces.

Gusts of wind produce dynamic pressures on structures. Gust effects depend on the gust size relative to building size and gust frequency relative to the natural frequency of the building. Except for tall, slender structures (designated wind-sensitive structures), the gust frequencies and the structure frequencies of vibration are sufficiently different that resonance effects are small, but they are not negligible. The size (spatial extent) of a gust relative to the size of the structure, or the size of a component on which the gust impinges, contributes to the magnitude of the dynamic pressure. A large gust that engulfs an entire structure has a greater dynamic effect on the main wind force resisting system than a small gust whose extent only partially covers the building. On the other hand, a small gust may engulf the entire tributary area of components such as a purlin, a girt, or cladding. In any event, wind loads may be treated as quasi-static loads by including an appropriate gust response factor in calculating

the magnitude of wind pressures. Extreme wind, hurricane, and tornado gusts are not exactly the same. However, errors owing to the difference in gust characteristics are believed to be relatively small for those structures that are not wind sensitive.

The roughness of terrain surrounding a structure significantly affects the magnitude of wind speed. Terrain roughness is typically defined in four classes: urban, suburban, open, and smooth. Wind speed profiles as a function of height above ground are represented by a power law relationship for engineering purposes. The relationship gives zero wind speed at ground level. The wind speed increases with height to the top of the boundary layer, where the wind speed remains constant with height.

3.2.2 Additional Adverse Effects of Tornadoes

In addition to wind pressures produced by tornadoes, low atmospheric pressure and debris transported by the tornado winds (tornado-generated missiles) pose additional potential damage.

Atmospheric pressure change (APC) affects only sealed buildings. Natural porosity, openings, or breach of the building envelope permits the inside and outside pressures of an unsealed building to equalize. Openings of one sq ft per 1000 cu ft volume are sufficiently large to permit equalization of inside and outside pressure as a tornado passes over a building. Buildings or other enclosures that are specifically sealed, e.g., a hot cell, will experience the net pressure difference caused by APC. When APC is present, it acts outward and combines with external wind pressures. The magnitude of APC is a function of the tangential wind speed of the tornado. However, the maximum tornado wind speed and the maximum APC pressure do not occur at the same place. The lowest APC occurs at the center of the tornado vortex, whereas the maximum wind pressure occurs at the radius of maximum winds, which ranges from 150-500 feet from the tornado center. The APC pressure is approximately one-half its maximum value at the radius of maximum wind speed.

The rate of APC is a function of the tornado's translational speed, which can vary from 5 to 60 mph. A rapid rate of pressure change can produce adverse effects on HVAC systems.

Violent tornado winds can pick up and transport various pieces of debris, including roof gravel, pieces of sheet metal, timber planks, pipes, and other objects that have high surface area to weight ratios. Automobiles, storage tanks, and railroad cars may be rolled or tumbled by tornado winds. In extremely rare instances, large-diameter pipes, steel wide-flange beams,

and utility poles might be transported by very intense tornado winds. These latter missiles are so rare that practicality precludes concern for their potential damage except for high hazard facilities comparable to commercial nuclear power plants.

Missiles that should be considered in the design and evaluation of DOE facilities include a 15-lb, 2x4-in. timber plank; a 75-lb, 3-in.-diameter steel pipe; and a 3000-lb automobile. The 2x4-in. timber missile is typical of debris found in the destruction of office trailers, storage sheds, residences, or other light timber structures. Hundreds of these missiles can be generated in the destruction of a residential neighborhood. The 3-in.-diameter steel pipe represents a class of debris that includes electrical conduit, liquid and gas piping, fence posts, and light columns. This missile is less frequently available for transport than the 2x4 timber. Tornado winds can roll or tumble a 3000 lb automobile, pickup trucks, small vans, forklifts, and storage tanks of comparable size and weight.

The three types of missiles produce varying degrees of damage. A specific type of construction is required to stop each missile. The 2x4-in. timber missile is capable of breaking glass and perforating curtain walls or unreinforced masonry walls. Reinforced concrete or masonry walls are required to stop the pipe missile. Timber and pipe missiles can perforate weak exterior walls and emerge with sufficient speed to perforate interior partitions or glove boxes. They also can damage HVAC ducts, HEPA filter enclosures, or pieces of control equipment. The impact of a rolling or tumbling automobile produces failure by excess structural response. Load bearing walls, rigid frames, and exterior columns are particularly susceptible to these objects. Failure of one of these elements could lead to progressive collapse of the structural system.

3.2.3 Effects on Structural Systems

A structural system consists of one-dimensional elements and two-dimensional subsystems that are combined to form the three-dimensional wind-load resisting system. The structural system is enclosed by walls and roof that make up the building envelope. Wind pressures develop on the surfaces of the building envelope and produce loads on the structural system, which in turn transmits the loads to the foundation. The structural system also must support dead and live loads.

Individual elements that make up the two-dimensional subsystems include girders, beams, columns, purlins, girts, piers, and footings. Failure of the elements themselves is relatively rare. Element connections are the more common source of failure. A properly conceived wind-force resisting system should not fail as a result of the failure of a single element

or element connection. A multiple degree of redundancy should be provided which allows redistribution of load in a ductile system when one element of the system is overloaded. Two-dimensional subsystems transmit wind loads from their points of application to the foundation. Typical subsystems include braced frames, rigid frames, shear walls, horizontal floor and roof diaphragms, and bearing walls. The subsystem must have sufficient strength and stiffness to resist the applied loads without excessive deflection or collapse. The three-dimensional wind-load resisting system is made up of two or more subsystems to form an overall system that is capable of transmitting all applied loads through various load paths to the foundation.

The main wind-force resisting system must be able to resist the wind loads without collapse or excessive deformation. The system must have sufficient ductility to permit relatively large deformations without sudden or catastrophic collapse. Ductility implies an ability of the system to redistribute loads to other components of the system when some part is overloaded.

Keys to successful performance of the wind-resisting system are well-designed connections and anchorages. Precast concrete structures and pre-engineered metal buildings generally have not demonstrated the same degree of satisfactory performance in high winds or tornadoes as conventional reinforced concrete and steel structures. The chief cause of the inadequate behavior is traced to weak connections and anchorages. These latter systems tend to have a lesser number of redundancies, which precludes redistribution of loads when yielding takes place. Failure under these circumstances can be sudden and catastrophic. Timber structures and those which rely on unreinforced load-bearing masonry walls suffer from weak anchorages and a lack of ductility, respectively. These systems, likewise, can experience sudden collapse under high wind loads. Reinforced masonry walls have inherent strength and ductility of the same order as reinforced concrete walls. Weak anchorages of roof to walls sometimes lead to roof uplift and subsequent collapse of the walls.

3.2.4 Effects on Cladding

Cladding forms the surface of the building envelope. Cladding on walls includes window glass, siding, sandwich panels, curtain walls, brick veneer, masonry walls, precast panels, and in-fill walls. Roof cladding includes wood and metal deck, gypsum planks, poured gypsum, and concrete slabs. Roofing material, such as built-up roofs or single-ply membrane systems, are also a part of the roof cladding.

Cladding failure results in a breach of the building envelope. A breach can develop because of failure of the cladding itself (excessive yielding or fracture), inadequate connections or anchorages, or perforation by missiles. Sometimes cladding provides lateral support to purlins, girts, and columns. If the cladding or its anchorage fails, this lateral support is lost, leaving the elements with a reduced load-carrying capacity.

Most cladding failures result from failure of fasteners or the material in the vicinity of the fastener. Cladding failures initiate at locations of high local wind pressures such as wall corners, eaves, ridges, and roof corners. Wind tunnel studies and damage investigations reveal that local pressures can be one to five times greater than overall external pressures.

Breach of the building envelope resulting from cladding failure allows air to flow into or out of the building, depending on where the breach occurs. The resulting internal pressures add to other external wind pressures, producing a worse loading case. Water damage is also a possibility, because most severe storms are accompanied by heavy rainfall.

If the building envelope is breached on two sides of the building, e.g., the windward and leeward walls, a channel of air can flow through the building from one opening to the other. The speed of the flowing air is related to the wind speed outside the building. A high-speed air flow (greater than 40 mph) could collapse interior partitions, pick up small pieces of equipment, or transport toxic or radioactive materials to the environment.

3.3 EFFECTS OF FLOODING

3.3.1 Causes and Sources of Flooding and Flood Hazards

There are a number of phenomena that can cause flooding in the vicinity of a site. For each cause or source of flooding, a facility may be exposed to one or a number of flood hazards. In most cases, the principal hazard of interest is submergence or inundation. However, significant damage can also occur if there are impact or dynamic forces, hydrostatic forces, water-borne debris, etc. Depending on the cause of flooding (e.g., river flooding, coastal storm surge) and the hazard (e.g., submergence, wave forces), the consequences can be very different.

Table 3-1 lists the various types or causes of flooding that can occur and the particular hazards they pose.

**TABLE 3-1
CAUSES OF FLOODING**

Source/Cause	Hazard
River flooding - precipitation - snow melt - debris jams - ice jams	Inundation, dynamic forces, wave action, sedimentation, ice loads
Dam failure - earthquake - flood - landslide - static failure (e.g., internal erosion, failure of outlet works)	Inundation, erosion, dynamic loads, sedimentation
Levee or dike failure - earthquake - flood - static failure (e.g., internal erosion, subsidence)	Inundation, erosion, dynamic loads, sedimentation
Precipitation/storm runoff	Inundation (ponding), dynamic loads (flash flooding)
Tsunami - earthquake	Inundation, dynamic loads
Seiche - earthquake - wind	Inundation, dynamic loads
Storm surge, usually accompanied by wave action - hurricane - tropical storm - squall line	Inundation, dynamic loads
Wave action	Inundation, dynamic loads
Debris	Dynamic loads

From the table, one notes that many of the causes or sources of flooding may be interrelated. For example, flooding on a river can occur due to dam or levee failure or precipitation.

Depending on the type of flooding and local conditions, the particular hazard posed by a flood can vary. For example, extreme flooding on a river may simply inundate a site. However, in a different situation, channel conditions may be such that prior to the site being inundated, high flows could lead to embankment erosion and structural damage to levees or dikes. Similarly, at coastal sites, storm surge and/or wave action can pose different hazards to a site.

In most cases, flood hazards are characterized in terms of the depth of flooding that occurs on site. This is reasonable since the depth of inundation is probably the single most relevant measure of flood severity. However, the type of damage that is caused by flooding depends very much on the nature of the hazard. For example, it is not uncommon that coastal sites can suffer significant damage due to wave action alone, even if the site is not completely inundated by a storm surge. Similarly, high-velocity flood waters on a river can add substantially to the threat of possible loss of life and the extent of structural damage. In many cases, the other hazards - such as wave action, sedimentation, and debris flow - can compound the damage caused by inundation.

3.3.2 Flooding Damage

In many ways, flood hazards differ significantly from other natural phenomena considered in this document. As an example, it is often relatively easy to eliminate flood hazards as a potential contributor to the chance of damage at a hazardous facility by strict siting requirements. Similarly, the opportunity to effectively utilize warning systems and emergency procedures to limit damage and personnel injury is significantly greater in the case of flooding than it is for seismic or extreme winds and tornadoes.

The damage to buildings and the threat to public health vary depending on the type of flood hazard. In general, structural and non-structural damage will occur if a site is inundated. Depending on the dynamic intensity of on-site flooding, severe structural damage and complete destruction of buildings can result. In many cases, structural failure may be less of a concern than the damaging effects of inundation on building contents and the possible transport of hazardous or radioactive materials.

For hazardous facilities that are not hardened against possible on-site and in-building flooding, simply inundating the site can result in a loss of function of equipment required to maintain safety and in a breach of areas that contain valuable or hazardous materials.

Structural damage to buildings depends on a number of factors related to the intensity of the flood hazard and the local hydraulics of the site. Severe structural damage and collapse generally occur as a result of a combination of hazards such as flood stage level, flow velocity, debris or sediment transport, wave forces, and impact loads. Flood stage is quite obviously the single most important characteristic of the hazard (flood stages below grade generally do not result in severe damage).

In general, the consequences of on-site flooding dramatically increase because flooding varies from submergence to rapidly moving water loaded with debris. Submergence results in water damage to a building and its contents, loss of operation of electrical components, and possible structural damage resulting from extreme hydrostatic loads. Roof collapse can occur when drains become clogged or are inadequate, and when parapet walls allow water, snow, or ice to collect. Also, exterior walls of reinforced concrete or masonry buildings (above and below grade) can crack and possibly fail under hydrostatic conditions.

Dynamic flood hazards can cause excessive damage to buildings not properly designed to withstand dynamic forces. Where wave action is likely, erosion of shorelines or river banks can occur. Structures located near the shore are subject to continuous dynamic forces that can break up a reinforced concrete structure and at the same time undermine the foundation. Buildings with light steel frames and metal siding, wooden structures, and unreinforced masonry are susceptible to severe damage and even collapse if they are exposed to direct dynamic forces. Reinforced concrete buildings are less likely to suffer severe damage or collapse. Table 3-2 summarizes the damage that various flood hazards can cause occur to buildings and flood protection devices.

TABLE 3-2
FLOOD DAMAGE SUMMARY

Hazard	Damage
Submergence	Water damage to building contents; loss of electric power and component function; settlements of dikes, levees; levee overtopping
Hydrostatic Loads	Can cause cracking in walls and foundation damage; ponding on roofs can cause collapse; levees and dikes can fail due to hydrostatic pressure and leakage
Dynamic Loads	Erosion of embankments and undermining of seawalls, high dynamic loads can cause severe structural damage, erosion of levees

The transport of hazardous or radioactive material represents a major consequence of on-site flooding if containment buildings or vaults are breached. Depending on the form and amount of material, the effects could be long-term and widespread once the contaminants enter the ground water or are deposited in populated areas.

1 2 1 2 1 3 1 8 5 5

**THIS PAGE INTENTIONALLY
LEFT BLANK**

4 EARTHQUAKE DESIGN AND EVALUATION GUIDELINES

4.1 INTRODUCTION

This chapter and Appendix A describe the philosophy and procedures for the design or evaluation of facilities for earthquake ground shaking. Much of this material deals with how seismic hazard curves such as those given in Reference 1 may be utilized to establish Design Basis Earthquake (DBE per Reference 9) loads on the facility; how to evaluate the response of the facility to these loads; and how to determine whether that response is acceptable with respect to the performance goals described in Chapter 2. In addition to facility evaluation for seismic loading, this chapter covers the importance of design details and quality control to earthquake safety of facilities. These earthquake design and evaluation guidelines are equally applicable to buildings and to items contained within the building, such as equipment and piping. In addition, the guidelines are intended to cover both new construction and existing facilities.

Design of facilities to withstand earthquake ground motion without significant damage or loss of function depends on the following considerations:

1. The facility must have sufficient strength and stiffness to resist the lateral loads induced by earthquake ground shaking. If a facility is designed for insufficient lateral forces or if deflections are unacceptably large, damage can result, even to well-detailed facilities.
2. Failures due to brittle behavior or instability which tend to be abrupt and potentially catastrophic must be avoided. The facility must be detailed in a manner to achieve ductile behavior such that it has greater energy absorption capacity than the energy content of earthquakes.
3. The behavior of the facility as it responds to earthquake ground motion must be fully understood by the designer such that some "weak link" which could produce an unexpected failure is not overlooked.
4. The facility must be constructed in the manner specified by the designer. Materials must be of high quality and as strong as specified by the designer. Construction must be of high quality and conform to the design drawings.

Specification of lateral load levels and methods of evaluating facility response to these loads (i.e., Item 1 above) are the primary subjects of this chapter. They are discussed in Section 4.2, Appendix A, and Section 4.4. In addition, Reference 22 addresses these subjects. Items 2, 3, and 4 assure good seismic design of facilities and they are described in Section 4.3. References 23 and 24 may be consulted for additional guidance on these items. Section 4.2 presents specific seismic design and analysis guidelines recommended for DOE facilities. Section 4.3 describes good earthquake design detailing practice and recommended quality

assurance procedures. Section 4.4 discusses important seismic design and evaluation considerations such as effective peak ground motion, soil-structure interaction, and evaluation of equipment and piping and existing facilities. Appendix A provides commentary which describes the basis for the guidelines presented in Section 4.2.

4.2 SEISMIC GUIDELINES FOR EACH FACILITY-USE CATEGORY

4.2.1 General

This section presents the specific procedures for seismic design and evaluation of facilities in each facility-use category. Seismic design and evaluation procedures include the following steps:

1. Selection of earthquake response spectra.
2. Evaluation of earthquake response.
3. Estimation of seismic capacity.
4. Assurance of proper details and quality construction.

For each facility-use category, a recommended exceedance probability for the earthquake hazard level is specified from which the peak ground acceleration may be determined from the hazard curves in Reference 1 or from other site-specific studies. Utilizing this peak ground acceleration, a deterministic approach is outlined by which both the demand placed on a facility and the capacity of that facility may be evaluated. From these data, new facilities may be designed such that the demand-capacity ratios are acceptable or the adequacy of an existing facility subjected to the specified earthquake motion can be evaluated.

The procedures presented herein are intended to meet the performance goals for structural behavior of facilities as defined in Chapter 2. This is accomplished by specifying hazard probabilities of exceedance along with seismic behavior evaluation procedures in which the level of conservatism introduced is controlled such that desired performance can be achieved. The guidelines generally follow the 1988 UBC provisions (Reference 10) for General Use and Important or Low Hazard facilities and the DOD Tri-service manual for essential buildings (Reference 11) for Moderate or High Hazard facilities. Minimum seismic design requirements for Moderate and High Hazard facilities are also based on the 1988 UBC provisions. Table 4-1 summarizes recommended earthquake design and evaluation guidelines for each facility-use category. Specific procedures are described in detail in Sections 4.2.2 and 4.2.3. The basis for these procedures is described in Appendix A.

**TABLE 4-1
SUMMARY OF EARTHQUAKE EVALUATION GUIDELINES**

	FACILITY-USE CATEGORY			
	General Use	Important or Low Hazard	Moderate Hazard	High Hazard
HAZARD EXCEEDANCE PROBABILITY	2x10 ⁻³	1x10 ⁻³	1x10 ⁻³	2x10 ⁻⁴
RESPONSE SPECTRA	Median Amplification (no conservative bias)			
DAMPING	5%		Post Yield (Table 4-4)	
ACCEPTABLE ANALYSIS APPROACHES	Static or Dynamic Force Method Normalized to Code Level Base Shear		Dynamic Analysis*	
IMPORTANCE FACTOR	I=1.0	I=1.25	Not Used*	
LOAD FACTORS	Code Specified Load Factors Appropriate for Structural Material		Load Factors of Unity	
INELASTIC DEMAND-CAPACITY RATIOS	Accounted for by R _w in Code Base Shear Equation (Ref. 10 and Table 4-2)		F _u from Table 4-2 Applied to Dead Load Plus Live Load Plus Earthquake	
MATERIAL STRENGTH	Minimum Specified or Known In-situ Values			
STRUCTURAL CAPACITY	Code Ultimate or Allowable Level		Yield Level	
PEER REVIEW, QA, SPECIAL INSPECTION	---	Required		

* Minimum seismic requirements in these categories include static analysis per UBC provisions with $I = 2.0$ and Z from hazard exceedance probability for category considered.

4.2.2 Evaluation of General Use & Important or Low Hazard Facility Seismic Behavior

Design or evaluation of General Use and Important or Low Hazard facilities for earthquake hazards is based on normal building code seismic provisions. In these guidelines, Reference 10, the 1988 edition of the *Uniform Building Code* is followed for these facility-use categories. Basic steps in the seismic design and analysis process are summarized in this section. **All 1988 UBC provisions are to be followed for General Use and Important or Low Hazard facilities (with modifications as described below), regardless of whether they are discussed herein.**

In the 1988 UBC provisions, the lateral force representing the earthquake loading on buildings is expressed in terms of the total base shear, V , given by the following equation:


$$V = ZICW / R_w \quad (4-1)$$

where: Z = a seismic zone factor equivalent to peak ground acceleration,
 I = a factor accounting for the importance of the facility,
 C = a spectral amplification factor,
 W = the total weight of the facility,
 R_w = a reduction factor to account for energy absorption capability
 of the facility (Ref. 10 values are shown in Table 4-2).

For General Use and Important or Low Hazard DOE facilities, it is recommended that the 1988 UBC provisions be followed, with the exception that Z be evaluated from the hazard curves in Reference 1, and C is the amplification factor from 5% damped median response spectra. It is recommended that both new and existing facilities (also refer to Section 4.4.5 for existing facilities) be evaluated for their adequacy to withstand earthquakes by the following procedure:

1.	Evaluate element forces, F(DL) and F(LL), throughout the facility for dead and live loads, respectively (realistic estimate of loads for existing facilities).
2.	Evaluate element forces, F(EQ), throughout the facility for earthquake loads.
a.	Static force method for regular facilities or dynamic force method for irregular facilities as described in the 1988 UBC provisions.
b.	In either case, the total base shear is given by Equation 4-1 where the parameters are evaluated as follows:
1)	Z is the peak ground acceleration from the hazard curves (Table 4-3) at the following exceedance probabilities: General Use - 2×10^{-3} Important or Low Hazard - 1×10^{-3}
2)	C is the spectral amplification at the fundamental period of the facility from the 5 percent damped median response spectra for the facility. Note that for fundamental periods lower than the period at which the maximum spectral acceleration occurs, ZC should be taken as the maximum spectral acceleration as illustrated in Figure 4-1. Amplification factors from median spectra may be determined by: a) site-specific geotechnical studies b) References 1, 25, 26, or 27
3)	If ZC is less than the 1988 UBC provisions (Reference 10):
a)	Earthquake loads should be based on the larger of ZC determined from Items 1 and 2 above or from the 1988 UBC provisions unless ZC is based upon a site-specific geotechnical study.
b)	If ZC is based upon a site-specific geotechnical study, any significant differences with UBC will be justified and resolved. Final earthquake loads are subject to approval by DOE/OSA.
4)	Importance factor, I, should be taken as: General Use - $I = 1.0$ Important or Low Hazard - $I = 1.25$
5)	Reduction factors, R_w , are from Table No. 23-O of Reference 10 as reproduced in Table 4-2.
3.	Combine responses from various loadings to evaluate demand, D, by: $D = LF [F(DL) + F(LL) + F(EQ)]$ or $D = 0.9 F(DL) \pm LF F(EQ)$ when strength design is used (LF is the load factor which would be 1.4 in the case of concrete). or $D = 0.75 [F(DL) + F(LL) + F(EQ)]$ when allowable stress design is used (the 0.75 factor corresponds to the one-third increase in allowable stress permitted for seismic loads).

4.	Evaluate capacities of the elements of the facility, CAP, from code ultimate values when strength design is used (e.g., UBC Sec. 2609 & 2625 for reinforced concrete) or from allowable stress levels when allowable stress design is used (e.g., UBC Sec. 2702 for steel). Minimum specified or known in-situ values for material strengths should be used for capacity estimation.
5.	Compare demand, D, with capacity, CAP, for all structural elements. If D is less than or equal to CAP, the facility satisfies the seismic lateral force requirements. If D is greater than CAP, the facility has inadequate lateral force resistance.
6.	Evaluate story drifts (i.e., the displacement of one level of the structure relative to the level above or below due to the design lateral forces), including both translation and torsion. Per Reference 10, calculated story drifts should not exceed $0.04/R_w$ times the story height nor 0.005 times the story height for buildings less than 65 feet in height. For taller buildings, the calculated story drift should not exceed $0.03/R_w$ nor 0.004 times the story height. Note that these story drifts are calculated from seismic loads reduced by R_w in accordance with Equation 4-1. These drift limits may be exceeded when it is demonstrated that greater drift can be tolerated by both structural systems and nonstructural elements.
7.	Elements of the facility should be checked to assure that all detailing requirements of the 1988 UBC provisions are met. UBC Seismic Zone No. 2 provisions should be met when Z is between 0.12 and 0.24g. UBC Seismic Zone Nos. 3 & 4 provisions should be followed when Z is 0.25g or more. Special seismic provisions in the UBC need not be followed if Z is 0.11g or less.
8.	Peer review of engineering drawings and calculations, special inspection and testing of new construction or existing facilities, and other quality assurance measures discussed in Section 4.3 should be implemented for important or Low Hazard facilities.



Note: For seismic evaluation of nonstructural components, equipment, piping, etc. by dynamic analysis, the actual spectrum should be used. The actual spectrum should also be used as the basis for developing floor spectra.

FIGURE 4-1
EXAMPLE DESIGN/EVALUATION EARTHQUAKE
GROUND MOTION RESPONSE SPECTRUM

TABLE 4-2
CODE REDUCTION COEFFICIENTS, R_w AND
INELASTIC DEMAND CAPACITY RATIOS, F_u

Structural System (terminology is identical to Ref. 10)	Category		
	GU & I or LH	MH	HH
	R_w	F_u	
MOMENT RESISTING FRAME SYSTEMS			
Columns	*	1.5	1.25
Beams			
Steel Special Moment Resisting Space Frame (SMRSF)	12	3.0	2.5
Concrete SMRSF	12	2.75	2.25
Concrete Intermediate Moment Frame (IMRSF)	7	1.5	1.25
Steel Ordinary Moment Resisting Space Frame	6	1.5	1.25
Concrete Ordinary Moment Resisting Space Frame	5	1.1	1
SHEAR WALLS			
Concrete Walls	8 (6)	1.7 (1.4)	1.4 (1.15)
Masonry Walls	8 (6)	1.5 (1.3)	1.25 (1.1)
Plywood Walls	9 (8)	2.0 (1.7)	1.5 (1.4)
Dual System, Concrete with SMRSF	12	2.5	2.0
Dual System, Concrete with Concrete IMRSF	9	2.0	1.5
Dual System, Masonry with SMRSF	8	1.5	1.25
Dual System, Masonry with Concrete IMRSF	7	1.4	1.15
STEEL ECCENTRIC BRACED FRAMES (EBF)			
Columns	*	1.5	1.25
Beams and Diagonal Braces	10	2.75	2.25
Beams and Diagonal Braces, Dual System with Steel SMRSF	12	3.0	2.5
CONCENTRIC BRACED FRAMES			
Steel Beams	8 (6)	2.0 (1.7)	1.5 (1.4)
Steel Diagonal Braces	8 (6)	1.7 (1.5)	1.4 (1.25)
Steel Columns	8 (6)	1.7 (1.5)	1.4 (1.25)
Connections of Steel Members	8 (6)	1.4 (1.25)	1.15 (1.05)
Concrete Beams	8 (4)	1.7 (1.3)	1.4 (1.1)
Concrete Diagonal Braces	8 (4)	1.5 (1.2)	1.25 (1)
Concrete Columns	8 (4)	1.5 (1.2)	1.25 (1)
Connections of Concrete Members	8 (4)	1.25 (1.1)	1.05 (1)
Wood Trusses	8 (4)	1.7 (1.3)	1.4 (1.1)
Wood Columns	8 (4)	1.5 (1.2)	1.25 (1)
Connections in Wood (other than nails)	8 (4)	1.5 (1.2)	1.25 (1)
Beams and Diagonal Braces, Dual Systems			
Steel with Steel SMRSF	10	2.5	2.0
Concrete with Concrete SMRSF	9	2.0	1.5
Concrete with Concrete IMRSF	6	1.4	1.15

Note: Values herein assume good seismic detailing practice per Section 4.3 and reasonably uniform inelastic behavior. Otherwise, lower values should be used. Moment resisting frame detailing per Reference 10.

Values in parentheses apply to bearing wall systems or systems in which bracing carries gravity loads

R_w values for columns are the same as for beams and braces for moment frames and for eccentric braced frames

F_u for chevron, vee, and K bracing is 1.15 for Moderate Hazard facilities and 1 for High Hazard facilities. K bracing is not permitted in buildings of more than two stories for Z of 0.25g or more. K bracing requires special consideration for any building if Z is 0.25g or more.

For columns subjected to combined axial compression and bending, interaction formulas from Figures 4-2 and 4-3 of Reference 11 should be used for Moderate and High Hazard facilities.

For Moderate and High Hazard facilities, it is permissible to use the F_u value which applies to the overall structural system for structural elements not mentioned on the above table. For example, to evaluate diaphragm elements, footings, pile foundations, etc., F_u of 3.0 may be used for a Moderate Hazard steel SMRSF. In the case of a Moderate Hazard steel concentric braced frame, F_u of 1.7 may be used.

TABLE 4-3
MAXIMUM HORIZONTAL GROUND SURFACE ACCELERATIONS AT DOE SITES
(Reference 1)

DOE SITE	HAZARD ANNUAL PROBABILITY OF EXCEEDANCE		
	2x10 ⁻³	1x10 ⁻³	2x10 ⁻⁴
BENDIX PLANT	.08	.10	.17
LOS ALAMOS SCIENTIFIC LABORATORY	.18	.22	.38
MOUND LABORATORY	.12	.15	.23
PANTEX PLANT	.08	.10	.17
ROCKY FLATS PLANTS**	.13	.15	.21
SANDIA NATIONAL LABORATORIES, ALBUQUERQUE	.17	.22	.38
SANDIA NATIONAL LABORATORIES, LIVERMORE, CA	.41	.48	.68
PINELLAS PLANT, FLORIDA	.04	.05	.09
ARGONNE NATIONAL LABORATORY-EAST	.09	.12	.21
ARGONNE NATIONAL LABORATORY-WEST	.12	.14	.21
BROOKHAVEN NATIONAL LABORATORY	.12	.15	.25
PRINCETON NATIONAL LABORATORY	.13	.16	.27
IDAHO NATIONAL ENGINEERING LABORATORY	.12	.14	.21
FEED MATERIALS PRODUCTION CENTER	.10	.13	.20
OAK RIDGE NATIONAL LABORATORY, X-10, K-25, and Y-12	.15	.19	.32
PADUCAH GASEOUS DIFFUSION PLANT	.33	.45	*
PORTSMOUTH GASEOUS DIFFUSION PLANT	.08	.11	.17
NEVADA TEST SITE	.21	.27	.46
HANFORD PROJECT SITE	.09	.12	.17
LAWRENCE BERKELEY LABORATORY	.55	.64	*
LAWRENCE LIVERMORE NATIONAL LABORATORY (LLNL)	.41	.48	.68
LLNL, SITE 300-854	.32	.38	.56
LLNL, SITE 300-834 & 836	.28	.34	.51
ENERGY TECHNOLOGY AND ENGINEERING CENTER	.53	.59	*
STANFORD LINEAR ACCELERATOR CENTER	.45	.59	*
SAVANNAH RIVER PLANT	.08	.11	.19

* Value not available from Reference 1 and must be determined for High Hazard facilities at these sites.

** Bedrock slopes at Rocky Flats. This value is surface acceleration at an average soil depth at this site.

Note: Values given in this table are largest peak instrumental accelerations. Maximum vertical acceleration may be assumed to be 2/3 of the mean peak horizontal acceleration (see Section 4.4.1 for a discussion of earthquake components and mean peak horizontal acceleration).

4.2.3 Evaluation of Moderate & High Hazard Facility Seismic Behavior

Moderate and High Hazard facilities should initially be analyzed by the 1988 UBC static force method (as described in Section 4.2.2) utilizing an importance factor, I , of 2.0 and peak ground accelerations, Z , corresponding to hazard exceedance probabilities of 1×10^{-3} for Moderate Hazard and 2×10^{-4} for High Hazard. **1988 UBC provisions with $I = 2.0$ provide minimum seismic requirements for Moderate and High Hazard facilities.**

In addition, the earthquake evaluation approach for Moderate and High Hazard facilities should also include elastic dynamic analysis of the facility. Limited inelastic behavior is permissible for those facilities with adequate design details such that ductile response is possible or for those facilities with redundant lateral load paths. Inelastic behavior is accounted for in the evaluation approach by specifying inelastic demand-capacity ratios, F_u , for elements of the facility. These ratios are the maximum amount that the elastically computed demand can exceed the capacity of elements of the facility, and they are related to the amount of inelastic deformation that is permissible in each category. By permitting less inelastic behavior for more hazardous categories, the margin of safety for that category is effectively increased. The approach employed for Moderate and High Hazard facilities is from the Department of Defense (DOD) Tri-service manual entitled *Seismic Design Guidelines for Essential Buildings* (Reference 11). The inelastic demand-capacity ratios from Reference 11 can be shown to be generally consistent with the performance goals for each category and with the R_w factors from the 1988 UBC provisions as discussed in Appendix A.

Elastic dynamic analysis procedures such as those described in Reference 11 can be used for both new and existing facilities (also refer to Section 4.4.5 for existing facilities). Basic steps by this approach include the following:

1.	Evaluate element forces, $F(DL)$ and $F(LL)$, throughout the facility for dead and live loads (realistic estimate of loads for existing facilities).
2.	<p>Develop median input earthquake response spectra from the Reference 1 hazard curves based upon site-specific geotechnical studies. In lieu of a site-specific study, it is acceptable to determine the median response spectral shape from References 1, 25, 26, or 27. Input spectra should be anchored to peak ground accelerations (Table 4-3) determined from the hazard curves at the following exceedance probabilities:</p> <p>Moderate Hazard - 1×10^{-3} High Hazard - 2×10^{-4}</p> <p>Note that for fundamental periods lower than the period at which the maximum spectral amplification occurs, the maximum spectral acceleration should be used (see Figure 4-1). For higher modes, the actual spectral accelerations should be used in accordance with recommendations from Reference 11. (Note that this requirement necessitates that response spectrum dynamic analysis be performed for building response evaluation). The actual spectrum may be used for all modes if there is high confidence in the frequency evaluation and F_u is taken to be unity. As stated on Figure 4-1, the actual spectrum at all frequencies should be used to evaluate nonstructural components, equipment, piping, etc. by dynamic analysis; and to develop floor response spectra used for the evaluation of structure-supported subsystems.</p>

3.	Utilizing the input spectra developed above and a mathematical model of the facility, perform an elastic dynamic analysis of the facility to evaluate the elastic earthquake demand, $F(EQ)$, of all elements of the facility. Damping should be determined from Table 4-4.
4.	Evaluate the total demand for all elements of the facility, D , from: $D = [F(DL) + F(LL) + F(EQ)] / F_U$ where F_U is the allowable inelastic demand-capacity ratio as given in Table 4-2.
5.	Evaluate capacities of the elements of the facility, CAP , from code ultimate or yield values (e.g., UBC Sec. 2609 & 2625 for reinforced concrete and 1.7 times UBC Sec. 2702 or UBC Sec. 2721 for steel). Note that strength reduction factors, ϕ , are retained for Moderate and High Hazard facilities. Minimum specified or known in-situ values for material strengths should be used for estimation of capacities.
6.	Compare total demand, D , with facility capacity, CAP . If D is less than or equal to CAP , the facility satisfies the seismic lateral force requirements. If D is greater than CAP , the facility has inadequate lateral force resistance.
7.	Evaluate story drifts due to lateral forces, including both translation and torsion. It may be assumed that inelastic drifts are adequately approximated by elastic analyses. Note that for Moderate and High Hazard facilities, loads used to compute drifts are not reduced as is the case for Section 4.2.2 guidelines where loads used to compute story drifts are reduced by R_w . Where confinement of hazardous materials is of importance, calculated story drifts should not exceed 0.010. This drift limit may be exceeded when acceptable performance of both the structure and nonstructural elements can be demonstrated at greater drift.
8.	Check elements of the facility to assure that good detailing practice has been followed. Values of F_U given in Table 4-2 are upper limit values assuming good design detailing practice as discussed in Section 4.3 and consistency with recent UBC provisions. UBC Seismic Zone No. 2 provisions should be met when Z is between 0.12 and 0.24g. UBC Seismic Zone Nos. 3 & 4 provisions should be followed when Z is 0.25g or more. Special seismic provisions in the UBC need not be followed if Z is 0.11g or less.
9.	Implement peer review of engineering drawings and calculations, special inspection and testing of new construction or existing facilities, and other quality assurance measures discussed in Section 4.3 for Moderate and High Hazard facilities.
10.	Inelastic analyses may, alternatively, be performed for Moderate and High Hazard facilities. Acceptable inelastic analysis procedures include: <ol style="list-style-type: none"> Capacity spectrum method as described in Reference 11. Direct integration time history analyses explicitly modeling inelastic behavior of individual elements of the facility. Several representative earthquake time histories are required for dependable results from these analyses.

TABLE 4-4
RECOMMENDED DAMPING VALUES*
(References 11 and 25)

Type of Structure	Damping (% of Critical)
Equipment and Piping	5
Welded Steel and Prestressed Concrete	7
Bolted Steel and Reinforced Concrete	10
Masonry Shear Walls	12
Wood	15

* Corresponding to post yield stress levels to be used for evaluation of Moderate and High Hazard Facilities.

4.3 EARTHQUAKE DESIGN DETAILS AND QUALITY ASSURANCE

This section briefly describes general design considerations which enable structures or equipment to perform during an earthquake in the manner intended by the designer. These design considerations attempt to avoid premature, unexpected failures and encourage ductile behavior during earthquakes. This material is intended for both design of new facilities and evaluation of existing facilities. For new facilities, this material addresses recommended seismic design practices. For existing facilities, this material may be used for identifying potential deficiencies in the capability of the facility to withstand earthquakes (i.e., ductile behavior, redundant load paths, high quality materials and construction, etc.). In addition, good seismic design practice, as discussed in this section, should be employed for upgrading or retrofitting existing facilities.

Characteristics of the lateral force-resisting systems are as important or more so than the earthquake load level used for design or evaluation. These characteristics include redundancy; ductility; tying elements together to behave as a unit; adequate equipment anchorage; understanding behavior of non-uniform; non-symmetrical structures or equipment; detailing of connections and reinforced concrete elements; and the quality of design, materials, and construction. The level of earthquake ground shaking to be experienced by any facility in the future is highly uncertain. As a result, it is important for facilities to be tough enough to withstand ground motion in excess of their design ground motion level. There can be high confidence in the earthquake safety of facilities designed in this manner. Earthquakes produce transient, limited energy loading on facilities. Because of these earthquake characteristics, well designed and constructed facilities (i.e., those with good earthquake design details and high quality materials and construction which provide redundancy and energy absorption capacity) can withstand earthquake motion well in excess of design levels. However, if details which provide redundancy or energy absorbing capacity are not provided, there is little real margin of safety built into the facility. It would be possible for significant earthquake damage to occur at ground shaking levels only marginally above the design lateral force level. Poor materials or construction could potentially lead to damage at well below the design lateral force level. Furthermore, poor design details, materials, or construction increase the possibility that a dramatic failure of a facility may occur.

A separate document providing guidelines, examples, and recommendations for good seismic design of facilities is currently being planned as part of this overall project. This section briefly describes general design considerations which are important to achieving well-designed and constructed earthquake-resistant facilities or to assessing whether existing

facilities are well-designed and constructed for earthquake effects. Considerations for good earthquake resistance of structures, equipment, and piping include (1) configuration; (2) continuous and redundant load paths; (3) detailing for ductile behavior; (4) tying systems together; (5) influence of non-structural components; (6) survival of emergency systems; and (7) quality of materials and construction. Each of these considerations is briefly discussed below. While the following discussion seems to primarily address buildings, the principles introduced are equally applicable to enhancing the earthquake resistance of equipment, piping, or other components.

Configuration - Structure configuration is very important to earthquake response. Irregular structures have experienced greater damage during past earthquakes than uniform, symmetrical structures. This has been the case even with good design and construction; therefore structures with regular configurations should be encouraged for new designs, and existing irregular structures should be evaluated with greater scrutiny than would otherwise be employed. Irregularities such as large re-entrant corners create stress concentrations which produce high local forces. Other plan irregularities, such as those due to the distribution of mass or vertical seismic resisting elements (or differences in stiffness between portions of a diaphragm), can result in substantial torsional response during an earthquake. Vertical irregularities, such as large differences in stiffness or mass in adjacent levels or significant horizontal offsets at one or more levels, can produce large local forces during an earthquake. An example is the soft story building which has a tall open frame on the bottom floor and shear wall or braced frame construction on upper floors (e.g., Olive View Hospital, San Fernando, CA earthquake, 1971 and Imperial County Services Building, Imperial Valley, CA earthquake, 1979). In addition, adjacent structures should be separated sufficiently so that they do not hammer one another during seismic response.

Continuous And Redundant Load Paths - Earthquake excitation induces forces at all points within structures or equipment of significant mass. These forces can be vertical or along any horizontal (lateral) direction. Structures are most vulnerable to damage from lateral seismic-induced forces, and prevention of damage requires a continuous load path (or paths) from regions of significant mass to the foundation or location of support. The designer/evaluator must follow seismic-induced forces through the structure (or equipment or piping) into the ground and make sure that every element and connection along the load path is adequate in strength and stiffness to maintain the integrity of the system. Redundancy of load paths is a highly desirable characteristic for earthquake-resistant design. When the primary element or system yields or fails, the lateral forces can be redistributed to a secondary system to prevent progressive failure. In a structural system without redundant components, every component

must remain operative to preserve the integrity of the structure. It is good practice to incorporate redundancy into the seismic-resisting system and not to rely on any system wherein distress in any member or element may cause progressive or catastrophic collapse.

Detailing For Ductile Behavior - In general, it is uneconomical or impractical to design structures to remain within the elastic range of stress for earthquakes which have very low probability of occurrence. Furthermore, it is highly desirable to design structures or equipment in a manner which avoids brittle response and premature unexpected failure such that the structure or equipment is able to dissipate the energy of the earthquake excitation without unacceptable damage. As a result, good seismic design practice requires selection of an appropriate structural system with detailing to develop sufficient energy absorption capacity to limit damage to permissible levels.

Structural steel is an inherently ductile material. Energy absorption capacity may be achieved by designing connections to avoid tearing or fracture and to ensure an adequate path for a load to travel across the connection. Because of the possibility of instability by buckling for relatively slender steel members acting in compression, detailing for adequate stiffness and restraint of compression braces, outstanding legs of members, compression flanges, etc., must be provided. Furthermore, deflections must be limited to prevent overall frame instability due to P-delta effects.

Brittle materials such as concrete and unit-masonry require steel reinforcement to provide the ductility characteristics necessary to resist seismic forces. Concrete structures should be designed to prevent concrete compressive failure, concrete shearing failure, or loss of reinforcing bond or anchorage. Compression failures in flexural members can be controlled by limiting the amount of tensile reinforcement or by providing compression reinforcement and requiring confinement by closely spaced transverse reinforcing of longitudinal reinforcing bars (e.g., spirals, stirrup ties, or hoops and supplementary cross ties). Confinement increases the strain capacity and compressive-, shear-, and bond-strengths of concrete. Maximum confinement should be provided near joints and in column members. Failures of concrete in shear or diagonal tension can be controlled by providing sufficient shear reinforcement, such as stirrups and inclined bars. Anchorage failures can be controlled by sufficient lapping of splices, mechanical connections, welded connections, etc. There should be added reinforcement around openings and at corners where stress concentrations might occur during earthquake motions. Masonry walls must be adequately reinforced and anchored to floors and roofs.

Tying Systems Together - One of the most important attributes of an earthquake-resistant structural system is that it is tied together to act as a unit. This attribute not only aids in earthquake resistance; it also adds to the capability to resist high winds, floods, explosions, progressive failure, and foundation settlement. Different parts of buildings should be interconnected. Beams and girders should be adequately tied to columns, and columns should be adequately tied to footings. Concrete and masonry walls should be anchored to all floors and roofs for lateral support. Diaphragms which distribute lateral loads to vertical resisting elements must be adequately tied to these elements. Collector or drag bars should be provided to collect shear forces and transmit them to the shear-resisting elements, such as shear walls or other bracing elements, which may not be uniformly spaced around the diaphragm. Shear walls must be adequately tied to floor and roof slabs and to footings.

In some structures, the system carrying earthquake-induced loads may be separate from the system which carries gravity loads. Although such systems are not needed for lateral resistance, they would deform with the rest of the structure as it deforms under lateral seismic loads. The vertical load carrying system should be evaluated for compatibility with the

deformations resulting from an earthquake to ensure that it is adequately designed. Similarly, gravity loads should be combined with earthquake loads in the evaluation of the lateral force resisting system.

Survival of Emergency Systems - In addition to preventing damage to structures, equipment, piping, nonstructural elements, etc., it is usually necessary for emergency systems and lifelines to survive the earthquake. Means of ingress and egress, such as stairways, elevator systems, and doorways, must remain functional for personnel safety and for control of hazardous operations. Fire protection systems must remain operational after an earthquake. Normal off-site power has been vulnerable during past earthquakes. Either normal off-site or emergency on-site water and power supplies must be available following an earthquake. Liquid fuels or other flammables may leak from broken lines. Electrical short circuits may occur. Hence, earthquake-resistant design considerations extend beyond the dynamic response of structures and equipment to include survival of systems which prevent facility damage or destruction due to fires or explosions which might result from an earthquake.

Quality of Materials and Construction - Earthquake design or evaluation considerations discussed thus far address recommended engineering practice that maximizes earthquake resistance of facilities. For important or hazardous facilities, it is further recommended that designers or earthquake consultants employ quality assurance procedures and that their work be subjected to independent peer review. Additional earthquake design or evaluation considerations include:

- a. Is the facility constructed of high quality materials that meet design specifications for strength and stiffness?
- b. Have the design detailing measures, as described above, been implemented in the construction of the facility?

The remainder of this section discusses earthquake engineering quality assurance, peer review, and construction inspection requirements.

To achieve well-designed and constructed earthquake-resistant facilities or to assess whether existing facilities are well-designed and constructed for earthquake effects, it is necessary to:

- a. Understand the seismic response of the facility.
- b. Select and provide an appropriate structural system.
- c. Provide seismic design detailing that obtains ductile response and avoids premature failures due to instability or brittle response
- d. Provide materials' testing and construction inspection.

It is recommended that Important or Low Hazard, Moderate Hazard, and High Hazard facilities be designed or evaluated utilizing an earthquake engineering quality assurance plan similar to that recommended by *Recommended Lateral Force Requirements and Tentative Commentary*, Seismology Committee, Structural Engineers Association of California (Reference 28). The earthquake engineering quality assurance plan should include:

1. A statement by the engineer of record on the earthquake design basis including: (1) description of the lateral force resisting system, and (2) definition of the earthquake loading used for the design or evaluation. For new designs, this statement should be on the design drawings; for evaluations of existing facilities, it should be at the beginning of the seismic evaluation calculations.
2. Seismic design or evaluation calculations should be checked for numerical accuracy and for theory and assumptions. The calculations should be signed by the responsible engineer who performed the calculations as well as the engineer who checked numerical accuracy and the engineer who checked theory and assumptions. If the calculations include work performed on a computer, the responsible engineer should sign the first page of the output, the model used should be described, and those values input or calculated by the computer should be identified.
3. For new construction, the engineer of record should specify a material testing and construction inspection program. In addition, the engineer should review all testing and inspection reports and periodically make site visits to observe compliance with plans and specifications. For certain circumstances, such as the placement of rebar and concrete for special ductile frame construction, the engineer of record should arrange to provide a specially qualified inspector to continuously inspect the construction and to certify compliance with the design.
4. For important or hazardous facilities, all aspects of the seismic design or evaluation must include independent peer review. For new construction, the designer will have been selected based on his capabilities to design a very complex facility with many problems in addition to seismic design. Furthermore, the designer will likely be under pressure to produce work on accelerated schedules and for low fees. As a result, the designer may not be able to devote as much attention to seismic design as he might like. Also, because of the low fee criteria, the most qualified designer may not be selected. Therefore, it is required to have the seismic design reviewed by a qualified, independent consultant or group. For existing facilities, the engineer conducting a seismic evaluation will likely be qualified and will be able to devote his full attention to evaluating the seismic adequacy of the facility. In this case, an independent review is not as important as it is for a new design. Even so, for major hazardous facilities, it may be prudent to have concurrent independent seismic evaluations performed or to have the seismic evaluation independently reviewed. The seismic design or evaluation review should include design philosophy, structural system, construction materials, criteria used, and other factors pertinent to the seismic capacity of the facility. The review need not provide a detailed check but rather an overview to help identify oversights, errors, conceptual deficiencies, and other potential problems which might affect the facility performance during an earthquake.

4.4 OTHER SEISMIC DESIGN AND EVALUATION CONSIDERATIONS

4.4.1 Effective Peak Ground Motion

Loads induced by earthquake ground shaking to be used for the design or evaluation of facilities, in accordance with the guidelines presented herein, are based on median amplification response spectra anchored to maximum ground acceleration for specified annual probabilities of exceedance (see Section 4.2 and Appendix A). As a result, seismic hazard curves wherein peak ground accelerations are presented as a function of annual probability of exceedance and median amplification response spectra are required for each DOE facility. This ground motion data can be obtained from site-specific studies. Alternatively, Reference 1 provides seismic hazard curves and earthquake response spectra for each DOE facility. In addition, Sections 4.2.2 and 4.2.3 allow the methods described in References 25, 26, and 27 to be used to estimate median spectral amplification. For convenience, this section discusses ground motion as defined by Reference 1. Maximum ground accelerations at the specified annual probabilities of exceedance recommended by these guidelines for each facility-use category are reproduced in Table 4-3. For some facility sites with high seismic hazard, note that the Reference 1 hazard curves do not provide acceleration values at hazard exceedance probability levels of 2×10^{-4} . For the design or evaluation of High Hazard facilities at these sites, maximum ground accelerations will have to be developed at 2×10^{-4} annual probability of exceedance.

The peak ground accelerations reported in Reference 1 correspond to the maximum acceleration that would be recorded during an earthquake by a three-axis strong motion instrument on a small foundation pad at the free ground surface. This value is called the peak instrumental acceleration. For the following reasons, the largest peak instrumental acceleration and response spectra anchored to such an acceleration often provide an excessively conservative estimate of the ground motion actually input to a stiff, massive structure and/or the damage potential of the earthquake.

- a. Peak value of other components is less than the largest peak acceleration as given in Reference 1.
- b. Effective peak acceleration based on repeatable acceleration levels with frequency content corresponding to that of structures is a better measure of earthquake damage potential.
- c. Soil-structure interaction reduces input motion from instrumental, free ground surface values.

These reasons are extensively discussed in Reference 29 and are briefly addressed below.

First, in most seismic evaluations, it is assumed that the defined ground motion represents both orthogonal horizontal components and that the vertical ground motion component is taken as two-thirds of the average horizontal component. This approach is consistent with the defined ground motion representing the mean peak (average of two horizontal components) instrumental acceleration, rather than the largest peak acceleration as defined by Reference 1. With the largest peak acceleration defined by Reference 1, it is permissible to assume that the second orthogonal horizontal component is 80 percent of the motion defined by Reference 1, while the vertical component is 60 percent of the Reference 1 motion. Note that this assumption is equivalent to the mean peak acceleration being 90 percent of the largest peak value and the vertical component being two-thirds of the mean peak value in accordance with common practice.

Second, the instrumental acceleration is a poor measure of the damage potential of ground motion associated with earthquakes at short epicentral ranges (less than about 20 km). Many structures located close to the epicentral region, which were subjected to high values of peak instrumental acceleration, have sustained much less damage than would be expected considering the acceleration level. In these cases, the differences in measured ground motion, design levels, and observed behavior were so great that it could not be reconciled by considering typical safety factors associated with seismic design. The problem with instrumental acceleration is that a limited number of high frequency spikes of high acceleration are not significant to structural response. Instead, it can be more appropriate to utilize a lower acceleration value which has more repeatable peaks and is within the frequency range of structures. Such a value, called effective peak acceleration, has been evaluated by many investigators and is believed to be a good measure of earthquake ground motion amplitude related to performance of structures. Reference 29 contains a suggested approach for defining the effective peak acceleration. However, this approach would require the development of representative ground motion time histories appropriate for the earthquake magnitudes and epicentral distances which are expected to dominate the seismic hazard at the site. Reference 1 does not contain this information, so special studies would be required for any site to take advantage of the resultant reduction. The reductions which are likely to be justifiable from such studies would most probably be significant for sites with peak instrumental accelerations defined by Reference 1 in excess of about 0.4g. The benefits would be expected to increase with increasing peak instrumental accelerations. These higher ground accelerations most probably are associated with short duration ground motion from earth-

base slab interface corresponding to a shear wave velocity, v_s , of 3500 fps or lower. Accounting for SSI requires sophisticated seismic analysis techniques which, if performed correctly, will most likely reduce the seismic forces in the structure. Accounting for SSI is recommended but not required. If SSI effects are considered, the seismic analysis should be reviewed by qualified experts.

The seismic hazard is defined by Reference 1 for the free ground surface. Input into the foundation is then most accurately determined by soil column site analysis. However, the free ground surface motion can be applied to the foundation provided the conservatism thus introduced is acceptable.

Horizontal spatial variations in ground motion result from non-vertically propagating shear waves and from incoherence of the input motion (i.e., refractions and reflections as earthquake waves pass through the underlying heterogeneous geologic media). The following reduction factors may be conservatively used to account for the statistical incoherence of the input wave for a 150-foot plan dimension of the structure foundation (Reference 29):

Fundamental Frequency of the Soil-Structure System (Hz)	Reduction Factor
5	1.0
10	0.9
25	0.8

For structures with different plan dimensions, a linear reduction proportional to the plan dimension should be used: for example, 0.95 at 10 Hz for a 75-foot dimension and 0.8 at 10 Hz for a 300-foot dimension (based on 1.0 reduction factor at 0-foot plan dimension). These reductions are acceptable for rock sites as well as soil sites. The above reduction factors assume a rigid base slab. Unless a severely atypical condition is identified, a rigid base slab condition may be assumed to exist for all structures for purposes of computing this reduction.

The available information for soil properties at different sites tends to be quite variable concerning the level of detail. Further uncertainty is usually introduced in the development of soil parameters appropriate for SSI analysis. For instance, the degree of soil softening at the dynamic strain levels expected during the defined seismic event, the amount of soil hysteretic material damping, and the impedance mismatches which may exist due to layering are usually not known precisely. It is not the intent to require additional soil boring or laboratory investigations unless absolutely necessary. Rather, a relatively wide range of soil shear moduli (which are usually used to define the foundation stiffness) is recommended such that a conservative structure response may be expected to be calculated. The well known effect that the shear

modulus of soils decreases with increasing shear strain must be accounted for when performing an SSI analysis. The variation in shear modulus as a function of shear strain for sands, gravelly soils, and saturated clays can be found in References 30 and 31.

To account for uncertainty in the soil properties, the soil stiffness (horizontal, vertical, rocking, and torsional) employed in analysis should include a range of soil shear moduli bounded by (a) 50 percent of the modulus corresponding to the best estimate at the seismic strain level, and (b) 90 percent of the modulus corresponding to the best estimate the low strain, unless better estimates of the uncertainty are available. Three soil modulus conditions are generally recommended corresponding to (a) and (b) above, and (c), a best estimate shear modulus.

Soil impedances (stiffness and damping) can be accounted for using either Finite Element Methods (FEM), elastic half-space solutions, or more refined analytical techniques which address layering, various foundation shapes, and foundation elevations. Elastic half-space solutions using frequency-dependent impedance functions, such as those shown in Table 4-5, are acceptable for facilities on uniform soil sites or sites where the soil properties do not create significant impedance mismatches between layers. In addition to geometric (radiation) damping developed using either elastic half-space or FEM methods, soil material damping should be included in an SSI analysis. Soil material damping as a function of shear strain can be found in References 30 and 31 for sands, gravelly soils, and saturated clays. Lacking site-specific data, it is appropriate to include soil material damping corresponding to the mean value at the earthquake shaking induced strain level from one of the above references.

For structures which are significantly embedded, the embedment effects should also be included in the SSI analysis. These effects can be incorporated using available simplified methods (References 32 and 33) for some geometries. The potential for reduced lateral soil support of the structure should be considered when accounting for embedment effects. Section 3.3.1.9 of Reference 34 provides guidance on this subject. Similarly, some layer effects can also be incorporated using simplified methods (Reference 35). For more complex situations, more refined analysis, such as discussed by various authors in Reference 36, is desirable.

TABLE 4-5
FREQUENCY DEPENDENT ELASTIC HALF-SPACE IMPEDANCE

Direction of Motion	Equivalent Spring Constant for Rectangular Footing	Equivalent Spring Constant for Circular Footing	Equivalent Damping Coefficient
Horizontal	$k_x = k_1 2(1 + \nu) G \beta_x \sqrt{BL}$	$k_x = k_1 \frac{32(1 - \nu) GR}{7 - 8\nu}$	$c_x = c_1 k_x(\text{static}) R \sqrt{\rho/G}$
Rocking	$k_\psi = k_2 \frac{G}{1 - \nu} \beta_\psi B^2 L$	$k_\psi = k_2 \frac{8GR^3}{3(1 - \nu)}$	$c_\psi = c_2 k_\psi(\text{static}) R \sqrt{\rho/G}$
Vertical	$k_z = k_3 \frac{G}{1 - \nu} \beta_z \sqrt{BL}$	$k_z = k_3 \frac{4GR}{1 - \nu}$	$c_z = c_3 k_z(\text{static}) R \sqrt{\rho/G}$
Torsion	—	$k_\theta = k_4 \frac{16}{3} GR^3$	$c_t = c_4 k_t(\text{static}) R \sqrt{\rho/G}$

ν = Poisson's ratio of foundation medium,

G = shear modulus of foundation medium,


R = radius of the circular base mat,

ρ = density of foundation medium,

B = width of the base mat in the plane of horizontal excitation,

L = length of the base mat perpendicular to the plane of horizontal excitation,

k_1, k_2, k_3, k_4 = frequency dependent coefficients modifying the static stiffness or damping (Refs. 32, 34, 35, etc.).
 c_1, c_2, c_3, c_4



Constants β_x , β_z , and β_ψ for a Rectangular Foundation

4.4.3 Combination of Earthquake Components

Actual earthquake records demonstrate that horizontal and vertical components of motion are essentially statistically independent. Consequently, there is only a small probability that the peak responses, due to each of the three individual earthquake components, will occur at the same time. Methods of combining responses from different earthquake components in a reasonable manner are described in this section.

For General Use and Important or Low Hazard facilities, the effects of concurrent earthquake ground motion in orthogonal horizontal directions should be considered for those cases required by the 1988 UBC provisions. This requirement is satisfied by designing elements for 100 percent of the prescribed seismic forces in one horizontal direction plus 30 percent of the prescribed forces in the perpendicular horizontal direction. The combination requiring the greater component strength should be used for design/evaluation. Alternatively, the effects of the two orthogonal directions may be combined on a square root of the sum of the squares (SRSS) basis. When the SRSS method of combining directional effects is used, each term computed is assigned the sign that produces the most conservative result. By UBC provisions, the contribution due to the vertical component is not combined with response from other components. There is a UBC requirement to design horizontal cantilever components for a net upward force.

For Moderate and High Hazard facilities, earthquake responses in a given direction from the three earthquake components should be combined directly, using the assumption that, when the maximum response from one component occurs, the responses from the other two components are 40 percent of the maximum. In this method, all possible combinations of the three orthogonal components, including variations in sign, should be considered. Alternatively, the effects of the three orthogonal directions may be combined by SRSS, as discussed above.

In Section 4.4.1, it was established that the peak value of other components of earthquake ground motion is less than the largest peak acceleration as given in Reference 1. As a result, with the largest peak acceleration defined by Reference 1, it may be assumed that the second orthogonal horizontal component is 80 percent of the motion defined by Reference 1, while the vertical component is 60 percent of the Reference 1 motion. Therefore, when the largest peak acceleration as defined in Reference 1 is used to evaluate earthquake response in a given horizontal direction, response due to the other horizontal direction of motion should be taken as 40 percent of 80 percent of the response computed from the largest peak acceleration. Response due to the vertical component should be taken as 40 percent of 60 percent of the

response computed from the largest peak acceleration. Note that this approach is approximately equivalent to the UBC provisions of designing elements for 100 percent of the prescribed seismic forces in one horizontal direction plus 30 percent of the prescribed forces in the perpendicular horizontal direction.

4.4.4 Special Considerations for Equipment and Piping

For DOE facilities that house hazardous operations and materials, the seismic adequacy of equipment and piping is as important as the adequacy of the building. As part of the DOE Natural Phenomena Hazards project, a document has been prepared which provides practical guidelines for the support and anchorage of many equipment items that are likely to be found in DOE facilities (Reference 5). This document primarily addresses equipment strengthening and upgrading to increase the seismic capacity in existing facilities. However, the document is also recommended for considerations of equipment support and anchorage in new facilities.

Special considerations about the seismic resistant capacity of equipment and piping include:

1. Equipment or piping supported within a structure respond to the motion of the structure rather than the ground motion. Equipment supported on the ground or on the ground floor within a structure experiences the same earthquake ground motion as the structure.
2. Equipment or piping supported at two or more locations within a structure are stressed due to both inertial effects and relative support displacements.
3. Equipment or piping may have either negligible interaction or significant coupling with the response of the supporting structure. With negligible interaction, only the mass distribution of the equipment should be included in the model of the structure. The equipment may be analyzed independently. With strong coupling or if the equipment mass is 10 percent or more of the structure story mass, the equipment should be modeled along with the structure model.
4. Many equipment items are inherently rugged and can survive large ground motion if they are adequately anchored.
5. Many equipment items are common to many industrial facilities throughout the world. As a result, there is a great deal of experience data on equipment from past earthquakes and from qualification testing. Equipment which has performed well based on experience would not require seismic analysis or testing (if it could be shown to be adequately anchored).
6. The presence of properly engineered anchorage is the most important single item which affects the seismic performance of equipment. There are numerous examples of equipment sliding or overturning in earthquakes due to lack of anchorage or inadequate anchorage.

For General Use and Important or Low Hazard facilities, the design or evaluation of equipment or nonstructural elements supported within a structure should be based on the total lateral seismic force, F_p , as given by the 1988 UBC provisions (Reference 10). For Moderate or High Hazard facilities, the design or evaluation of these items should be based on dynamic analysis, testing, or past earthquake experience data. In any case, equipment items and nonstructural elements must be adequately anchored to their supports. Anchorage must be verified for adequate strength and sufficient stiffness. In the remainder of this section, the UBC lateral force provisions are reproduced, important aspects of dynamic analyses are introduced, the use of past earthquake experience data is addressed, and guidance on equipment anchorage is provided.

UBC lateral force provisions - By the 1988 UBC provisions, parts of structures, permanent non-structural components, and equipment supported by a structure and their anchorages and required bracing must be designed to resist seismic forces. Such elements should be designed to resist a total lateral seismic force, F_p , of:

$$F_p = ZIC_pW_p \quad (4-2)$$

where: W_p = the weight of element or component

C_p = a horizontal force factor as given by Table 23-P of the UBC for rigid elements, or determined from the dynamic properties of the element and supporting structure for non-rigid elements, as discussed in Section 4.4.4 (In the absence of detailed analysis, the value of C_p for a non-rigid element should be taken as twice the value listed in Table 23-P, but need not exceed 2.0).

The lateral force determined using Equation 4-2 should be distributed in proportion to the mass distribution of the element or component. Forces determined from Equation 4-2 should be used for the design or evaluation of elements or components and their connections and anchorage to the structure, and for members and connections which transfer the forces to the seismic-resisting systems. Forces should be applied in the horizontal directions which result in the most critical loadings for design/evaluation.

Dynamic analysis principles - Guidelines for the design and analysis of equipment or non-structural elements supported within a structure by dynamic analysis are given in Chapter 6 of Reference 11 and in Reference 34. Elements attached to the floors, walls, or ceilings of a building (e.g., mechanical equipment, ornamentation, piping, and nonstructural partitions) respond to the motion of the building in much the same manner that the building responds to the earthquake ground motion. However, the building motion may vary substantially from the ground motion. The high frequency components of the ground motion are not amplified by

the building while the components of ground motion that correspond to the natural periods of vibrations of the building tend to be magnified. If the elements are rigid and rigidly attached to the structure, accelerations of the elements will be the same as the accelerations of the structure at the attachment points. But elements that are flexible and have periods of vibration close to any of the predominant modes of the building vibration will experience amplified accelerations over that which occurs in the structure.

The most common method of representing support excitation is by means of floor response spectra (also commonly called in-structure response spectra). A floor response spectrum is a response spectrum evaluated from the seismic response at support locations determined from a dynamic analysis of the structure. Floor response spectra can be computed most directly from a dynamic analysis of the structure conducted on a time-step by time-step basis. In addition, there are algorithms available that allow the generation of floor response spectra directly from the ground motion response spectrum and modal properties of the structure without time history analysis (e.g., References 37, 38, and 39). A simple method for evaluating floor spectra is provided in Chapter 6 of Reference 11 and is recommended herein. Note that floor response spectra should generally be developed assuming elastic behavior of the supporting structure even though inelastic behavior is permitted in the design of the structure. Conservatively underestimating the capacity of the structure as well as using minimum specified material strengths leads to conservative design of the structure but potentially unconservative floor response spectra. Greater floor spectra would result from elastic analysis based on realistic strength of the structure.

Equipment or piping which is supported at multiple locations throughout the structure could have different floor spectra for each support point. In such a case, it is acceptable to use a single envelope spectrum of all locations as the input to all supports. Alternatively, there are analytical techniques available for using different spectra at each support location or for using different input time histories at each different support.

Past earthquake experience data - Since many equipment items within DOE facilities will likely require seismic qualification, seismic experience data and data from past qualification program experience should be utilized, if possible. Seismic experience data is being developed in usable format by ongoing research programs sponsored by the nuclear power industry (References 40, 41, 42, and 43). It is necessary to conduct either seismic analyses or shake table testing to demonstrate sufficient seismic capacity for those items which cannot be eliminated from consideration through the use of seismic experience data or for items which

are not obviously invulnerable to earthquakes due to inherent ruggedness. It is also necessary to estimate the input excitation at locations of support for seismic qualification by experience data, analysis or testing of structure-supported equipment or piping.

Anchorage - Engineered anchorage of equipment or components is required for all facility-use categories. It is intended that anchorage have both adequate strength and sufficient stiffness. Types of anchorage include: (1) cast-in-place bolts or headed studs; (2) expansion anchor bolts; and (3) welds to embedded steel plates or channels.

Adequate strength of equipment anchorage requires consideration of tension, shear, and tension-shear interaction load conditions. It is recommended that the strength of cast-in-place anchor bolts be based on UBC Sec. 2624 provisions (Reference 10) for General Use and Important or Low Hazard facilities and on ACI 349-85 provisions (Reference 44) for Moderate and High Hazard facilities. The strength of expansion anchor bolts should generally be based on design allowable strength values available from standard manufacturers' recommendations or sources such as Reference 43. Design allowable strength values typically include a factor of safety of about 4 on the mean capacity of the anchorage. It is permissible to utilize strength values based on a lower factor of safety for evaluation of anchorage in existing facilities, provided the detailed inspection and evaluation of anchors is performed in accordance with Reference 43. Currently, a factor of safety on the order of 3 is judged to be appropriate for this situation. When anchorage is modified or new anchorage is designed, it is recommended that design allowable strength values including the factor of safety of 4 be used. For strength considerations of welded anchorage, it is recommended that AISC, Part 1 (Reference 45) allowable values multiplied by 1.7 be used.

Stiffness of equipment anchorage as discussed in Reference 41 should also be considered. Flexibility of base anchorage can be caused by the bending of anchorage components or equipment sheet metal. Excessive eccentricities in the load path between the equipment item and the anchor is a major cause of base anchorage flexibility. Equipment base flexibility can allow excessive equipment movement, reducing its natural frequency and possibly increasing its dynamic response. In addition, flexibility can lead to high stresses in anchorage components and failure of the anchorage or equipment sheet metal.

Summary - For General Use and Important or Low Hazard facilities, seismic evaluation of equipment or nonstructural elements supported by a structure can be based on the total lateral seismic force as given by Equation 4-2. For Moderate and High Hazard facilities, the seismic evaluation of equipment and piping necessitates the development of floor response spectra

representing the input excitation. Once seismic loading is established, seismic capacity can be determined by analysis, testing, or the use of seismic experience data. It is recommended that wherever possible, seismic qualification be accomplished through the use of experience data because such an approach is likely to be far less costly and time consuming.

4.4.5 Special Considerations for Evaluation of Existing Facilities

It is anticipated that these guidelines would also be applied to evaluations of existing facilities. General guidelines for the seismic evaluation of existing facilities are presented in a DOD manual (Reference 46). In addition, guidelines for upgrading and strengthening equipment are presented in Reference 5. These documents should be referred to for the overall procedure of evaluating seismic adequacy of existing facilities, as well as for specific guidelines on upgrading and retrofitting. General requirements and considerations in the evaluation of existing facilities are briefly presented below.

Existing facilities should be evaluated for earthquake ground motion in accordance with the guidelines presented earlier in this chapter. The process of evaluation of existing facilities differs from the design of new facilities in that the as-built condition of the existing facility must be assessed. This assessment includes reviewing drawings and making site visits to determine deviations from the drawings. In-place strength of the materials should also be determined. The actual strength of materials is likely to be greater than the minimum specified values used for design, and this may be determined from tests of core specimens or sample coupons. On the other hand, corrosive action and other aging processes may have had deteriorating effects on the strength of the structure or equipment, and these effects should also be evaluated in some manner. The inelastic action of facilities prior to occurrence of unacceptable damage should be taken into account since the inelastic range of response is where facilities can dissipate a major portion of the input earthquake energy. The ductility available in the existing facility without loss of desired performance should be estimated based on as-built design detailing rather than using the inelastic demand-capacity ratios presented in Table 4-2. An existing facility may not have seismic detailing to the desired level discussed in Section 4.3 and upon which the values presented in Table 4-2 are based.

Evaluation of existing facilities should begin with a preliminary inspection of site conditions, the building lateral force-resisting system and anchorage of building contents, mechanical and electrical systems, and nonstructural features. This inspection should include review of drawings and facility walkdowns. Site investigation should assess the potential for earthquake hazards in addition to ground shaking, such as active faults which might pass

beneath facilities or potential for earthquake-induced landslides, liquefaction, and consolidation of foundation soils. Examination of the lateral force-resisting system, concentrating on seismic considerations as discussed in Section 4.3, may point out obvious deficiencies or weakest links such that evaluation effort can be concentrated in the most useful areas and remedial work can be accomplished in the most timely manner. Inspection of connections for both structures and equipment indicates locations where earthquake resistance can be readily upgraded.

Once the as-built condition of a facility has been verified and deficiencies or weak links have been identified, detailed seismic evaluation and/or upgrading of the facility can be undertaken. Obvious deficiencies that can be readily improved should be remedied as soon as possible. Seismic evaluation for existing facilities would be similar to evaluations performed for new designs except that a single as-built configuration is evaluated instead of several configurations in an iterative manner as is required in the design process. Evaluations should be conducted in order of priority. Highest priority should be given to those areas identified as weak links by the preliminary investigation and to areas that are most important to personnel safety and operations with hazardous materials.

As discussed in Chapter 2, the evaluation of existing facilities for natural phenomena hazards can result in a number of options based on the evaluation results. If the existing facility can be shown to meet the design and evaluation guidelines as presented in Section 4.2 and good seismic design practice had been employed per Section 4.3, then the facility would be judged to be adequate for potential seismic hazards to which it might be subjected. If the facility does not meet the seismic evaluation guidelines of this chapter, several alternatives can be considered:

1. If an existing facility is close to meeting the guidelines, a slight increase in the annual risk to natural phenomena hazards can be allowed due to the difficulty in upgrading an existing facility compared to incorporating increased seismic resistance in a new design and due to the fact that existing facilities may have a shorter remaining life than a new facility. As a result, some relief in the guidelines can be allowed by either of the following approximately equivalent approaches:
 - a. permitting calculated seismic demand to exceed the seismic capacity by no more than 20 percent, or
 - b. performing the evaluation using hazard exceedance probability of twice the value recommended in Section 4.2 for each facility-use category.
2. The facility may be strengthened such that its seismic resistance capacity is sufficiently increased to meet the guidelines. When upgrading is required, it should be accomplished in compliance with unreduced guidelines (i.e., Item 1 provisions should not be used for upgrading).

3. The usage of the facility may be changed such that it falls within a less hazardous facility-use category and consequently less stringent seismic requirements.
4. It may be possible to conduct the aspects of the seismic evaluation in a more rigorous manner that removes conservatism such that the facility may be shown to be adequate. Alternatively, a probabilistic assessment of the facility might be undertaken in order to demonstrate that the performance goals for the facility can be met.

**THIS PAGE INTENTIONALLY
LEFT BLANK**

5 DESIGN AND EVALUATION CRITERIA FOR WIND LOAD

5.1 INTRODUCTION

This chapter presents a uniform approach to wind load determination that is applicable to the design of new facilities and the evaluation of existing ones. As discussed in Section 3.2, a uniform treatment of wind loads is recommended to accommodate extreme, hurricane, and tornado winds. Buildings or facilities are first assigned to appropriate facility-use categories as defined in Chapter 2. Criteria are recommended such that the performance goals for each category can be achieved. Procedures according to ANSI A58.1-1982 (Reference 16) are recommended for determining wind loads produced by straight, hurricane, and tornado winds. The extreme wind/tornado hazard models for DOE sites published in Reference 2 are used to establish site-specific criteria for each of the 25 DOE sites included in this study.

The performance goals established for General Use and Important or Low Hazard facility-use categories are met by conventional building codes or standards (see discussion in Chapter 2). These criteria do not account for the possibility of tornado winds, because wind speeds associated with extreme winds typically are greater than those for tornadoes at exceedance probabilities greater than approximately 1×10^{-4} . For this reason, tornado design criteria are specified only for buildings and facilities in Moderate and High Hazard categories, where hazard exceedance probabilities are less than 1×10^{-4} .

The traditional approach to establishing tornado design criteria is to select extremely low exceedance probabilities. For example, the exceedance probability for design of commercial nuclear power plants is 1×10^{-7} . There are reasons for departing from this traditional approach. The low exceedance value for commercial nuclear power plants was established circa 1960 when very little was known about tornadoes from an engineering perspective. Much has been learned about tornadoes since that time. Use of a low hazard probability is inconsistent with the practice relating to other natural hazards, such as earthquakes. There are many uncertainties in tornado hazard probability assessment, but they are not significantly greater than the uncertainties in earthquake probability assessment (see discussion in Appendix A). The strongest argument against using low probability criteria is that a relatively short period of record (37 years) must be extrapolated to extremely small exceedance probabilities. For these reasons, an alternative approach is proposed in these guidelines.

The rationale for establishing tornado criteria is described below. Figure 5-1 shows the tornado and straight wind hazard curves for two DOE sites (SLAC and ORNL). The wind speed at the intersection of the tornado and straight wind curves is defined for purposes of

this discussion as the transition wind speed. An exceedance probability is associated with each transition wind speed. If the exceedance probability of the transition wind speed is less than 10^{-5} per year, tornadoes are not a viable threat to the site, because straight winds are more likely. Thus, from Figure 5-1, tornadoes should not be considered at SLAC.




FIGURE 5-1
STRAIGHT WIND AND TORNADO REGIONS OF WIND HAZARD CURVES

Table 5-1 tabulates best estimate wind speeds from Reference 2 for each DOE site, along with the transition wind speed. Those sites with transition wind speed exceedance probabilities greater than 10^{-5} should be designed for tornadoes; others should be designed for extreme winds or hurricanes.

**TABLE 5-1
TYPES OF WIND FOR DESIGN LOADS**

Best-Estimate Wind Speeds- mph ¹						
DOE PROJECT SITES	Annual Hazard Exceedance Probability				Transition Wind Speed ²	Type of Wind for Design
	10 ⁻³	10 ⁻⁴	10 ⁻⁵	10 ⁻⁶		
Bendix Plant, MO	88	110	177	233	100	Tornado
Los Alamos National Scientific Laboratory, NM	93	107	122	136	140	Extreme
Mound Laboratory, OH	90	108	171	227	104	Tornado
Pantex Plant, TX	98	112	168	220	115	Tornado
Rocky Flats Plant, CO	138	161	183	208	— ³	Both
Sandia National Laboratories, Albuquerque, NM	93	107	122	135	139	Extreme
Sandia National Laboratories, Livermore, CA	96	113	131	150	—	Extreme
Pinellas Plant, FL	130	150	174	204	181	Hurricane
Argonne National Laboratory—East, IL	72	118	176	228	77	Tornado
Argonne National Laboratory—West, ID	83	95	105	118	119	Extreme
Brookhaven National Laboratory, NY	86	100	127	179	106	Tornado
Princeton Plasma Physics Laboratory, NJ	80	83	135	182	90	Tornado
Idaho National Engineering Laboratory, ID	84	95	105	115	117	Extreme
Feed Materials Production Center, OH	87	108	173	231	96	Tornado
Oak Ridge National Laboratory, X-10, K-25, and Y-12, TN	80	90	152	210	101	Tornado
Paducah Gaseous Diffusion Plant, KY	75	115	180	235	80	Tornado
Portsmouth Gaseous Diffusion Plant, OH	83	95	145	205	98	Tornado
Nevada Test Site, NV	87	100	110	124	131	Extreme
Hanford Project Site, WA	68	77	85	112	89	Extreme
Lawrence Berkeley Laboratory, CA	95	111	130	148	—	Extreme
Lawrence Livermore National Laboratory, CA	96	113	131	150	—	Extreme
Lawrence Livermore National Laboratory Site 300, CA	104	125	145	164	—	Extreme
Energy Technology and Engineering Center, CA	59	68	98	141	74	Tornado
Stanford Linear Accelerator Center, CA	95	112	130	149	158	Extreme
Savannah River Plant, SC	109	138	172	228	155	Tornado

NOTES:

1. Best-estimate wind speeds come from Reference 2.
2. Transition wind speed is at the intersection of the extreme wind hazard and the tornado hazard curves.
3. When transition wind speed is not listed, it is associated with a probability less than 10^{-6} .

TABLE 5-2
RELATIONSHIP BETWEEN TORNADO WIND SPEEDS AND
FASTEST-MILE WIND SPEEDS

Tornado Wind Speed, mph (V_t)	Fastest-Mile Wind Speed, mph (V_{fm})
100	85
110	94
120	103
130	113
140	123
150	132
160	142
170	151
180	161
190	170
200	180
210	190
220	200
230	209
240	218
250	231
260	241
270	250
280	260
290	271
300	280

$$V_{fm} = 0.958 V_t - 11.34$$

For an overview of extreme wind and tornado hazards, Reference 53 should be consulted. Reference 54 provides guidance on the design of structures to wind and tornado loads. These references supplement the material presented in this chapter.

5.2 CRITERIA FOR DESIGN OF FACILITIES

The criteria presented herein are consistent with the performance goals described in Chapter 2 for each facility-use category. Buildings or facilities in each category have a different role and represent different levels of hazard to people and the environment. In addition, the degree of wind hazard varies geographically. Facilities in the same facility-use category, but at different geographical locations, will have different criteria specified to achieve the same performance goal.

The minimum wind design criteria for each of the four facility-use categories are summarized in Table 5-3. The recommended basic wind speeds for extreme wind, hurricanes, and tornadoes are contained in Table 5-4. All wind speeds are fastest-mile. Minimum recommended basic wind speeds are noted in the table. The use of importance factors in evaluating effective velocity pressure is summarized in Table 5-5. Performance goals and their implications are discussed for each of the categories.

**TABLE 5-3
SUMMARY OF MINIMUM WIND DESIGN CRITERIA**

	Building Category	General Use	Important or Low Hazard	Moderate Hazard	High Hazard
w i n d	Annual Probability of Exceedance	2×10^{-2}	2×10^{-2}	1×10^{-3}	1×10^{-4}
	Importance Factor*	1.0	1.07	1.0	1.0
	Missile Criteria			2x4 timber plank 15 lb @ 50 mph (horiz.); max. height 30 ft.	2x4 timber plank 15 lb @ 50 mph (horiz.); max. height 50 ft.
t o r n a d o	Annual Hazard Probability of Exceedance			2×10^{-5}	2×10^{-5}
	Importance Factor*			$I = 1.0$	$I = 1.35$
	APC			40 psf @ 20 psf/sec	125 psf @ 50 psf/sec
	Missile Criteria			2x4 timber plank 15 lb @ 100 mph (horiz.); max. height 150 ft; 70 mph (vert.) 3 in. dia. std. steel pipe, 75 lb @ 50 mph (horiz.); max. height 75 ft, 35 mph (vert.)	2x4 timber plank 15 lb @ 150 mph (horiz.), max. height 200 ft; 100 mph (vert.) 3 in. dia. std. steel pipe, 75 lb @ 75 mph (horiz.); max. height 100 ft, 50 mph (vert.) 3,000 lb automobile @ 25 mph, rolls and tumbles

* See Table 5-5 for discussion of importance factors

**TABLE 5-4
RECOMMENDED BASIC WIND SPEEDS FOR DOE SITES**

Building Category	Fastest-Mile Wind Speeds at 10m Height					
	General Use	Important or Low Hazard	Moderate Hazard		High Hazard	
	Wind	Wind	Wind	Tornado	Wind	Tornado
DOE PROJECT SITES	2x10⁻²	2x10⁻²	1x10⁻³	2x10⁻⁵	1x10⁻⁴	2x10⁻⁵
Bendix Plant, MO	72	72	--	144	--	144
Los Alamos National Scientific Laboratory, NM	77	77	93	--	107	--
Mound Laboratory, OH	73	73	--	136	--	136
Pantex Plant, TX	78	78	--	132	--	132
Rocky Flats Plant, CO	109	109	138	138	161	161
Sandia National Laboratories, Albuquerque, NM	78	78	93	--	107	--
Sandia National Laboratories, Livermore, CA	72	72	96	--	113	--
Pinellas Plant, FL	93	93	130	--	150	--
Argonne National Laboratory--East, IL	70(1)	70(1)	--	142	--	142
Argonne National Laboratory--West, ID	70(1)	70(1)	83	--	95	--
Brookhaven National Laboratory, NY	70(1)	70(1)	--	95(2)	--	95(2)
Princeton Plasma Physics Laboratory, NJ	70(1)	70(1)	--	103	--	103
Idaho National Engineering Laboratory	70(1)	70(1)	84	--	95	--
Feed Materials Production Center, OH	70(1)	70(1)	--	139	--	139
Oak Ridge National Laboratory, X-10, K-25, and Y-12, TN	70(1)	70(1)	--	113	--	113
Paducah Gaseous Diffusion Plant, KY	70(1)	70(1)	--	144	--	144
Portsmouth Gaseous Diffusion Plant, OH	70(1)	70(1)	--	110	--	110
Nevada Test Site, NV	72	72	87	--	100	--
Hanford Project Site, WA	70(1)	70(1)	80(1)	--	90(1)	--
Lawrence Berkeley Laboratory, CA	72	72	95	--	111	--
Lawrence Livermore National Laboratory, CA	72	72	96	--	113	--
Lawrence Livermore National Laboratory, Site 300, CA	80	80	104	--	125	--
Energy Technology and Engineering Center, CA	70(1)	70(1)	--	95(2)	--	95(2)
Stanford Linear Accelerator Center, CA	72	72	95	--	112	--
Savannah River Plant, SC	78	78	--	137	--	137

NOTES:

1. Minimum extreme wind speed.
2. Minimum tornado speed.

TABLE 5-5
IMPORTANCE FACTORS AND EFFECTIVE VELOCITY PRESSURES

Facility-Use Category	Extreme Winds	At Hurricane Oceanlines	Tornadoes
General Use	1.00	1.05	--
Important or Low Hazard	1.07	1.11	--
Moderate Hazard	1.00	1.05	1.00
High Hazard	1.00	1.11	1.35

* For regions between the hurricane oceanline and 100 miles inland, the importance factor I shall be determined by linear interpolation.

In ANSI A58.1-1982 (Reference 16), effective velocity pressure, q_z , at any height z above ground is given by:

$$q_z = 0.00256K_z(I)V^2$$

where K_z is a velocity pressure coefficient evaluated at height z (as a function of terrain exposure category per Table 6 of Reference 16)
 I is importance factor given in Table 5-3 and above
 V is the basic wind speed given in Table 5-4

5.2.1 General Use Facilities

The performance goals for General Use facilities are consistent with objectives of ANSI A58.1-1982 Building Class I, Ordinary Structures. The wind-force resisting structural system should not collapse under design load. Survival without collapse implies that occupants should be able to find an area of relative safety inside the building. Breach of the building envelope is acceptable, since confinement is not essential. Flow of air through the building and water damage are acceptable. Severe damage, including total loss, is acceptable, so long as the structure does not collapse.

The ANSI A58.1-1982 calls for the basic wind speed to be based on an exceedance probability of 0.02 per year. The importance factor for this class of building is 1.0. For those sites within 100 miles of the Gulf of Mexico or Atlantic coastlines, a slightly higher importance factor is recommended to account for hurricanes (see Table 5-5).

Distinctions are made in the ANSI Specification between buildings and other structures, between main wind-force resisting systems, components, and cladding. In the case of components and cladding, a further distinction is made between buildings less than or equal to 60 ft and those greater than 60 ft in height.

Terrain surrounding the facilities should be classified as Exposure B, C, or D, as appropriate. Gust response factors and velocity pressure exposure factors should be used according to rules of the ANSI A58.1-1982 procedures.

Wind pressures are calculated on the walls and roofs of enclosed buildings by appropriate pressure coefficients specified in the ANSI A58.1-1982 standard. Distinctions are made between overall pressures on walls and roofs of enclosed buildings and local pressures at wall corners, eaves, ridges, and roof corners. Local pressures are used for anchorage and cladding design and should not be combined with overall pressures. Openings, either of necessity or created by wind forces or missiles, result in internal pressures that can increase wind forces on components and cladding. The worst cases of combined internal and external pressures should be considered as required by the ANSI standard.

Structures in the General Use category may be designed by either allowable stress design (ASD) or strength design (SD) as appropriate for the material used in construction. Load combinations that produce the most unfavorable effect should be determined. When using ASD methods, the following load combinations should be considered (Reference 16):

- (a) DL (alone)
- (b) DL + LL
- (c) DL + W
- (d) $0.75(DL + W + LL)$

where

DL = dead load

LL = live load

W = wind or tornado load

The reduction of combinations (c) and (d) by 0.75 represents, in effect, a 33% increase in the allowable stress. The provision recognizes that the probability of experiencing the load combinations simultaneously is significantly less than one.

When using SD methods for concrete, the following load factors are recommended in Reference 55:

- (a) $U = 1.4DL + 1.7LL$
- (b) $U = 0.75(1.4DL + 1.7LL + 1.7W)$
- (c) $U = 0.90DL + 1.3W$

The SD method requires that the strength provided be greater than or equal to the strength required to carry the factored loads. Appropriate strength reduction factors shall be applied to the nominal strength calculated in accordance with Reference 55.

Strength design (SD) for steel construction, based on Part 2 of the AISC specification (Reference 45) calls for the following factored load combinations:

$$U = 1.7(DL + LL)$$

$$U = 1.3(DL + LL + W)$$

Application of strength reduction factors in the AISC procedure is not required in Reference 45.

5.2.2 Important or Low Hazard Facilities

Important or Low Hazard facilities are equivalent to essential facilities (Class II), as defined in ANSI A58.1-1982. The structure's main wind-force resisting structural systems shall not collapse at design wind speeds. Complete integrity of the building envelope is not required because no significant quantities of toxic or radioactive materials are present. However, breach of the building envelope may not be acceptable if wind or water interfere with the facility function. If water damage to sensitive equipment, collapsed interior partitions, or excessive damage to HVAC ducts and equipment leads to loss of facility function, then loss of cladding and missile perforation at the design wind speeds must be prevented.

An annual wind speed exceedance probability of 0.02 is specified, but the importance factor for Important or Low Hazard category structures is 1.07. For those sites located within 100 miles of the Gulf of Mexico or Atlantic coastlines, a slightly higher importance factor (as listed in Table 5-5) is used to account for hurricane winds.

Once the design wind speeds are established and the importance factors applied, the determination of wind loads on Important or Low Hazard category structures is identical to that described for General Use category structures. Facilities in this category may be designed by ASD or SD methods, as appropriate, for the construction material. The load combinations described for General Use structures are the same for Important or Low Hazard structures. Greater attention should be paid to connections and anchorages for main members and components, such that the integrity of the structure is maintained.

5.2.3 Moderate Hazard Facilities

The performance goal for Moderate Hazard facilities requires more rigorous criteria than is provided by standards or model building codes. In some geographic regions, tornadoes must be considered.

Extreme Winds and Hurricanes

For those sites where tornadoes are not a viable threat (see Table 5-1), the recommended basic wind speed is based on an annual exceedance probability of 1×10^{-3} . The importance factor is 1.0. For those sites located within 100 miles of the Gulf of Mexico or Atlantic coastlines, a slightly higher importance factor is specified to account for hurricanes (see Table 5-5).

A minimum missile criteria is specified to account for objects or debris that could be picked up by extreme winds, hurricane winds, or weak tornadoes. A 2x4-in. timber plank weighing 15 lbs. is the specified missile. Its impact speed is 50 mph at a maximum height of 30 ft above ground level. The missile will break glass; it will perforate sheet metal siding, wood siding up to 3/4 in. thick, or form board. The missile could pass through a window or a weak exterior wall and cause personal injury or damage to interior contents of a building. The specified missile will not perforate unreinforced concrete masonry or brick veneer walls or other more substantial walls.

Once the basic wind speeds are established and the importance factors applied, determination of Moderate Hazard category wind loads is identical to that described for the General Use category. Facilities in this category may be designed by ASD or SD methods, as appropriate, for the material being used in construction. The load combinations described for General Use structures are the same for the Moderate Hazard category. Greater attention should be paid to connections and anchorages for main members and components, such that the integrity of the structure is maintained.

Tornadoes

For those sites requiring design for tornadoes (see Table 5-1), the criteria is based on site-specific studies as published in Reference 2. The basic wind speed is associated with an annual hazard probability of exceedance of 2×10^{-5} . The wind speed obtained from the tornado hazard model is converted to fastest-mile. The importance factor for the Moderate Hazard category is 1.0.

With the wind speed converted to fastest-mile wind and an importance factor of 1.0, the equations in Table 4 of the ANSI standard should be used to obtain design wind pressures on the structure. Exposure Category C should be used with tornado winds. The velocity pressure factor is obtained, as is the gust response factor, from appropriate tables in the ANSI standard. Pressure coefficients for external, internal, and local pressures are used to obtain tornado wind pressures on various parts of the structure. A distinction is made between the main wind-force resisting system and components and cladding.

In addition to the tornado wind loads, atmospheric pressure change (APC) loads may need to be considered if the building is sealed for the purpose of confining hazardous materials. The maximum APC shall be 40 psf with the rate of pressure change at 20 psf/sec. The following loadings are appropriate for sealed buildings:

1. APC alone
2. One-half maximum APC pressure plus maximum wind pressure.

APC alone could occur on the roof of a buried tank or sand filter if the roof is exposed at ground level. APC pressure is only half its maximum value at the radius of maximum wind speed in a tornado. The effect of rate of pressure change on ventilation systems should be analyzed to assure that it does not interrupt function or processes carried out in the facility. Procedures and computer codes are available for such analyses.

Two missiles are specified as minimum criteria for this facility-use category. The 2x4-in. timber plank weighing 15 lbs. is assumed to travel in a horizontal direction at a speed up to 100 mph. The horizontal speed is effective up to a height of 150 ft above ground level. If carried to a great height by the tornado winds, the timber plank could achieve a terminal vertical speed of 70 mph in falling to the ground. The horizontal and vertical speeds are assumed uncoupled and should not be combined. The missile will perforate most conventional wall and roof cladding except reinforced masonry or concrete. The cells of concrete masonry walls must be filled with grout to prevent perforation by the timber missile. The second missile is a 3-in.-diameter standard steel pipe, which weighs 75 lbs. It can achieve a horizontal impact speed of 50 mph and a vertical speed of 35 mph. Its horizontal speed could be effective to heights of 75 ft above ground level. The missile will perforate conventional metal siding, sandwich panels, wood and metal decking on roofs, and gypsum panels. In addition, it will perforate unreinforced concrete masonry and brick veneer walls, reinforced concrete masonry walls less than 8 in. thick, and reinforced concrete walls less than 6 in. thick.

5.2.4 High Hazard Facilities

The performance goal can be achieved for this category if the main wind-force resisting members do not collapse, structural components do not fail, and the building envelope is not breached at the design wind loads. Loss of cladding, broken windows, collapsed doors, or significant missile perforations shall be prevented. Air flow through the building or water damage cannot be tolerated.

Extreme Winds and Hurricanes

For those sites which do not require specific design for tornado resistance, the recommended basic wind speed is based on an annual hazard exceedance probability of 1×10^{-4} . The importance factor is 1.0 as shown in Table 5-5. The wind speed is fastest-mile at an anemometer height of 10 meters above ground level.

The missile criteria is the same as for the Moderate Hazard category, except that the maximum height achieved by the missile is 50 ft instead of 30 ft.

Tornadoes

For those sites requiring design for tornado resistance (see Table 5-1), the criteria is based on site-specific studies as published in Reference 2. The recommended basic wind speed is associated with an annual hazard probability of exceedance of 2×10^{-5} (same as the Moderate Hazard category). The wind speed obtained from the tornado hazard model is converted to fastest-mile. The importance factor for the High Hazard category is 1.35.

With the wind speed expressed as fastest-mile and an importance factor of 1.35, the equations in Table 4 of ANSI A58.1-1982 should be used to obtain design wind pressures on the structure. Exposure Category C should always be used with tornado winds. The velocity pressure exposure factor is obtained, as is the gust response factor, from appropriate tables in the ANSI standard. Pressure coefficients for external, local, and internal pressures are used to obtain tornado wind pressures on various parts of the structure. A distinction is made between main wind-force resisting system and components and cladding in determining wind pressures.

In addition to the tornado wind loads, APC loads may need to be considered. If the building is sealed to confine hazardous materials, the maximum APC pressure shall be 125

psf with a rate of 50 psf/sec. The wind and APC load combinations specified for the Moderate Hazard facility-use category also are applicable for this category. The effects of rate of pressure change on ventilating systems should be analyzed.

Three missiles are specified as minimum criteria for this facility-use category. The 2x4-in. timber plank weighs 15 lbs. and is assumed to travel in a horizontal direction at speeds up to 150 mph. The horizontal missile is effective to a maximum height of 200 ft above ground level. If carried to a great height by the tornado winds, it could achieve a terminal speed in the vertical direction of 100 mph. The horizontal and vertical speeds are uncoupled and should not be combined. The missile will perforate most conventional wall and roof cladding except reinforced masonry and concrete. Each cell of the concrete masonry shall contain a 1/2-in.-diameter rebar and be grouted to prevent perforation by the missile. The second missile is a 3-in.-diameter standard steel pipe, which weighs 75 lbs. It can achieve a horizontal impact speed of 75 mph and a vertical speed of 50 mph. The horizontal speed could be effective at heights up to 100 ft above ground level. This missile will perforate unreinforced concrete masonry and brick veneer walls, reinforced concrete masonry walls less than 12 in. thick, and reinforced concrete walls less than 8 in. thick. The third missile is a 3000-lb automobile that is assumed to roll and tumble on the ground and achieve an impact speed of 25 mph. Impact of an automobile can cause excessive structural response to columns, walls, and frames. Impact analyses should be performed to determine specific effects. Collapse of columns, walls, or frames may lead to further progressive collapse.

5.2.5 Recommended Design Wind Speeds for Specific DOE Sites

The criteria specified in Table 5-3 for the four facility-use categories should be applied to the site-specific extreme wind/tornado hazard models for each of the 25 DOE sites included in this study. Table 5-4 summarizes the recommended design wind speeds. Appropriate importance factors to be used with the wind speeds are listed in Table 5-5. The wind speeds are fastest-mile. Minimum wind speed values for a particular facility-use category have been imposed. The wind speeds listed in Table 5-4 should be treated as basic design wind speeds in the ANSI A58.1-1982 procedures for determining wind pressures on buildings and other structures.

The following sites require design for extreme winds:

Argonne National Laboratory-West, ID
Hanford Project Site, WA
Idaho National Engineering Laboratory, ID

Lawrence Berkeley Laboratory, CA
Lawrence Livermore National Laboratory, CA
Lawrence Livermore National Laboratory Site 300, CA
Los Alamos National Scientific Laboratory, NM
Nevada Test Site, NV
Pinellas Plant, FL
Sandia National Laboratories, Albuquerque, NM
Sandia National Laboratories, Livermore, CA
Stanford Linear Accelerator Center, CA

The Rocky Flats Plant site presents a unique situation. The presence of downslope winds dominate the extreme wind distribution, suggesting that the design criteria should be based on extreme wind criteria. However, tornadoes are possible and have occurred near the site. Hence, both extreme winds and tornadoes should be considered in arriving at a final design criteria for this site. A specific hazard assessment was performed for the Pinellas Plant, FL, whose wind design is governed by hurricane (see Table 5-1). The importance factor for this site should not be increased above the value for straight winds.

The sites for which tornadoes are the viable wind hazard include:

Argonne National Laboratory - East, IL
Bendix Plant, MO
Brookhaven National Laboratory, NY
Energy Technology and Engineering Center, CA
Feed Metals Production Center, OH
Mound Laboratory, OH
Oak Ridge National Laboratory, TN
Paducah Gaseous Diffusion Plant, KY
Pantex Plant, TX
Portsmouth Gaseous Diffusion Plant, OH
Princeton Plasma Physics Laboratory, NJ
Savannah River Plant, SC

Brookhaven National Laboratory, Long Island, NY, and Princeton Plasma Physics Laboratory, NJ, are located in hurricane-prone zones. See Table 5-5 for values of importance factor for hurricane winds. For Moderate and High Hazard categories, the minimum tornado wind speed criteria apply because they are a worse case than the hurricane criteria.

5.3 CRITERIA FOR EVALUATION OF EXISTING FACILITIES

The performance goals for design presented in the previous section may be used to evaluate existing facilities. The objective of the evaluation process is to determine if an existing facility meets the performance goals for a particular facility-use category.

The key to the evaluation of existing facilities is to identify the potential failure points in a structure. The critical failure mechanism could be failure of the wind-load resisting structural subsystem, or it could be a breach of the building envelope which allows release of toxic materials to the environment or results in wind or water damage to the building contents. The structural subsystem of many old facilities (25 to 40 years old) have considerable reserve strength because of conservatism used in the design approach. However, the facility could still fail to meet performance goals if breach of building envelope is not acceptable.

The weakest link in a structural system usually determines the adequacy or inadequacy of the performance of a structure under wind load. Thus, evaluation of existing facilities normally should focus on the strengths of connections and anchorages in both the wind-force resisting subsystems and in the components and cladding.

Experience from windstorm damage investigations provides the best guidelines for anticipating the potential performance of various structural systems under wind load conditions. Reference 56 provides insights into the performance of various structural systems. A general approach to evaluating existing facilities is presented herein. The steps include:

1. Data Collection.
2. Analysis of system failure.
3. Postulation of failure mechanisms and their consequences.
4. Comparison of postulated performance with performance goals.

5.3.1 Data Collection

An as-built description of the building or facility is needed to make the evaluation for the wind hazard. If not available from construction plans and specifications, then site visits are required. Verification that the facility was built according to plans also is a necessary part of a site visit. Modifications subsequent to preparation of the drawings should be verified.

Material properties are required for the structural analyses. Accurate determination of material properties may be the most challenging part of evaluation of existing facilities. Median values of material properties should be obtained. This will allow an estimate of the degree of conservatism in the analysis if other than the median values are used.

5.3.2 Analysis of Components

In the design of new facilities, several wind-force resisting systems concepts may be considered. Only the one built needs to be considered in evaluating existing facilities.

After determining the as-built condition and the material properties, the wind-resistant subsystem(s) are modeled and analyzed. The type of model employed depends on the material, the loads, and the connections. Modeling of the structural system should include load path identification, stiffness calculations, and support restraint determination. Once the system is modeled, all appropriate loads and load combinations (including dead, live, and wind loads) should be considered in the analyses.

Most of the time it is not feasible to model the three-dimensional load-resisting system. In that case, the system is decomposed into subsystems or individual elements. Wind loads appropriate to the facility-use category are imposed on these structural components and their ability to sustain the loads are evaluated.

Breach of the building envelope may not be tolerable for some facility-use categories. The building envelope is breached by cladding failure or by tornado missile impact.

Cladding failure can occur in the walls or the roof. Wall cladding, as used in the general sense, includes all types of attached material as well as in-fill walls, masonry walls, or precast walls. The strength of anchorages and fasteners should be checked, as well as the strength of the materials. Roof cladding includes material fastened to the roof support system (purlins or joists) such as metal deck, gypsum planks, or timber decking, as well as poured slabs of gypsum or concrete (normal or light weight). Local wind pressures and appropriate internal pressures should be used to evaluate cladding performance.

The tornado missiles in the performance criteria are selected to require certain types of cladding to stop them, based on experimental tests. If existing facilities have exterior walls that are not capable of stopping the missile, then the consequences of the missile perforating exterior walls should be evaluated.

5.3.3 Postulation of Failure Mechanism

After analyzing the structural load-resisting systems under loads appropriate to the facility-use category, it is possible to identify potential failure mechanisms. The failure mechanism can range from subsystem collapse to the failure of an individual element such as a column, beam, or particular connection. The consequences of the postulated failure are evaluated in light of the stated performance goals for the designated facility-use category.

The failure of cladding or individual elements or subsystems can lead to a change in the loading condition or a change in the support restraints of various components of the load-resisting system. A breach in the envelope of a sealed building results in a change in the internal wind pressure of a building. The change in pressure, which can be an increase or a decrease, adds vectorially to external and local pressures, which may lead to additional component failures. The uplift of a building roof leaves the tops of walls unsupported, therefore with a reduced capacity to resist wind loads.

5.3.4 Comparison of Postulated Performance with Performance Goals

Once the postulated failure mechanisms are identified, the structural system performance is compared with the stated performance goals for the specified facility-use category. The general procedures described in Chapter 2 (Figure 2-1) are followed. If the wind load-resisting system is able to resist the design loads without violating performance goals, then the facility meets the criteria. If the guideline criteria are not met, then the assumption and methods of analysis can be modified to eliminate unnecessary conservatism introduced in the evaluation methods. The hazard probability levels can be raised slightly if the facility is close to meeting the criteria (it is acceptable to increase the hazard probability level by a factor of 2, as is done for the earthquake evaluation described in Chapter 4). Otherwise, various means of retrofit can be employed. Several options are listed below, although the list is not meant to be exhaustive.

1. Add x-bracing or shear walls to obtain additional lateral load-resisting capacity.
2. Modify connections in steel, timber, or precast concrete construction to permit them to transfer moment, thus increasing lateral load resistance in structural frames.
3. Brace a relatively weak structure against a more substantial one.
4. Install tension ties in walls that run from roof to foundation to improve roof anchorage.
5. Provide x-bracing in the plane of a roof to improve diaphragm stiffness and thus achieve a better distribution of lateral load to rigid frames, braced frames, or shear walls.

To prevent breach of building envelope or to reduce the consequences of missile perforation, the following general suggestions are presented:

1. Install additional fasteners to improve cladding anchorage.
2. Provide interior barriers around sensitive equipment or rooms containing hazardous materials.
3. Eliminate windows or cover them with missile-proof grills.
4. Place missile-proof barriers in front of doors or windows.
5. Replace ordinary overhead doors with heavy-duty ones that will resist design wind loads and provide missile impact resistance. The tracks must be capable of resisting the postulated loads.

Each building will likely have special situations that need attention. Consultants who evaluate existing facilities should have experience and knowledge of the behavior of buildings and other structures when subjected to wind loads.

**THIS PAGE INTENTIONALLY
LEFT BLANK**

6 FLOOD DESIGN AND EVALUATION GUIDELINES

6.1 FLOOD DESIGN OVERVIEW

The flood design and evaluation guidelines seek to ensure that DOE facilities satisfy the performance goals described in Chapter 2. The guidelines are applicable to new and existing construction; however, in the evaluation of existing facilities, fewer design options may be available to satisfy the performance goals. Table 6-1 shows guidelines recommended for each facility category in terms of the hazard input, hazard annual probability, design requirements, and emergency operation plan requirements.

**TABLE 6-1
FLOOD GUIDELINES SUMMARY**

Flood Design Step	Facility Use Category			
	General Use	Important or Low Hazard	Moderate Hazard	High Hazard
Flood Hazard Input	Flood insurance studies or equivalent input and Table 6-2 combinations	Flood insurance studies or equivalent input and Table 6-2 combinations	Site probabilistic hazard analysis and Table 6-2 combinations	Site probabilistic hazard analysis and Table 6-2 combinations
Hazard Annual Probability	2×10^{-3}	5×10^{-4}	1×10^{-4}	1×10^{-5}
Structural Evaluation (Roofs, etc.)	UBC or applicable criteria for roof and site drainage, building load factors, and design criteria	UBC or applicable criteria for roof and site drainage, building load factors, and design criteria	Flood hazard analysis, strength design	Flood hazard analysis, strength design
Warning and Emergency Procedures	Required to evacuate on-site personnel if site is below DBFL	Required to evacuate on-site personnel and to secure vulnerable areas if site is below DBFL level	Required if buildings are below DBFL	Required if buildings are below DBFL

Evaluation of the flood design for a facility consists of:

1. defining the DBFL,
2. evaluating site conditions (e.g., facility location, location of openings and doorways), and
3. assessing flood design strategies (e.g., build above DBFL levels, harden the site).

Each of these areas is briefly described in the following subsections.

6.1.1 DESIGN BASIS FLOOD (DBFL)

Use of the term DBFL should be understood to mean that multiple flood hazards may be included in the design. For example, a site located along a river may have to consider the potential for river flooding as well as the possible hazards associated with rainfall that could

cause onsite flooding (e.g., roofs, streets). Factors contributing to potential river flooding such as spring snowmelt or upstream dam failure must be considered. The DBFL for each flood type (e.g., river flooding, rainfall, snow) is defined in terms of:

1. peak flood level (e.g., flow rate, volume, elevation, depth of water) corresponding to the mean hazard annual probability of exceedance,
2. combinations of events (e.g., storm surge, wave action); and
3. evaluation of flood loads (e.g., hydrostatic and/or hydrodynamic forces, debris loads).

The first two items are determined as part of the site hazard assessment. Flood loads must be assessed on a facility-by-facility basis.

Table 6-2 defines the design basis events that must be considered. For each hazard, the worst combination of events defines the DBFL. These events apply for all facility categories, subject to the constraint that the probability of exceedance is equal to or greater than the design basis. For example, if the design basis flood probability for General Use facilities is 2×10^{-3} per year, failure of an upstream dam need not be considered if the frequency of failure is less than 2×10^{-3} . For purposes of design, the event combinations in Table 6-2 are assumed to be perfectly correlated. In other words, the combinations of events listed are assumed to occur with certainty if the conditions stated are met.

**TABLE 6-2
DESIGN BASIS FLOOD EVENTS**

Primary Hazard	Event
River Flooding	<ol style="list-style-type: none"> 1. Tide Effects (if applicable) 2. Wind wave activity and Event 1. (above). 3. Coincident upstream dam failure, if for the design basis flood, (1) the reservoir elevation is greater than or equal to an elevation which is 90% of available free-board; or (2) spillway is structurally unable to pass the design basis flood; and Events 1. and 2. above. 4. Ice forces and Event 1. above.
Dam Failure	All modes must be considered (e.g., seismically induced, random structural failures, upstream)
Local Precipitation	Roof drains clogging, and storm sewers blocked
Tsunami	Tide effects.
Storm Surge (due to, e.g., hurricane, seiche)	Tide effects and wind wave activity (if not included in the hazard analysis).
Levee or Dike Failure	Consider failure for events less than the design basis (i.e., failure during a flood, less than the design basis).

6.1.2 EVALUATION OF SITE CONDITIONS

The flood evaluation process is illustrated below:




FIGURE 6-1. FLOOD EVALUATION PROCEDURE

The steps in the flood evaluation process include:

1. Determine the facility category (see Chapter 2).
2. From the results of a site screening analysis or flood hazard study, identify the sources of flooding at the facility.

- 9
2
1
2
3
9
3
1
9
2
7
3. Based on the flood design guidelines in Table 6-1, determine the DBFL for each flood hazard. The design basis flood should include possible combinations of hazards and the assessment of flood loads (e.g., hydrostatic and hydrodynamic loads) or other effects (e.g., scour, erosion).
 4. Determine whether the site or facility is situated above the DBFL flood level. If not, alternative design strategies must be considered such as hardening the facility or developing emergency operation plans.
 5. Evaluate whether roof drainage is adequate to convey design level precipitation to prevent ponding or excessive roof loads. The structural design of the roof system should also be evaluated.
 6. Evaluate the site stormwater management system to determine whether applicable design regulations (i.e., DOE 6430.1A [Reference 9] or local regulations) are satisfied. Site drainage should also be adequate to satisfy the DBFL (e.g., precipitation).
 7. For existing construction, review whether the building and/or the site are hardened by adequate flood protection devices.
 8. If the facility is located below the DBFL level (even if the facility has been hardened), emergency procedures should be provided to evacuate personnel and to secure the facility when the flood arrives.

In principle, buildings that fit into one category or another should be designed for different hazard levels because of the importance assigned to each. However, because floods have a common-cause impact on all buildings at or below the design basis flood level, the design basis for the most critical structure may govern the design for all buildings onsite when it is more feasible to harden a site, rather than an individual building. Exceptions to this case exist when building locations vary (i.e., they are at significantly different elevations or there are large spatial separations), or in the case when individual buildings are hardened to resist the expected flood loads (i.e., addition of watertight doors to a High Hazard facility building).

It is important to consider possible interaction between buildings or building functions as part of the process of evaluating buildings at a site. For example, if a High Hazard facility requires emergency electric power in order to maintain safety levels, buildings which house emergency generators and fuel should be designed to a High Hazard category flood level. In general, a systematic review of a site for possible common-cause dependencies is required. This applies equally for new construction and existing facilities. A straightforward review develops a logic diagram that displays the functional dependencies and system interactions between operations housed in each building.

6.1.3 FLOOD DESIGN STRATEGIES

The basis for the flood evaluation procedure is defined according to a hierarchy of design strategies. They are:

1. Situate facilities above the DBFL level.
2. Harden a site or individual facility to withstand the effects of flood forces such that the performance goals are satisfied.
3. For the DBFL, if adequate warning is available, emergency operation plans can be developed to safely evacuate employees and secure areas with hazardous, mission-dependent, or valuable materials.

If a DOE facility is situated above the DBFL, the performance goals are readily satisfied. An option to satisfy the performance goals is to harden a building or site against the effects of floods such that the chance of damage is acceptably low and to provide emergency operation plans. This dual strategy is secondary to siting facilities above the DBFL level because some probability of damage does exist and facility operations may be interrupted.

Whether or not a facility is situated above the DBFL should be assessed on the basis of the critical flood elevation. The critical elevation represents the flood level at which, if flooding were to occur beyond this depth, the performance level specified as part of the performance goals would be exceeded. Typically, the first floor elevation or a below-grade elevation (i.e., foundation level) is assumed to be the critical elevation. However, based on a review of a facility, it may be determined that only greater flood depths would cause damage (e.g., critical equipment or materials may be housed above the first floor). The critical elevation will depend on the flood hazard (e.g., hydrostatic, hydrodynamic loads), the building structure, and the facility category.

6.2 DOE FLOOD HAZARD ASSESSMENTS

While probabilistic hazard evaluations for seismic and wind phenomena have been performed for all of the DOE sites, comparable evaluations for flood hazards have been performed at only 9 of these sites. Flood screening evaluations have been performed for eight sites in the jurisdiction of the Albuquerque Operations Office (References 60-67). Also, a flood hazard assessment has been performed for the Hanford Project Site (Reference 68). The results of these evaluations have been summarized in Reference 3. An overview of flood considerations is given in Reference 57.

9 2 1 2 3 1 9 0 6 1 3 6 1 2 9

All sites are exposed to the potential effects of flooding. For example, localized flooding due to rainfall can occur in streets, in depressed areas, and on roofs. In addition, flooding can occur on a nearby river, lake, or ocean. The objective of probabilistic hazard evaluations is to assess the probability of extreme events that have a low probability of being exceeded. In the case of floods, facilities at DOE sites may not be exposed to extreme flood hazards. Because of topography, regional climate, or the location of sources of flooding in relation to a site, extreme flooding on-site may be precluded. For existing facilities, design decisions may have resulted in all buildings being sited above possible flood levels. Consequently, in some cases it may be apparent that floods do not pose a substantial hazard to facility operations. For these so called "dry sites" (Reference 58), it may be possible to demonstrate, without performing a detailed hazard assessment, that the flood design guidelines described in this document are satisfied.

The concept of a dry site as used here does not imply that a site is free of all sources of flooding (e.g., all sites are exposed at least to precipitation). Rather, a dry site is interpreted to mean that facilities (new or existing) are located high enough above potential flood sources such that a minimum level of analysis demonstrates that design guidelines are satisfied. For example, for the flooding source of local precipitation, the adequacy of the stormwater management system can be readily demonstrated (e.g., roof drainage, storm sewers, local topography).

To consider flood hazards at DOE sites, a two-phase evaluation process is used. In the first phase, flood screening analyses are performed (Reference 59). These studies provide an initial evaluation of the potential for flooding at a site. As part of the screening analysis, available hydrologic data and results of previous studies are gathered, and a preliminary assessment of the probability of extreme floods is performed. Results of the screening analysis can be used to assess whether flood hazards can occur at a site. In some cases, these studies may demonstrate that flood hazards are extremely rare and, therefore, performance goals are satisfied. For those sites with high potential for flooding and which have Moderate Hazard and High Hazard facilities, the second phase will be undertaken. This consists of detailed probabilistic flood hazard assessment.

A number of methods have been developed to assess the probability of extreme floods. These include:

1. extrapolation of frequency distributions,
2. joint probability techniques,
3. regional analysis methods,

4. paleohydrologic evaluation of floods, and
5. Bayesian techniques.

References 81-84 provide background on these methods. There is no general agreement in the literature regarding the appropriateness of these methods to estimate the probability of extreme floods. Each approach has its advantages and disadvantages and thus no single technique is well-established.

In estimating the probability of extreme floods it is important that uncertainty analysis be performed. The uncertainty analysis should consider statistical uncertainty due to limited data and the uncertainty in the flood evaluation models used (e.g., choice of different statistical models, uncertainty in flood routing). Discussions of uncertainty assessments can be found in References 59, 68, 78-80.

6.3 FLOOD DESIGN GUIDELINES FOR EACH FACILITY-USE CATEGORY

Unlike design strategies for seismic and wind hazards, it is not always possible to provide margin in the flood design of a facility. For example, the simple fact that a site is inundated (forgetting for a moment the possible structural damage that might occur), may cause significant disruption (clean-up) and downtime at a facility; this may prove an unacceptable risk in terms of economic impact and disruption of the mission-dependent function of the site. In this case, there is no margin, as used in the structural sense, that can be provided in the facility design. Therefore, the facility must be kept dry and operations must be unimpeded. As a result, the annual probability of the DBFL corresponds to the performance goal probability of damage, since any exceedance of the DBFL results in consequences that exceed the performance goal.

The DBFL for General Use and Important or Low Hazard facilities can generally be estimated from available flood hazard assessment studies. These include: the results of flood screening studies, flood insurance analyses, or other comparable evaluations. For these facility types, it is not necessary that a full-scope hazard evaluation be performed, if the results of other recent studies are available and, if uncertainty in the hazard estimate is accounted for.

For Moderate and High hazard facilities, a comprehensive flood hazard assessment should be performed, unless the results of the screening analysis (see Reference 59) demonstrate that the performance goals are satisfied.

6.3.1 General Use Facilities

The performance goal for General Use facilities specifies that occupant safety be maintained and that the probability of severe structural damage be less than or about a 10^{-3} per year. For General Use facilities, the DBFL corresponds to the hazard level whose mean annual probability of exceedance is 2×10^{-3} . In addition, event combinations that must be considered are listed in Table 6-2.

To meet the performance goal for this category, two requirements must be met: (1) the facility structural system must be capable of withstanding the forces associated with the DBFL and (2) adequate flood warning time must be available to ensure that building occupants can be evacuated (1 to 2 hours, Reference 71). If the facility is located above the DBFL, then structural and occupant safety requirements are met.

For structural loads applied to roofs, exterior walls, etc., applicable building code requirements (e.g., DOE 6430.1A, Uniform Building Code (UBC) References 9, 10) provide standards for design that meet the performance goal for General Use facilities.

For existing construction, or at new sites where the facility cannot be above the DBFL level, an acceptable design can be achieved by:

1. Providing flood protection for the site or for specific General Use facilities, such that severe structural damage does not occur, and
2. Developing emergency procedures in order to secure facility contents above the design flood elevations in order to limit damage to the building to within acceptable levels and to provide adequate warning to building occupants.

6.3.2 Important or Low Hazard Facilities

The performance goal for Important or Low Hazard facilities is to limit damage and interruption of facility operations while also maintaining occupant safety. For these facilities, the DBFL is equal to the flood whose probability of exceedance is 5×10^{-4} per year plus the event combinations listed in Table 6-2. The results of flood insurance studies (Reference 69) routinely report the flood level corresponding to the 2×10^{-3} probability level. For purposes of establishing the DBFL for Important or Low Hazard facilities, the results of these studies can be extrapolated to obtain the flood with a probability of 5.0×10^{-4} of being exceeded (if this result is not reported). A range of extrapolations should be considered, with a weighted average being used as the design basis.

For new construction, facilities in this category should be located above the DBFL. For existing construction, or at new sites where the above siting criteria cannot be met, an acceptable design can be achieved by the same measures described for General Use facilities. For Important or Low Hazard facilities whose critical elevation is below the DBFL, emergency procedures must be developed to mitigate the damage to mission-dependent components and systems. These procedures may include installation of temporary flood barriers, removal of equipment to protected areas, anchoring vulnerable items, or installing sumps or emergency pumps.

As in the case of General Use facilities, UBC design standards or local ordinances should be used to determine design requirements and site drainage. Site drainage should be adequate for roofs and walls to prevent flooding that would interrupt facility operations.

6.3.3 Moderate Hazard Facilities

The performance goal for Moderate Hazard facilities is continued function of the facility, including confinement of hazardous materials and occupant safety. Facilities in this category should be located above flood levels whose annual probability of exceedance is 10^{-4} , including the combinations of events shown in Table 6-2.

Emergency operation procedures must be developed to secure hazardous materials, prepare Moderate Hazard facilities for possible extreme flooding and loss of power, and for an extended stay on-site. Emergency procedures should be coordinated with the results of the flood hazard analysis, which provides input on the time variation of flooding, type of hazards to be expected, and their duration. The use of emergency operation plans is not an alternative to hardening a facility to provide adequate confinement unless all hazardous materials can be completely removed from the site.

Roofs should be designed in accordance with UBC standards in order to drain rainfall whose probability of exceedance is 10^{-4} . The amount of ponding that can occur on building roofs should be controlled by adding scuppers (openings in parapet walls) and/or limiting parapet wall heights. If ponding on-site is expected to occur, drainage should be provided to convey the stormwater away from the facility. Alternatively, doors and openings should be made watertight.

6.3.4 High Hazard Facilities

The performance goals for High Hazard facilities are basically the same as for Moderate Hazard facilities. However, a higher confidence is required that the performance goals are

met. Facilities in this category should be located above flood levels whose annual probability of exceedance is 10^{-5} , including combinations of events listed in Table 6-2. Required emergency operation procedures are the same as those for Moderate Hazard facilities. Roofs should be designed in accordance with UBC standards in order to drain the rainfall whose probability of exceedance is 10^{-5} . The control of ponding is the same as that recommended for Moderate Hazard facilities.

6.4 FLOOD DESIGN PRACTICE FOR FACILITIES BELOW THE DBFL ELEVATION

For structures located below the design basis flood level, mitigation measures other than siting at a higher elevation can provide an acceptable margin of safety. In general, structural measures are considered next, followed by non-structural actions (i.e., flood warning and emergency operations plans). In practice, for sites located below the design basis flood level, a combination of structural and non-structural measures are used. Guidelines for structural flood mitigation measures are described in this section.

6.4.1 Flood Loads

To evaluate the effects of flood hazards, corresponding forces on structures must be evaluated. Force evaluations must consider hydrostatic and hydrodynamic effects, including the impact associated with wave action. In addition, the potential for erosion and scour and debris loads must be considered. Good engineering practice should be used to evaluate flood loads (References 70, 72-76). The forces due to ice formation on bodies of water should be considered in accordance with DOE 6430.1A (Reference 9).

Building roof design should provide adequate drainage as specified by DOE 6430.1A (Reference 9) and in accordance with local plumbing regulations. Secondary drainage (overflow) should be provided at a higher level and have a capacity at least that of the primary drain. Limitations of water depth on a roof specified by DOE 6430.1A or applicable local regulations apply. The roof should be designed to consider the maximum depth of water that could accumulate if the primary drainage system is blocked (Reference 10, 16).

6.4.2 Design Requirements

Design criteria (i.e., for allowable stress or strength design, load factors, and load combinations) for loads on exterior walls or roofs due to rain, snow, and ice accumulation should follow applicable code standards for the materials being used (References 45, 55).

6.4.2.1 General Use and Important or Low Hazard Facilities

Facilities that are subject to flood loads should be designed according to provisions of UBC or local ordinances and specified flood load combinations (e.g., ponding, hydrostatic).

6.4.2.2 Moderate and High Hazard Facilities

Buildings and related structures that are directly impacted by flood hazards should be constructed of reinforced concrete and designed according to strength methods as required by ACI 349-85 (Reference 44). Load factors and combinations specified in Reference 69 should be used.

6.4.3 Design of Other Civil Engineering Facilities

In addition to the design of buildings to withstand the effects of flood hazards, other civil works must be designed for flood conditions. These include components of the stormwater management system such as street drainage, storm sewers, stormwater conveyance systems such as open channels, and roof drainage. Applicable procedures and design criteria specified in DOE 6430.1A (Reference 9) and/or local regulations should be used in the design of stormwater systems. However, the design of individual facilities to resist the effects of local, onsite flooding (e.g., local ponding, street flooding) should be evaluated to ensure that the performance goals are satisfied.

6.4.4 Flood Protection Structures

Facilities can be hardened to withstand the effects (e.g., loads, erosion, scour) of flood hazards. Typical hardening systems are:

1. structural barriers (e.g., building, watertight doors),
2. waterproofing (e.g., waterproofing exterior walls, watertight doors),
3. levees, dikes, seawalls, revetments, and
4. diversion dams and retention basins.

Applicable design guides for levees, dikes, small dams, etc. can be found in U.S. Army Corps of Engineers, U.S. Bureau of Reclamation, Soil Conservation Service reference documents (References 70, 71, 72, 76, 77). Design of structural systems such as exterior walls, roof systems, doors, etc. should be designed according to applicable criteria for the facility category considered (see Section 6.4.2).

6.5 FLOOD RISK ASSESSMENT

In some cases the need may arise for DOE or the DOE site manager to perform a quantitative flood risk assessment. There may be a variety of reasons requiring a comprehensive risk evaluation of a site. These considerations include:

1. Demonstration that the performance goals are satisfied.
2. Evaluation of alternative design strategies to meet the performance goals.
3. Detailed consideration of conditions at a site that may be complex, such as varying hydraulic loads (e.g., scour, high velocity flows), system interactions, secondary failures, or a potential for extraordinary health consequences.
4. A building is not reasonably incorporated in the four facility categories.

A quantitative evaluation of the risk due to flooding can be assessed by performing a probabilistic safety analysis (PSA). The objective of a flood PSA is to evaluate the risk of damage to systems important for maintaining safety and operating a critical facility. Risk calculations can be performed to evaluate the likelihood of damage to onsite systems and of public health consequence. Procedures to perform PSAs are discussed in References 78-80, 85.

APPENDIX A

COMMENTARY ON SEISMIC DESIGN AND ANALYSIS GUIDELINES

The overall approach employed for the seismic design and evaluation guidelines is discussed in Section A.1. The basis for selection of recommended hazard exceedance probabilities is described in Section A.2. Earthquake ground motion response spectra are discussed in Section A.3. The basic attributes of equivalent static force methods and dynamic analysis methods are described in Sections A.4 and A.5. Note that energy dissipation from damping or inelastic behavior is implicitly accounted for by the code formulas in equivalent static force methods. The means of accounting for energy absorption capacity of structures in dynamic analyses are discussed in Section A.6. The basis for the specific seismic design and evaluation guidelines including the inelastic demand-capacity ratios recommended for usage in the design and evaluation of Moderate and High Hazard facilities is described in Section A.7.

A.1 Basic Approach for Earthquake Design and Evaluation at Appropriate Lateral Force Levels

The performance of a DOE facility subjected to a natural phenomena hazard (earthquake, wind, or flood) depends not only on the level of hazard selected for design or evaluation, but also on the degree of conservatism used in the design or evaluation process. For instance, if one wishes to achieve less than about 10^{-4} annual probability of onset of loss of function, this goal can be achieved by using conservative design or evaluation approaches for a natural phenomena hazard which has a more frequent annual probability of exceedance (such as 10^{-3}), or it can be achieved by using median centered design or evaluation approaches (i.e., not having any intentional conservative or unconservative bias) coupled with a 10^{-4} hazard definition. At least for the earthquake hazard, the former alternate has been the most traditional. Conservative design or evaluation approaches are well established, extensively documented, and commonly practiced. Median design or evaluation approaches are currently controversial, not well understood, and seldom practiced. Conservative design and evaluation approaches are utilized for both conventional facilities (similar to DOE category - General Use Facilities) and for nuclear power plants (equal to or more severe than DOE category - High Hazard Facilities). For consistency with these other uses, the approach in this report recommends using conservative design and evaluation procedures coupled with a hazard definition consistent with these procedures.

The performance goals for General Use and Important or Low Hazard facilities are consistent with goals of conventional building codes for normal and important or essential facilities, respectively. For seismic design and evaluation of facilities, conventional building codes utilize equivalent static force methods except for very unusual or irregular facilities, for which a dynamic analysis method is employed. The performance goals for Moderate and High Hazard Facilities approach those used for nuclear power plants for which seismic design and evaluation is accomplished by means of dynamic analysis methods. For these reasons, the guidelines presented in this report recommend that lesser hazard facilities be evaluated by methods corresponding closely to conventional building codes and higher hazard facilities be evaluated by dynamic analyses.

The performance goals presented in Chapter 2 and the recommended hazard exceedance probabilities presented in Sections 4.2.2 and 4.2.3, are tabulated below for each facility-use category.

Facility Category	Performance Goal	Hazard Exceedance Probability	Ratio of Hazard to Performance Probability
General Use	1×10^{-3}	2×10^{-3}	2
Important or Low Hazard	5×10^{-4}	1×10^{-3}	2
Moderate Hazard	1×10^{-4}	1×10^{-3}	10
High Hazard	1×10^{-5}	2×10^{-4}	20

As shown in the above table, the hazard exceedance probabilities and performance goal exceedance probabilities recommended herein are different. These differences indicate that conservatism must be introduced in the seismic behavior evaluation approach. In earthquake evaluation, there are many places where conservatism can be introduced, including:

1. Maximum design/evaluation ground acceleration.
2. Response spectra amplification.
3. Damping.
4. Analysis methods.
5. Specification of material strengths.
6. Estimation of structural capacity.
7. Load factors.
8. Importance factors.
9. Limits on inelastic behavior.

10. Soil-structure interaction.
11. Effective peak ground motion.
12. Effects of a large foundation or foundation embedment.

For the earthquake evaluation guidelines presented in this chapter, conservatism is intentionally introduced and controlled by specifying (1) hazard exceedance probabilities, (2) load factors, (3) importance factors, (4) limits on inelastic behavior, and (5) conservatively specified material strengths and structural capacities. Load and importance factors have been retained for the evaluation of General Use and Important or Low Hazard facilities because the 1988 UBC approach which includes these factors is followed for these categories. These factors are not used in general dynamic analyses of facilities or in Reference 11, and thus they were not used for the evaluation of Moderate and High Hazard facilities by dynamic analysis. Material strengths and structural capacities specified herein correspond to ultimate strength code-type provisions (i.e., ACI 318-83 for reinforced concrete, UBC Sec. 2721 for steel). It is recognized that such provisions introduce conservatism. In addition, it is acceptable by these guidelines to use peak ground accelerations from Reference 1 as the input earthquake excitation at the foundation level of facilities. As discussed in Sections 4.4.1 and 4.4.2, significant additional conservatism can be introduced if considerations of effective peak ground motion, soil-structure interaction, and effects of large foundation or foundation embedment are ignored.

The seismic design and evaluation guidelines presented in Section 4.2, are consistent from category to category, with the 1988 UBC provisions (Reference 10) for General Use facilities being the baseline for the guidelines for all categories. The differences in seismic evaluation guidelines among categories in terms of load and importance factors, limits on inelastic behavior, and other factors as described in Section 4.2, and illustrated in Table 4-1, are summarized below:

1.	General Use and Important or Low Hazard	Only hazard exceedance probability and importance factor differ. All other factors are held the same.
2.	Important or Low Hazard and Moderate Hazard	Load factors, importance factors, damping, and limits on inelastic behavior differ. All other factors are essentially the same, although static force evaluation methods are used for Important or Low Hazard facilities and dynamic analysis is used for Moderate Hazard facilities.
3.	Moderate and High Hazard	Hazard exceedance probability and limits on inelastic behavior differ. All other factors are held the same.

The different load factors, importance factors, limits on inelastic behavior, and damping making up the seismic design and analysis guidelines for each facility-use category result in facilities in each category having a different demand (i.e., the value, D , computed as shown in Sections 4.2.2 and 4.2.3, which is compared to ultimate capacity to assess facility adequacy).

Larger demand (i.e., required capacity) values result for more hazardous categories, which is indicative of the greater conservatism and reduced probability of damage or loss of capability to function associated with the higher hazard categories.

A.2 Earthquake Hazard Annual Exceedance Probabilities

Historically, non-Federal Government General Use and Essential or Low Hazard facilities located in California, Nevada, and Washington have been designed for the seismic hazard defined in the Uniform Building Code. Other regions of the U.S. have generally used either some version of the UBC seismic hazard definition or else have ignored seismic design. Past UBC seismic provisions (1985 and earlier) are based upon the largest earthquake intensity which has occurred in a given region during the past couple of hundred years. These provisions do not consider the probability of occurrence of such an earthquake and thus do not make any explicit use of a probabilistic seismic hazard analysis. However, within the last ten years there has been considerable interest in developing a national seismic design code. Proponents have suggested that a seismic design code would be more widely accepted if the seismic hazard provisions of this code were based upon a consistent uniform annual probability of exceedance for all regions of the U.S. Several probabilistic-based seismic hazard provisions have been proposed (References 11,47,48). A probabilistic based seismic zone map was recently incorporated into the 1988 Uniform Building Code (Reference 10). Canada has adopted this approach (Reference 15). The suggested annual frequency of exceedance for the design seismic hazard level differs somewhat between proposed codes, but all lie in the range of 10^{-2} to 10^{-3} . For instance, ATC-3 (Reference 47) has suggested the design seismic hazard level should have about a 10 percent frequency of exceedance level in 50 years which corresponds to an annual exceedance frequency of about 2×10^{-3} . The Canadian building code used 1×10^{-2} as the annual exceedance level for their design seismic hazard definition. The Department of Defense (DOD) tri-services seismic design provisions for essential buildings (Reference 11) suggests a dual level for the design seismic hazard. Facilities should remain essentially elastic for seismic hazard with about a 50 percent frequency of exceedance in 50 years or about a 1×10^{-2} annual exceedance frequency, and they should not fail for a seismic hazard which has about a 10 percent frequency of exceedance in 100 years or about 1×10^{-3} annual exceedance frequency.

On the other hand, nuclear power plants are designed so that safety systems do not fail if subjected to a safe shutdown earthquake (SSE). The SSE generally represents the expected ground motion at the site either from the largest historic earthquake within the tectonic province within which the site is located or from an assessment of the maximum earthquake potential

of the appropriate tectonic structure or capable fault closest to the site. The key point is that this is a deterministic definition of the design SSE. Recent probabilistic hazard studies (e.g., Reference 49) have indicated that for nuclear plants in the eastern U.S., the design SSE level generally corresponds to an estimated mean annual frequency of exceedance of between 10^{-3} and 10^{-4} . Also, during the last ten years, considerable interest has developed in attempting to estimate the seismic risk of these nuclear power plants in terms of annual probability of seismic-induced core melt or risk of early fatalities and latent cancer to the public. Many studies have been conducted on seismic risk of individual nuclear power plants. Because those plants are very conservatively designed to withstand the SSE, these studies have indicated that the seismic risk is acceptably low (generally less than about 10^{-5} annual probability of seismic induced core damage) when such plants are designed for SSE levels with a mean annual frequency of exceedance between 10^{-3} and 10^{-4} (References 17, 18, 19, and 20).

With this comparative basis for other facilities, it is judged to be consistent and appropriate to define the seismic hazard for DOE facilities as follows:

Category	Earthquake Hazard Annual Exceedance Probability
General Use	2×10^{-3}
Important or Low Hazard	1×10^{-3}
Moderate Hazard	1×10^{-3}
High Hazard	2×10^{-4}

These hazard definitions are appropriate so long as the seismic design or evaluation of the facility is conservatively performed for these hazards. The level of conservatism of the evaluation for these hazards should increase as one goes from General Use to High Hazard facilities. The conservatism associated with General Use and Important or Low Hazard categories should be consistent with that contained in the UBC (Reference 10) or ATC-3 (Reference 47) for normal or essential facilities, respectively. The level of conservatism in the seismic evaluation for High Hazard facilities should approach that used for nuclear power plants when the seismic hazard is designated as above. The criteria contained in this report follow the philosophy of a gradual reduction in the annual exceedance probability of the hazard coupled with a gradual increase in the conservatism of the evaluation procedure as one goes from a General Use to a High Hazard facility.

A.3 Earthquake Ground Motion Response Spectra

Design/evaluation earthquake response spectra generally have the shape shown in Figure 4-1. The design/evaluation spectrum shape is similar to that for an actual earthquake except that peaks and valleys which occur with actual earthquake spectra are smoothed out. Also, design/evaluation spectra typically include motions from several potential earthquakes such that they are broader in frequency content than spectra computed for actual earthquake ground motion. Such simplified spectral shapes are necessary in order to provide a practical input for seismic analyses. Because design/evaluation spectra are smoothed and broadened relative to actual earthquake spectra, a design/evaluation spectrum tends to be a conservative representation of actual earthquake amplification that might occur at a facility site.

Spectral amplification depends strongly on site conditions. For this reason, it would generally be expected that response spectra to be used for the design or evaluation of hazardous DOE facilities would be evaluated from site-specific geotechnical studies. There is a very good discussion on the development of response spectra from site-specific studies and other approaches in Reference 11. Alternatively, response spectra for DOE sites are available for use from Reference 1. Reference 1 spectra were developed from general site conditions and not from a site-specific geotechnical study. Additional approaches available for estimating response spectra from general site conditions are described in References 25, 26, and 27. Any of these methods is acceptable for estimating input design/evaluation response spectra. Note that to meet the performance goals in Chapter 2 using the guidelines presented in Sections 4.2.2 and 4.2.3, median amplification response spectra should be used. Mean amplification spectra are a conservative approximation of median spectra.

The C factor in the 1988 UBC base shear equation (e.g., Equation 4-1) is approximately equivalent to spectral amplification for 5 percent damping, and the Z factor corresponds to the maximum ground acceleration such that ZC corresponds to a 5 percent damping earthquake response spectrum. For General Use and Important or Low Hazard facilities, earthquake loading is evaluated from Equation 4-1 in accordance with UBC seismic provisions with the exception that the ZC is determined from input design/evaluation response spectra as described in Section 4.2.2. ZC as given by 1988 UBC provisions is plotted as a function of natural period on Figure A-1. Also, Figure A-1 includes a typical design/evaluation spectra.




FIGURE A-1
COMPARISON OF 1988 UBC ZC WITH TYPICAL
DESIGN/EVALUATION RESPONSE SPECTRUM

It is shown in Figure A-1 that an actual design evaluation spectrum differs significantly from the code coefficients, ZC, only in the low natural period region (i.e., less than about 0.125 seconds). As a result, an adjustment must be made in the low period region in order to not be unconservative when the design/evaluation spectra are used along with other provisions of the code. The required adjustment to the design/evaluation spectra is to require that for fundamental periods lower than the period at which the maximum spectral acceleration occurs, ZC should be taken as the maximum spectral acceleration. This provision has the effect of making the design/evaluation spectra as shown in Figure 4-1, have a shape similar to that for ZC per the code provisions as shown in Figure A-1. In this manner, the recommended seismic evaluation approach for General Use and Important or Low Hazard facilities closely follows the 1988 UBC provisions while utilizing seismic hazard data from site dependent studies.

In the design and evaluation guidelines presented in Section 4.2.3, for Moderate and High Hazard facilities, design/evaluation spectra as shown in Figure 4-1, are used for dynamic seismic analysis. However, in accordance with Reference 11, for fundamental periods lower than the period at which the maximum spectral acceleration occurs, spectral acceleration should be taken as the maximum spectral acceleration. For higher modes, the actual spectrum at all natural periods should be used in accordance with recommendations from Reference 11.

period, a factor of conservatism based on the importance of the facility, and a reduction factor which accounts for energy absorption capacity. Very simple formulas estimate fundamental period by relating period to structure dimensions with coefficients for different materials or by a slightly more complex formula based on Rayleigh's method. This code defines the distribution of lateral forces of various floor levels. In addition, a top force is introduced to accommodate the higher modes by increasing the upper story shears where higher modes have the greatest effect. The overturning moment is calculated as the static effect of the forces acting at each floor level. Story shears are distributed to the various resisting elements in proportion to their rigidities, considering diaphragm rigidity. Increased shears due to actual and accidental torsion must be accounted for.

Seismic forces in members determined from the above approach and combined with forces due to other loadings are multiplied by a load factor and compared to code ultimate strength levels in order to evaluate whether or not the design is adequate for earthquake loads. In addition, deflections are computed from the lateral forces and compared to story drift limitations to provide for control of potential damage and overall structural frame stability from P-delta effects.

A.5 Dynamic Seismic Analysis

As mentioned previously, complex irregular structures cannot be evaluated by the equivalent static force method because the formulas for seismic forces throughout the structure would not be applicable. For such structures, more rigorous dynamic analysis approaches are required. In addition, for very important or highly hazardous facilities, such as the Moderate or High Hazard categories, it is recommended that the equivalent static force method not be used except for very simple structures. Dynamic analysis approaches lead to a greater understanding of seismic structural behavior. These approaches should generally be utilized for high hazard facilities.

An analysis is considered dynamic if it recognizes that both loading and response are time-dependent and if it employs a suitable method capable of simulating and monitoring such time-dependent behavior. In this type of analysis, the dynamic characteristics of the structure are represented by a mathematical model. Input earthquake motion can be represented as a response spectrum or an acceleration time history.

The mathematical model describes the stiffness and mass characteristics of the structure as well as the support conditions. This model is described by designating nodal points which correspond to the structure geometry. Mass in the vicinity of each nodal point is typically

lumped at the nodal point location in a manner that all of the mass of the structure and its contents are accounted for. The nodal points are connected by elements which have properties corresponding to the stiffness of the structure between nodal point locations. Nodal points are free to move (called degrees of freedom) or are constrained from movement at support locations. Equations of motion equal to the total number of degrees of freedom can be developed from the mathematical model. Response to any dynamic forcing function such as earthquake ground motion can be evaluated by direct integration of these equations. However, dynamic analyses are more commonly performed by considering the modal properties of the structure.

For each degree of freedom of the structure, there are natural modes of vibration, each of which responds at a particular natural period in a particular pattern of deformation (mode shape). There are many methods available for computing natural periods and associated mode shapes of vibration. Utilizing these modal properties, the equations of motion can be written as a number of single degree-of-freedom equations by which modal responses to dynamic forcing functions such as earthquake motion can be evaluated independently. Total response can then be determined by superposition of modal responses. The advantage of this approach is that much less computational effort is required for modal superposition analyses than direct integration analyses since fewer equations of motion require solution. Many of the vibration modes do not result in significant response and thus can be ignored. The significance of modes may be evaluated from modal properties before response analyses are performed.

The direct integration or modal superposition methods calculate response by considering the motions applied and the responses computed using a time-step by time-step numerical dynamic analysis. When the input earthquake excitation is given in terms of response spectra (as is the case for the motions provided for design and evaluation of DOE facilities in Reference 1) the maximum structural response may be most readily estimated by the response spectrum evaluation approach. The complete response history is seldom needed for design of structures; maximum response values usually suffice. Because the response in each vibration mode can be modeled by single degree-of-freedom equations, and response spectra provide the response of single degree-of-freedom systems to the input excitation, maximum modal response can be directly computed. Procedures are then available to estimate the total response from the modal maxima which do not necessarily occur simultaneously.

A.6 Analytical Treatment of Energy Dissipation and Absorption

Earthquake ground shaking is a limited energy transient loading, and structures have energy dissipation and absorption capacity through damping and through hysteretic behavior during inelastic response. This section discusses simplified methods of accounting for these modes of energy dissipation and absorption in seismic response analyses.

Damping - Damping accounts for energy dissipation in the linear range of response of structures and equipment to dynamic loading. Damping is a term which is utilized to account for various mechanisms of energy dissipation during seismic response such as cracking of concrete, slippage at bolted connections, and slippage between structural and nonstructural elements. Damping is primarily affected by:


1. Type of construction and materials used.
2. The amount of nonstructural elements attached.
3. The earthquake response strain levels.

Damping increases with rising strain level as there are increased concrete cracking and internal work done within materials. Damping is also larger with greater amounts of nonstructural elements (interior partitions, etc.) in a structure which provide more opportunities for energy losses due to friction. For convenience in seismic response analyses, the damping is generally assumed to be viscous in nature (velocity dependent) and is so approximated. Damping is usually considered as a proportion or percentage of the critical damping value, which is defined as that damping in a system which would prevent oscillation for an initial disturbance not continuing through the motion.


Table 4-4 reports typical structural damping values for various materials and construction (Reference 11). These values correspond to strains beyond yielding of the material and are recommended for usage along with other provisions of this document for design or evaluation seismic response analyses of Moderate and High Hazard facilities. Post-yielding damping values are judged to be appropriate because facilities designed by these guidelines are intended to reach strains beyond yield level if subjected to the design/evaluation level earthquake ground motion, and such damping levels are consistent with other seismic analysis provisions based on Reference 11. For General Use and Important or Low Hazard facilities, the guidelines recommend seismic evaluation by code type equivalent static force methods but with the factors for maximum ground acceleration and spectral amplification in the total base shear formula taken from Reference 1. In this case, it is recommended that the 5 percent

damped spectra be used for all General Use and Important or Low Hazard facilities to be consistent with building code evaluation methods. The spectral amplification factor in conventional building codes is based upon 5 percent damped spectral amplification.

Inelastic Behavior - Energy absorption in the inelastic range of response of structures and equipment to earthquake motions can be very significant. Figure A-2 shows that large hysteretic energy absorption can occur for even structural systems with relatively low ductility such as concrete shear walls or steel braced frames.



a. Shear force-distortion for concrete wall test (Ref.51)



b. Lateral force-displacement for steel braced frame (Ref.52)

FIGURE A-2 CYCLIC LOAD-DEFLECTION BEHAVIOR OF CONCRETE SHEAR WALLS AND STEEL BRACED FRAMES

Generally, an accurate determination of inelastic behavior necessitates dynamic nonlinear analyses performed on a time history basis. However, there are simplified methods to approximate nonlinear structural response based on elastic response spectrum analyses through the use of either spectral reduction factors or inelastic demand-capacity ratios. Spectral reduction factors and inelastic demand-capacity ratios permit structural response to exceed yield stress levels a limited amount as a means to account for energy absorption in the inelastic range. Based on observations during past earthquakes and considerable dynamic test data, it is known that structures can undergo limited inelastic deformations without unacceptable damage when subjected to transient earthquake ground motion. Simple linear analytical methods approximating inelastic behavior using spectral reduction factors and inelastic demand-capacity ratios are briefly described below.

1. *Spectral reduction factors* - Structural response is determined from a response spectrum dynamic analysis. The spectral reduction factors are used to deamplify the elastic response spectrum producing an inelastic response spectrum which is used in the analysis. The resulting member forces are compared to yield level stresses to determine structural adequacy.
2. *Inelastic demand-capacity ratios* - Structural response is determined from either response spectra or time history dynamic analyses with the input excitation consistent with the elastic response spectra. The resulting member forces are the demand on the structure which is compared to the capacity determined from member forces at yield stress level. If the permissible demand-capacity ratios are not exceeded, it would be concluded that the structure was adequate for earthquake loading.

The spectral reduction factors and inelastic demand-capacity ratios are evaluated based upon the permissible inelastic behavior level, which depends on the materials and type of construction. For ductile steel moment frames, relatively large reduction factors or demand-capacity ratios are used. For less ductile shear walls or braced frames, lower reduction values or demand-capacity ratios are employed. For more hazardous facilities, lower reduction factors or demand-capacity ratios may be used to add conservatism to the design or evaluation process, such that increased probability of surviving any given earthquake motion may be achieved. The inelastic demand-capacity ratio approach is employed for design or evaluation of higher hazard DOE facilities by these guidelines. This approach is recommended in the DOD manual for seismic design of essential buildings (Reference 11). Inelastic demand-capacity ratios are called F_u in this document. Base shear reduction coefficients which account for energy absorption due to inelastic behavior and other factors are called R_w by the 1988 UBC provisions.

Reduction coefficients, R_W , to be used for evaluation of General Use and Important or Low Hazard facilities and recommended inelastic demand-capacity ratios, F_U , for Moderate and High Hazard facilities are presented in Table 4-2 for various structural systems. R_W factors given in the table are taken directly from Reference 10. The F_U factors presented in Table 4-2 were established to approximately meet the performance goals for structural behavior of the facility as defined in Chapter 2 and as discussed in Section A.1. These factors are based both on values given in Reference 11 and on values calculated from code reduction coefficients in a manner that the demand or required capacity which meets the performance goal is obtained. The following section describes the detailed method of establishing the values of F_U .

The code reduction coefficients, R_W , by the 1988 UBC approach and inelastic demand-capacity ratios, F_U , by the DOD approach differ in the procedures that define permissible inelastic response under extreme earthquake loading. By the 1988 UBC approach, only the element forces due to earthquake loads are reduced by the reduction coefficient, R_W , in evaluating demand; while by the DOD approach, element forces due to both earthquake and dead and live loads are reduced by the inelastic demand-capacity ratio, F_U , in evaluating demand. The effect of this difference is that the DOD approach may be less conservative for beam or brace members heavily loaded by dead and live loads.

In addition, the approach for permitting inelastic behavior in columns subjected to both axial forces and bending moments differs between the 1988 UBC and DOD provisions. By the 1988 UBC approach, seismic axial forces and moments are both reduced by R_W , and then combined with forces and moments due to dead and live loads, along with an appropriate load factor. The resultant forces and moments are then checked in code type interaction formulas to assess the adequacy of the column. By the DOD approach, column interaction formulas have been rewritten to incorporate the inelastic demand-capacity ratio (as shown in Figures 4-2 and 4-3 of Reference 11): By the DOD interaction formulas, the inelastic demand-capacity ratio is applied only to the bending moment, and axial forces are unaffected. In addition, the inelastic demand-capacity ratios are low compared to ratios for other types of members such as beams, as discussed in the next section, A.7. The DOD approach for columns is followed by these guidelines. The result of these differences is that the DOD provisions for columns are conservative relative to the 1988 UBC provisions such that there is less probability of damage to columns in Moderate and High Hazard facilities than in the Chapter 2 performance goals.

Several other factors may be noted about the inelastic demand-capacity ratios, F_U :

1. Table 4-2 values assume that good seismic design detailing practice as discussed in Section 4.3 has been employed such that ductile behavior is maximized. If this is not the case (e.g., an existing facility constructed a number of years ago), lower inelastic demand-capacity ratios should be used than those presented herein.
2. Table 4-2 values assume that inelastic behavior will occur reasonably uniformly throughout the lateral load-carrying system. If inelastic behavior during seismic response is concentrated in local regions of the lateral load carrying system, lower inelastic demand-capacity ratios should be used than those presented herein.
3. Inelastic demand-capacity ratios are provided in Table 4-2 for the structural systems described in References 10 and 11. For other structural systems not covered in the table, engineers must interpolate or extrapolate from the values given based on judgement in order to evaluate inelastic demand-capacity ratios which are consistent with the intent of these guidelines.

A.7 Basis for Seismic Guidelines for Important or Low Hazard, Moderate Hazard, and High Hazard Facilities

The performance goal for General Use facilities is probability of exceedance of 1×10^{-3} for significant structural damage to the facility. It is judged that this goal is approximately met by following the 1988 UBC provisions (Reference 10) and with a probability of exceedance of 2×10^{-3} for the design/evaluation level peak ground acceleration. The facility demand for General Use facilities in accordance with the 1988 UBC provisions is based on maximum ground acceleration as described above, median spectral amplification at 5 percent damping, load factor of approximately 1.4, importance factor of unity, and reduction coefficients, as given in Table 4-2. This demand level is the baseline from which the design/evaluation demand level for other category facilities is determined as described below.

In the seismic design and analysis guidelines presented in Sections 4.2.2 and 4.2.3, the demand is compared to the ultimate capacity in order to assess the seismic adequacy of structures or equipment for all facility use categories. While the ultimate capacities are the same for all categories, the demand is different for each facility-use category, with larger demand values being computed for more hazardous categories. The larger values are indicative of the greater conservatism and reduced probability of damage or loss of capability to function associated with the higher hazard categories. Demand provides a good means for comparing guidelines among the various categories. The demand for General Use and Important or Low Hazard facilities due to earthquake ground motion in accordance with the provisions in Section 4.2.2, can be approximated by:

$$D = LF I k Z DAF_{5\%} W / R_w$$

(A-1)

where: LF = load factor
 I = importance factor
 I = 1.0 for General Use facilities
 I = 1.25 for Important or Low Hazard facilities
 Z = peak ground acceleration appropriate for General Use facilities (i.e., 2×10^{-3} exceedance probability)
 k = a factor by which the peak ground acceleration differs from that corresponding to the General Use category
 k = 1.0 for General Use facilities
 k = 1.25 for Important or Low Hazard facilities

In this section, peak ground acceleration for each category is expressed as kZ where Z is the General Use category peak ground acceleration and k is a factor accounting for the differences in peak ground accelerations among categories such that $k = 1.0$ for General Use facilities, $k = 1.25$ for Important or Low Hazard and Moderate Hazard facilities, and $k = 2.0$ for High Hazard facilities (k is the mean value of the ratio of peak ground acceleration at the exceedance probability for the category considered to peak ground acceleration at the General Use category exceedance probability determined from the Reference 1 seismic hazard curves).

$DAF_{5\%}$ = dynamic amplification factor from the 5 percent ground response spectrum at the natural period of the facility
 W = total weight of the facility
 R_w = reduction coefficient accounting for available energy absorption (Table 4-2)

The demand for Moderate and High Hazard facilities due to earthquake ground motion in accordance with the provisions in Section 4.2.3 can be approximated by:

$$D = m DAF_{5\%} k Z W / F_u$$

(A-2)

where: m = a factor accounting for the difference in spectral amplification from 5 percent to the damping appropriate for the facility in accordance with Table 4-4
 e.g., $m = 0.9$ for 7 percent damping
 $m = 0.8$ for 10 percent damping
 $m = 0.7$ for 15 percent damping
 (m values are from Reference 11)
 k = ground motion factor as defined above
 $k = 1.25$ for Moderate Hazard facilities
 $k = 2.0$ for High Hazard facilities
 F_u = inelastic demand-capacity ratio (Table 4-2)

For any facility-use category, the demand, D , is compared to the code ultimate capacity, CAP , to determine if the facility is adequate for earthquake ground motion. Note that the demand as expressed by Equations A-1 and A-2 is only a general approximation. The demand for specific cases depends on the particular characteristics of the input ground motion and earthquake response spectra, as well as the effect of other loadings acting concurrently on the facility. However, these approximations for the demand are utilized to establish seismic design and analysis guidelines such that the performance goals described in Chapter 2 are approximately met.

The relationship between performance goal exceedance probability and facility demand is used to determine the specific values making up the seismic design and analysis guidelines such that the performance goals described in Chapter 2 can be approximately met for earthquake considerations. This relationship is the same as the relationship between hazard exceedance probability and peak ground acceleration, as determined from the seismic hazard curves. Differences in hazard exceedance probabilities correspond to differences in peak ground acceleration for which the facility is to be designed or evaluated for earthquake effects. These differences can be evaluated from the Reference 1 hazard curves by comparing ground acceleration levels at different hazard exceedance probabilities. From the Reference 1 data presented in Table 4-3, the mean ratio of peak ground acceleration for Low and Moderate Hazard categories to that for the General Use category is about 1.25 (standard deviation is 0.08), and the mean ratio of peak ground acceleration for the High Hazard category to that for the General Use category is about 2.0 (standard deviation is 0.21). As a result, a difference in probability of 2 should also correspond to a difference in demand (or required facility capacity) of about 1.25, and a difference in performance goal probability of 10 should correspond to a difference in demand of about 2.0.

The relationships described above between performance goal exceedance probability and earthquake demand have been used to develop the specific limits on inelastic behavior and other seismic provisions for Important or Low Hazard, Moderate Hazard, and High Hazard categories. The differences in performance goal probability and facility demand between Important or Low Hazard, Moderate Hazard, and High Hazard categories and that for the General Use category are tabulated below.

Category	Ratio of Performance Goal to that for General Use Facilities	Ratio of Earthquake Demand to that for General Use Facilities
Important or Low Hazard	2	1.25
Moderate Hazard	10	2.0
High Hazard	100	4.0

However, it should be noted that the performance goals for Important or Low Hazard, Moderate Hazard, and High Hazard categories are different from the General Use category in both probability level and in acceptable structural behavior. The goal for General Use facilities is to prevent structural damage to the extent that occupants might be endangered. The goal for the other categories is to maintain the capability of the facility to perform its function. As a result, the facility demand for Important or Low Hazard, Moderate Hazard, and High Hazard facilities should be even more different from General Use facilities than is indicated above. The 1988 UBC provisions suggest an importance factor of 1.25 for essential facilities (similar to the Important or Low Hazard category herein) to account for the difference in performance goals between normal use and essential facilities. It seems reasonable that if the demand levels for Important or Low Hazard, Moderate Hazard, and High Hazard categories were all increased by an additional factor of 1.25 greater relative to the General Use category, the differences in performance goal behavior would be fully accounted for.

In addition, because of the increased hazard associated with Moderate and High Hazard facilities, it is judged to be appropriate to provide some additional conservatism such that very high confidence of achieving the performance goal can be achieved. For this reason, the facility demand for Moderate and High Hazard categories is further increased by an additional factor of about 1.25 relative to other categories. More factors of conservatism have been incorporated into the guidelines for Moderate and High Hazard facilities than for General Use and Important or Low Hazard facilities in order to obtain higher levels of confidence of achieving the performance goal for these facilities, which contain hazardous materials and which may be sensitive to public opinion such that damage is especially undesirable. These additional factors have the effect of restricting inelastic behavior to be more closely elastic and of limiting drift of the facility such that damage is controlled in the event of a severe earthquake.

Hence, assuming the performance goal for General Use facilities is achieved for seismic design by following the 1988 UBC provisions, performance goals for other categories would be achieved if the earthquake demand levels for other categories were as follows:

$$\begin{aligned} D_{ILH} / D_{GU} &= 1.25 \times 1.25 = 1.56 \\ D_{MH} / D_{GU} &= 1.25 \times 1.25 \times 2.0 = 3.13 \\ D_{HH} / D_{GU} &= 1.25 \times 1.25 \times 4.0 = 6.25 \end{aligned}$$

Note:

GU = General Use category
ILH = Important or Low Hazard category
MH = Moderate Hazard category
HH = High Hazard category

Based upon Equations (A-1) and (A-2), these differences in earthquake demand for Important or Low Hazard, Moderate Hazard, and High Hazard categories compared to that for the General Use category are given by the following equations (k and l for the General Use category are unity):

$$D_{ILH} / D_{GU} = I_{ILH} k_{ILH} = 1.56 \quad (A-3)$$

$$D_{MH} / D_{GU} = m k_{MH} R_w / (LF F_{U-MH}) = 3.13 \quad (A-4)$$

$$D_{HH} / D_{GU} = m k_{HH} R_w / (LF F_{U-HH}) = 6.25 \quad (A-5)$$

Note that using an importance factor of 1.25 for Important or Low Hazard facilities combined with a hazard exceedance probability which is one half that for General Use facilities is approximately equivalent to an importance factor of slightly more than 1.5 for Important or Low Hazard facilities if the hazard exceedance probabilities were the same for both categories as shown above. Hence, the guidelines presented herein for Important or Low Hazard facilities are somewhat more conservative than the 1988 UBC provisions for essential or hazardous facilities.

By these seismic design and analysis guidelines, Moderate and High Hazard facilities are to be evaluated by elastic dynamic analysis; however, the elastically computed demand on the facility is permitted to exceed the capacity of the facility as a means of permitting limited inelastic behavior in good structural systems with detailing for ductile behavior. The amount that the elastic demand can exceed the capacity is the inelastic demand-capacity ratio, F_u . Values for inelastic demand-capacity ratio, F_u , which when used with the seismic guidelines described in Section 4.2.3, assure that the performance goals presented in Chapter 2 are approximately met. A means of estimating F_u values which approximately meet the performance goals is described below.

Expressing the demand equations, (A-4) and (A-5) in general terms, the ratio of the demand for Moderate and High Hazard categories to that for the General Use category is:

$$\frac{D_{MH \text{ or } HH}}{D_{GU}} = \frac{(k)(m)R_w}{(LF)F_u} = RATIO \quad (A-6)$$

Where:

- k = 1.25 for Moderate Hazard
- k = 2.0 for High Hazard
- m = 0.9 for Steel (7% damping)
- m = 0.8 for Concrete (10% damping)
- m = 0.75 for Masonry (12% damping)
- m = 0.7 for Wood (15% damping)

LF = 1.3 for Steel
 LF = 1.4 for Concrete And Masonry
 LF = 1.5 for Wood
 RATIO = 3.13 for Moderate Hazard
 RATIO = 6.25 for High Hazard

Equation (A-6) may be solved for inelastic demand-capacity ratio, F_u , as follows:

$$F_u = \frac{(k)(m)R_w}{(LF)(RATIO)} \quad (A-7)$$

Example calculations of F_u for Moderate & High Hazard steel moment frames using Equation (A-7) are shown below:

MODERATE HAZARD	HIGH HAZARD
$k = 1.25$ $m = 0.9$ $R_w = 12$ $LF = 1.3$ RATIO = 3.13	$k = 2.0$ $m = 0.9$ $R_w = 12$ $LF = 1.3$ RATIO = 6.25
$F_u = \frac{(1.25)(0.9)(12)}{(1.3)(3.13)} = 3.32$	$F_u = \frac{(2.0)(0.9)(12)}{(1.3)(6.25)} = 2.66$
$F_u = 2.5$ IN DOD MANUAL $F_u = 3.0$ IN GUIDELINES	$F_u = 2.0$ IN DOD MANUAL $F_u = 2.5$ IN GUIDELINES

Example calculations of F_u for Moderate & High Hazard concrete shear walls in accordance with Equation (A-7) are shown below:

MODERATE HAZARD	HIGH HAZARD
$k = 1.25$ $m = 0.8$ $R_w = 8$ $LF = 1.4$ RATIO = 3.13	$k = 2.0$ $m = 0.8$ $R_w = 8$ $LF = 1.4$ RATIO = 6.25
$F_u = \frac{(1.25)(0.8)(8)}{(1.4)(3.13)} = 1.83$	$F_u = \frac{(2.0)(0.8)(8)}{(1.4)(6.25)} = 1.46$
$F_u = 1.5$ IN DOD MANUAL $F_u = 1.7$ IN GUIDELINES	$F_u = 1.25$ IN DOD MANUAL $F_u = 1.4$ IN GUIDELINES

Values of inelastic demand-capacity ratio, F_u , from Equation (A-7) along with values from the DOD seismic provisions (Reference 11), are presented in Table A-1 for many structural systems, materials, and construction.

TABLE A-1
INELASTIC DEMAND-CAPACITY RATIOS FROM
EQUATION A-7 AND REFERENCE 11

Structural System	R _w	F _u *			
		Moderate Hazard		High Hazard	
		R11	A-7	R11	A-7
MOMENT RESISTING FRAME SYSTEMS					
Columns	**	1.5	**	1.25	**
Beams					
Steel Special Moment Resisting Space Frame (SMRSF)	12	2.5	3.32	2.0	2.66
Concrete SMRSF	12	2.5	2.74	2.0	2.19
Concrete Intermediate Moment Frame (IMRSF)	7	-	1.60	-	1.28
Steel Ordinary Moment Resisting Space Frame	6	-	1.66	-	1.33
Concrete Ordinary Moment Resisting Space Frame	5	-	1.14	-	<1
SHEAR WALLS					
Concrete Bearing Walls	6	1.5	1.37	1.25	1.10
Concrete Non-Bearing Walls	8	1.5	1.83	1.25	1.46
Masonry Bearing Walls	6	1.25	1.29	1.1	1.03
Masonry Non-Bearing Walls	8	1.25	1.71	1.1	1.37
Plywood Bearing Walls	8	2.5	1.49	2.0	1.19
Plywood Non-Bearing Walls	9	2.5	1.68	2.0	1.34
Dual System, Concrete with SMRSF	12	1.5	2.74	1.25	2.19
Dual System, Concrete with Concrete IMRSF	9	1.5	2.06	1.25	1.65
Dual System, Masonry with SMRSF	8	1.25	1.71	1.1	1.37
Dual System, Masonry with Concrete IMRSF	7	1.25	1.50	1.1	1.20
CONCENTRIC BRACED FRAMES (BRACING CARRIES GRAVITY LOADS)					
Steel Beams	6	1.75	1.66	1.5	1.33
Steel Diagonal Braces	6	1.5	1.66	1.25	1.33
Steel Columns	6	1.5	1.66	1.25	1.33
Connections of Steel Members	6	1.25	1.66	1.0	1.33
Concrete Beams	4	1.75	<1	1.5	<1
Concrete Diagonal Braces	4	1.5	<1	1.25	<1
Concrete Columns	4	1.5	<1	1.25	<1
Connections of Concrete Members	4	1.25	<1	1.0	<1
Wood Trusses	4	1.75	<1	1.5	<1
Wood Columns	4	1.5	<1	1.25	<1
Connections in Wood (other than nails)	4	1.5	<1	1.25	<1
CONCENTRIC BRACED FRAMES (NO GRAVITY LOADS)					
Steel Beams	8	1.75	2.22	1.5	1.77
Steel Diagonal Braces	8	1.5	2.22	1.25	1.77
Steel Columns	8	1.5	2.22	1.25	1.77
Connections of Steel Members	8	1.25	2.22	1.0	1.77
Concrete Beams	8	1.75	1.83	1.5	1.46
Concrete Diagonal Braces	8	1.5	1.83	1.25	1.46
Concrete Columns	8	1.5	1.83	1.25	1.46
Connections of Concrete Members	8	1.25	1.83	1.0	1.46
Wood Trusses	8	1.75	1.49	1.5	1.19
Wood Columns	8	1.5	1.49	1.25	1.19
Connections in Wood (other than nails)	8	1.5	1.49	1.25	1.19
Beams and Diagonal Braces, Dual Systems					
Steel with Steel SMRSF	10	-	2.77	-	2.22
Concrete with Concrete SMRSF	9	-	2.06	-	1.65
Concrete with Concrete IMRSF	6	-	1.37	-	1.10
STEEL ECCENTRIC BRACED FRAMES (EBF)					
Columns	**	1.5	**	1.25	**
Beams and Diagonal Braces	10	-	2.77	-	2.22
Beams and Diagonal Braces, Dual System with Steel SMRSF	12	-	3.32	-	2.66

* Columns marked R11 are inelastic demand-capacity ratios directly from Reference 11. Columns marked A-7 are inelastic demand-capacity ratios calculated from Equation (A-7).

** Values are the same as for beams and braces in this structural system

9 2 1 2 1 9 3 1 9 3 7

The inelastic demand-capacity ratios from Equation (A-7) are based on the structural systems for which reduction coefficients, R_w , are given in the 1988 UBC provisions. These provisions give different reduction coefficients for bearing wall systems and for building frame systems in which gravity loads are carried by different structural members than the lateral force resisting system. In addition, the 1988 UBC provisions distinguish between different levels of detailing for moment resisting space frames, between eccentric and concentric braced frames, and between single and dual lateral load resisting systems. Consequently, Equation (A-7) results in more inelastic demand-capacity ratios than Reference 11, which does not make the above distinctions. On the other hand, DOD provisions give different inelastic demand-capacity ratios for individual members of the lateral load-resisting system, while 1988 UBC reduction coefficients refer to all members of the lateral load resisting system.

In general, there is reasonable agreement between the inelastic demand-capacity ratios from Reference 11 and those computed from Equations (A-7). For example, the DOD inelastic demand-capacity ratio for concrete shear walls is between the values for bearing and non-bearing walls from the equations. The DOD values are much lower than the values computed when shear walls act as a dual system with ductile moment resisting space frames to resist seismic loads. The inelastic demand-capacity ratios for braced frames agree fairly well in the case where the bracing carries no gravity loads. When bracing carries gravity loads, values for steel braced frames are in good agreement, but based on Equation (A-7), no inelastic behavior would be permitted for concrete braced frames or wood trusses. The DOD inelastic demand-capacity ratio for beams in a ductile moment resisting frame fall between values from the equations for special and intermediate moment resisting space frames (SMRSF and IMRSF as defined in Reference 10). However, the DOD values for columns are low compared to values derived from the code reduction coefficients.

Based upon the data presented in Table A-1, the inelastic demand-capacity ratios for seismic design and analysis of Moderate and High Hazard facilities presented in Table 4-2 have been selected. Because of the reasonable agreement with the DOD values from Reference 11 combined with the capability to distinguish between a greater number of structural systems, the values derived from Equation (A-7) have been given somewhat more weight for Table 4-2 than Reference 11 values. The only major exception is that Reference 11 values for columns have been utilized. Increased conservatism for columns as recommended in the DOD manual is retained. In addition, Reference 11 provides slightly different values for different members making up braced frames, and these differences are retained.

9 2 1 2 1 3 3 1 9 3 3

In Section 4.2.3, Moderate and High Hazard facilities must meet minimum seismic requirements of the 1988 UBC static force method provisions with an importance factor, I , of 2.0 and peak ground acceleration corresponding to Moderate or High Hazard category hazard exceedance probabilities, respectively. The purpose of these additional seismic requirements is twofold. First, these requirements provide a relatively simple approach to establish reasonable initial designs of facilities to be evaluated for earthquake effects by dynamic analyses as required for these categories. Second, the 1988 UBC type provisions may govern the seismic design in cases where structural members are heavily loaded by dead and live loadings in addition to earthquake excitation. 1988 UBC and DOD seismic provisions differ. In the 1988 UBC approach, only the element forces due to earthquake loads are reduced by the reduction coefficient, R_w , in evaluating facility demand. In the DOD approach, element forces due to both earthquake and dead and live loads are reduced by the inelastic demand-capacity ratio, F_u , in evaluating the facility demand. The effect of these differences is that the DOD approach may be less conservative for beam or brace members heavily loaded by dead and live loads. The minimum 1988 UBC type seismic requirements assure that Moderate and High Hazard requirements are substantially more stringent than those for the Important or Low Hazard category, even if members have significant dead and live loadings.

**THIS PAGE INTENTIONALLY
LEFT BLANK**

REFERENCES

- 1 Coats, D.W. and R.C. Murray, "Natural Phenomena Hazards Modeling Project: Seismic Hazard Models for Department of Energy Sites," UCRL-53582 Rev. 1, Lawrence Livermore National Laboratory, Livermore, California, 1984.
- 2 Coats, D.W. and R.C. Murray, "Natural Phenomena Hazards Modeling Project: Extreme Wind/Tornado Hazard Models for Department of Energy Sites," UCRL-53526 Rev. 1, Lawrence Livermore National Laboratory, Livermore, California, 1985.
- 3 Savy, J.B. and R.C. Murray, "Natural Phenomena Hazards Modeling Project: Flood Hazard Models for Department of Energy Sites," UCRL-53851, Lawrence Livermore National Laboratory, Livermore, California, 1988.
- 4 "Suspended Ceiling System Survey and Seismic Bracing Recommendations," UCRL-15714 S/C 5110600, prepared by ED2 International, San Francisco, CA, for Lawrence Livermore National Laboratory, August 1985.
- 5 Hom, S., R. Kincaid, and P.I. Yanev, "Practical Equipment Seismic Upgrade and Strengthening Guidelines," UCRL-15815, EQE Incorporated, San Francisco, California, September, 1986.
- 6 "The Effects of Natural Phenomena on the Exxon Nuclear Company Mixed Oxide Fabrication Plant at Richland, Washington," NUREG-0722, Docket No. 70-1257, Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, Washington, D.C., September 1980.
- 7 Ayer, J.E. and W. Burkhardt, "Analysis of the Effects of Abnormal Natural Phenomena on Existing Plutonium Fabrication Plants," Proceedings of the ANS Topical Meeting on the Plutonium Fuel Cycle, Bal Harbour, FL, May 2-4, 1977.
- 8 U.S. Nuclear Regulatory Commission, "Policy Statement on Safety Goals," **Federal Register**, Vol. 51, pg. 30028, Aug. 21, 1986.
- 9 U.S. Department of Energy, **General Design Criteria**, DOE Order 6430.1A, Washington, D.C., 1987 (draft).
- 10 **Uniform Building Code**, 1988 Edition, International Conference of Building Officials, Whittier, California, 1988.
- 11 **Seismic Design Guidelines for Essential Buildings (A Supplement to "Seismic Design for Buildings")**, Army TM5-809-10.1, Navy NAVFAC P-355.1, Air Force AFM 88-3, Chapter 13.1, Departments of the Army, Navy and Air Force, Washington, D.C., February, 1986.
- 12 "Earthquake Resistant Design of Nuclear Facilities with Limited Radioactive Inventory," IAEA-TECDOC-348, International Atomic Energy Agency, Vienna, 1985.
- 13 DOE 5481.1B, Safety Analysis and Review System (SARS), U.S. Department of Energy, Washington, D.C.

- 9 2 1 2 1 3 1 9 1 0
- 14 NFPA 13, Installation of Sprinkler Systems, National Fire Protection Association, Quincy, MA.
 - 15 **National Building Code of Canada and Supplement**, 1980, NRCC No. 17303, Associate Committee on the National Building Code, National Research Council of Canada, Ottawa, 1980.
 - 16 **Minimum Design Loads for Buildings and Other Structures**, ANSI A58.1-1982, American National Standards Institute, New York, New York, 1982.
 - 17 "Millstone 3 Probabilistic Safety Study," Northeast Utilities, Connecticut, August, 1983.
 - 18 "Zion Probabilistic Safety Study," Commonwealth Edison Company, Chicago, Illinois, 1981.
 - 19 "Indian Point Probabilistic Safety Study," Power Authority of the State of New York, 1982.
 - 20 "Severe Accident Risk Assessment, Limerick Generating Station," Philadelphia Electric Company, April, 1983.
 - 21 Manual of Professional Practice, "Quality in the Constructed Project," for Trial Use and Comment, American Society of Civil Engineers, October 1987.
 - 22 Kennedy, R.P. and S.A. Short, "Seismic Analysis," Lawrence Livermore National Laboratory report UCRL-15742, October 1985.
 - 23 Nicoletti, J.P., L.E. Malik, and P.G. Griffin, "Seismic Design," Lawrence Livermore National Laboratory report UCRL-15744, October 1985.
 - 24 Yanev, P.I., S. Hom, C.A. Kirtcher, and N.D. Bailey, "Emergency Preparedness," Lawrence Livermore National Laboratory report UCRL-15746, October 1985.
 - 25 Newmark, N.M. and W.J. Hall, "Development of Criteria for Seismic Review of Selected Nuclear Power Plants," NUREG/CR-0098, U.S. Nuclear Regulatory Commission, May 1978.
 - 26 Seed, H.B., et al., "Site-Dependent Spectra for Earthquake Resistant Design," Report No. EERC 74-12, University of California, Berkeley, 1974.
 - 27 Kiremidjian, A.S. and H.C. Shah, "Probabilistic Site-Dependent Response Spectra," Journal of the Structural Division, Proceedings of the ASCE, Vol. 106, No. ST1, January 1980, pp. 69-86.
 - 28 **Recommended Lateral Force Requirements and Tentative Commentary**, Seismology Committee, Structural Engineers Association of California, San Francisco, California, 1988.
 - 29 Power, M.S., C.Y. Chang, I.M. Idriss, and R. P. Kennedy, "Engineering Characterization of Ground Motion - Summary Report," NUREG/CR-3805, Vol. 5, prepared for U.S. Nuclear Regulatory Commission, August, 1986.

- 30 Seed, H.B., and Idriss, I.M. (1970), "Soil Moduli and Damping Factors for Dynamic Response Analyses," Report No. EERC 70-10, Earthquake Engineering Research Center, University of California, Berkeley, California.
- 31 Seed, H.B., Wong, R.T., Idriss, I.M. and Tokimatsu, K. (1984), "Moduli and Damping Factors for Dynamic Analyses of Cohesionless Soils," Report No. UCB/EERC-84/14, Earthquake Engineering Research Center, University of California, Berkeley, California.
- 32 Kausel, E., R.V. Whitman, F. Elsabee, and J.P. Morray, "Dynamic Analysis of Embedded Structures," **Transactions, Fourth International Conference on Structural Mechanics in Reactor Technology**, San Francisco, Paper K2/6, Vol. K(a), 1977.
- 33 Kausel, E. and R. Ushijima, "Vertical and Torsional Stiffness of Cylindrical Footings," MIT Research Report R79-6, Dept. of Civil Engineering, Massachusetts Institute of Technology, February, 1979.
- 34 **Seismic Analysis of Safety-Related Nuclear Structures and Commentary on Standard for Seismic Analysis of Safety-Related Nuclear Structures**, Reference 582, American Society of Civil Engineers (ASCE), April, 1987.
- 35 Luco, J.E., "Impedance Functions for a Rigid Foundation on a Layered Medium," **Nucl. Engin. Design**, Vol. 31, 1974.
- 36 Johnson, J.J., "Soil-Structure Interaction: The Status of Current Analysis Methods and Research," U.S. Nuclear Regulatory Commission, NUREG/CR-1780, 1981.
- 37 Singh, M.P., "Generation of Seismic Floor Spectra," **Journal of the Engineering Mechanics Division**, ASCE, Vol. 101, No. EM5, October, 1975.
- 38 Singh, M.P., "Seismic Design Input for Secondary Systems," **Journal of the Structural Division**, ASCE, Vol. 106, No. ST2, Proc. Paper 15207, pp. 505-517, February, 1980.
- 39 Scanlan, R.H., and K. Sachs, "Floor Response Spectra for Multi-degree-of-freedom Systems by Fourier Transformation," Paper K 5/5, Third International Conference on Structural Mechanics in Reactor Technology, London, September, 1975.
- 40 Yanev, P.I., S.W. Swan, N.P. Smith, and J.E. Thomas, "A Summary of the Seismic Qualification Utilities Group (SQUG) Program," **Transactions of the 8th International Conference on Structural Mechanics in Reactor Technology**, Brussels, Belgium, Paper D 9/3, Vol. D. 1985.
- 41 Kennedy, R.P., W.A. Von Riesemann, P. Ibanez, A.J. Schiff, and L.A. Wyllie, "Use of Seismic Experience and Test Data to Show Ruggedness of Equipment in Nuclear Power Plants," Senior Seismic Review and Advisory Panel, prepared for the Seismic Qualification Utility Group and in cooperation with the Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, October, 1987.
- 42 Smith, C.B., and K.L. Merz, "Seismic Ruggedness of Nuclear Plant Equipment," ANCO Engineers, prepared for Electric Power Research Institute, December, 1986.

- 9 2 2 2 3 1 9 1 2 6 1 3 6 1 2 1 2 6
- 43 "Seismic Verification of Nuclear Plant Equipment Anchorage," URS Corporation, prepared for Electric Power Research Institute, May 1987.
 - 44 American Concrete Institute, **Code Requirements for Nuclear Safety Related Concrete Structures (ACI 349-85) and Commentary - ACI 349R-85**, Detroit, Michigan, 1985.
 - 45 American Institute of Steel Construction, **Manual of Steel Construction**, Eighth Ed., Chicago, Illinois, 1980.
 - 46 **Seismic Design Guidelines for Upgrading Existing Buildings, (A Supplement to "Seismic Design of Buildings")**, Joint Departments of the Army, Navy, and Air Force, USA, Technical Manual TM 5-809-10-2/NAVFAC P-355.2/AFM 88-3, Chapter 13.2, December, 1986.
 - 47 Applied Technology Council (ATC), **ATC-3-06, Tentative Provisions for the Development of Seismic Regulations for Buildings**, Palo Alto, California, 1978.
 - 48 Algermissen, S.T., and Perkins, D.M., "A Probabilistic Estimate of Maximum Acceleration in Rock in the Contiguous United States," U.S. Geological Survey Open File Report No. 76-416, 1976.
 - 49 Bernreuter, D.L., et al, "Seismic Hazard Characterization of the Eastern United States, Vol. 1 - Methodology and Results for Ten Sites," UCID-20421 Vol. 1, Lawrence Livermore National Laboratory, April, 1985.
 - 50 Riddell, R. and Newmark, N.M. (1979), "Statistical Analysis of the Response of Nonlinear Systems Subjected to Earthquakes," SRS 468, Department of Civil Engineering, University of Illinois, Urbana, August.
 - 51 Wang, T.Y., Bertero, V.V. and Popov, E.P. (1975), "Hysteretic Behavior of Reinforced Concrete Framed Walls," Report No. EERC 75-23, EERC, University of California, Berkeley.
 - 52 Wakabayashi, M. et al, (1973), "Inelastic Behavior of Steel Frames Subjected to Constant Vertical and Alternating Horizontal Loads," **Proceeding of the Fifth World Conference on Earthquake Engineering**, Rome, Vol. I, pp. 1194-1197.
 - 53 McDonald, J.R., "Extreme winds and tornadoes: an overview," Lawrence Livermore National Laboratory report UCRL-15745, October 1985.
 - 54 McDonald, J.R., "Extreme winds and tornadoes: design and evaluation of buildings and structures," Lawrence Livermore National Laboratory report UCRL-15747, October 1985.
 - 55 American Concrete Institute, **Building Code Requirements for Reinforced Concrete, AC 318-83**, Detroit, Michigan, 1983.
 - 56 Minor, J.E., McDonald, J.R. and Mehta, K.C., "The Tornado: An Engineering Oriented Perspective," NOAA Tech Memo ERL NSSL-82, National Severe Storms Laboratory, Norman, Oklahoma, December 1977.

- 57 McCann, M.W. and H.J. Owen, "Overview of flood considerations," Lawrence Livermore National Laboratory report UCRL-15743, October 1985.
- 58 U.S. Nuclear Regulatory Commission, "Regulatory Guide 1.59, Design Basis Floods for Nuclear Power Plants," Revision 2, August, 1977.
- 59 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 1: Methodology," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 60 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 2: Bendix Plant, Kansas City, Missouri," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 61 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 3: Mound Facility, Miamisburg, Ohio," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 62 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 4: Pinellas Plant, St. Petersburg, Florida," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 63 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 5: Sandia National Laboratory, Livermore, California," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 64 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 6: Los Alamos Scientific Laboratory, Los Alamos, New Mexico," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 65 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 7: Rocky Flats Plant, Golden, Colorado," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 66 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 8: Pantex Plant, Amarillo, Texas," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.

- 67 Jack R. Benjamin and Associates, Inc., "Natural Phenomena Hazards Modeling Project: Preliminary Flood Hazard Estimates for Screening Department of Energy Sites, Part 9: Sandia Laboratories, Albuquerque, New Mexico," JBA Report 105-140, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1987.
- 68 Jack R. Benjamin and Associates, Inc., "Probabilistic Flood Hazard Assessment for the N-Reactor, Hanford, Washington," JBA Report 105-130, prepared for Lawrence Livermore National Laboratory, Mountain View, California, 1988.
- 69 Federal Insurance Administration, Federal Emergency Management Agency, "Exhibit 1, Flood Insurance Manual Revision," Washington D.C., October, 1980.
- 70 U.S. Army Corps of Engineers, "Shore Protection Manual," U.S. Army Coastal Engineering Research Center, Waterways Experiment Station, Vicksburg, Mississippi, 1978.
- 71 U.S. Department of the Interior, **Guidelines to Decision Analysis**, ACER Technical Memorandum No. 7, Bureau of Reclamation, Denver, Colorado, 1986.
- 72 **Design of Small Dams**, U.S. Bureau of Reclamation, Department of the Interior, Washington, D.C. 1977.
- 73 Merritt, F. S. (ed.), **Standard Handbook for Civil Engineering**, McGraw-Hill Company, 1968.
- 74 Streeter, V. L., **Fluid Mechanics**, McGraw-Hill Book Company, 1971.
- 75 Linsley, R. K. and J. B. Franzini, **Water-Resources Engineering**, McGraw-Hill Book Company, New York, 1964.
- 76 U.S. Department of Agriculture, **National Engineering Manual**, Soil Conservation Service, 1980.
- 77 U. S. Army Corps of Engineers, "Design and Construction of Levees," EM 110-2-1913, Department of the Army, Office of the Chief of Engineers, Washington, D.C., 1978.
- 78 Brookhaven National Laboratory, "Probabilistic Safety Analysis Procedures Guide," prepared for U.S. Nuclear Regulatory Commission, NUREG/CR-2815, BNL/NUREG-51559 Rev., Vols. 1 and 2, 1985.
- 79 American Nuclear Society and Institute of Electrical and Electronic Engineers, "PRA Procedures Guide," prepared for U.S. Nuclear Regulatory Commission, NUREG/CR-2300, January, 1983.
- 80 McCann, Jr., M. W., "An Introduction to Flood Probabilistic Risk Assessment Methodology," Proceedings, Department of Energy Natural Phenomena Hazards Mitigation Conference, Las Vegas, Nevada, October, 1985.

- 81 Interagency Advisory Committee on Water Data, "Feasibility of Assigning a Probability to the Probable Maximum Flood," prepared by the Work Group on Probable Maximum Flood Risk Assessment, Hydrology Subcommittee, Office of Water Data Coordination, 1986.
- 82 U.S. Department of the Interior, "Guidelines for Determining Flood Flow Frequency," Interagency Advisory Committee on Water Data, Bulletin #17B of the Hydrology Subcommittee, Reston, Virginia, 1982.
- 83 Kite, G. W., "Frequency and Risk Analysis in Hydrology," Water Resources Publication, Littleton, Colorado, 1977.
- 84 American Society of Civil Engineers, "Evaluation Procedure for Hydrologic Safety of Dams," Task Committee on Spillway Design Flood Selection, Surface Water Hydrology Committee Hydraulics Division, September, 1987.
- 85 Wagner, D. D., J. J. Rooney and J. B. Fussell, "A Flood Analysis of the Surry Power Station Unit 1, Auxiliary Feedwater System," JBF Associates, JBFA-109-80, 1980.

**THIS PAGE INTENTIONALLY
LEFT BLANK**